



**MDNR CONSUMPTIVE WATER USE STUDY - APPENDIX**  
**FOR THE**  
**MINNESOTA DEPARTMENT OF NATURAL RESOURCES**  
**FEBRUARY, 1990**

LEGISLATIVE REFERENCE LIBRARY  
615 Gore-Luce Building  
Saint Paul, Minnesota 55155

TK  
1055  
.M36  
1990  
append.

MAY 1 1990



**MDNR CONSUMPTIVE WATER USE STUDY - APPENDIX  
FOR THE  
MINNESOTA DEPARTMENT OF NATURAL RESOURCES  
FEBRUARY, 1990**

**Prepared By:**

**ORR-SCHELEN-MAYERON & ASSOCIATES, INC.  
2021 East Hennepin Avenue  
Suite 238  
Minneapolis, MN 55413  
(612) 331-8660**

**OSM Commission #4485**



APPENDIX TABLE OF CONTENTS

GENERAL CALCULATIONS

ASSUMPTIONS (ELECTRIC COSTS, PUMPING FORMULAS)

LIFE CYCLE COST COMPARISONS

WATER TREATMENT

COOLING TOWERS - WATER MAKE-UP

ECONOMIC AND KW IMPACT

TOTAL ELECTRIC REQUIREMENTS

ENVIRONMENTAL IMPACT - NSP

TABLE 24

TABLE 33

TABLE 34

FACILITY ANALYSIS - (GENERAL MILLS, GAVIIDAE COMMONS  
HONEYWELL AVIONICS, METHODIST HOSPITAL)

SUMMARY - ANNUAL OPERATING COSTS

TON-HOURS

WELL WATER OPERATING COSTS

CONVERSION OPERATING COSTS

PEAK DAY TONS

TOTAL FIRST COSTS - CONVERSION

MANUFACTURER OPERATING DATA: CHILLERS, COMPUTER ROOM UNITS, HEAT  
PUMPS, DISTRICT COOLING & HEATING

TOWER SELECTION

GEOHERMAL SURVEY INFO

## APPENDIX

### Calculations

#### ASSUMPTIONS

##### Electrical Costs.

A value of \$.045/KWH will be assumed.

##### Pumping Costs.

In cases where the brake horsepower or head pressure of the pump is not known, it is assumed that the motor is loaded to 85% of rated horsepower. Where motor efficiency is not known, a 90% value for efficiency is assumed.

$$\text{HP} \times .746 \frac{\text{KW}}{\text{HP}} \times .85 \text{ LOADING} \times \frac{1}{.90 \text{ EFFICIENCY}} \times \frac{\$.045}{\text{KWH}} = \frac{\$}{\text{HR}}$$

##### Chiller Capacity.

$$\text{Chilled Water Pumps} \quad \text{Tons} = \frac{\text{GPM} \times \text{TD}}{24}$$

$$\text{Condenser Water Pumps} \quad \text{Tons} = \frac{\text{GPM} \times \text{TD}}{30} \quad (\text{Where Condenser Heat Rejection is } 1.25 \times \text{Capacity} = 1.25 \times 24 = 30)$$

##### Annual Operating Costs.

$$\frac{\text{Pumps}}{\text{HP}} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$.045}{\text{KWH}} \times \frac{\text{OPERATING HRS}}{\text{YEAR}} = \frac{\$}{\text{YEAR}}$$

$$\frac{\text{Chillers/Heat Pumps}}{\text{KW}} \times \frac{\text{HR}}{\text{YR}} \times \frac{\$.045}{\text{KWH}} = \frac{\$}{\text{YR}}$$

(Where KW Input Data is Available at Operating Conditions)

- OR -

$$\text{TONS} \times \frac{\text{KW}}{\text{TON}} \times \frac{\text{HR}}{\text{YR}} \times \frac{\$.045}{\text{KWH}} = \frac{\$}{\text{YR}}$$

(Where KW/Ton is Estimated for Particular Device and Condenser EWT/LWT)

APPENDIX

LIFE CYCLE COST CALCULATIONS

1 of 2

ASSUME: 20 YRS, 8% DISCOUNT (COST OF \$), NO SALVAGE VALUE

A) ESCALATION CALC - ELECTRICAL COSTS ESCALATE @ 5%/YR

DEF= DISCOUNT-ESCALATION FACTOR, DEF  
WHERE; DEF BASED ON N=20, E=5, D=8  
(DEF 20,5,8) = 15.07582  
source; DEF Tables in  
"life Cycle Costing"  
Robt J. Brown & Rudolph R. Ynuck  
Fairmont Press, 1980

B) ESCALATION CALC - WATER TREATMENT & MISC COSTS @ 4%/YR

DEF = DISCOUNT-ESCALATION FACTOR  
(DEF 20,4,8) = 13.77

C) RESULTANT PRESENT WORTH

PW = ANNUAL OPER COST x DEF

WHERE ; PW= PRESENT WORTH IN 1989 DOLLARS FOR  
20 YR OPER, 8% COST OF MONEY, DEF  
AT (4 OR 5)% ESCALATION.

NOTE: SUNK COSTS (EXISTING INSTALLATIONS)  
NOT INCL: PW IS FOR OPER FROM 1989  
FORWARD. FIRST COSTS OF CONVERSION  
ARE COST x 1.0 IN 1989 DOLLARS.

LIFE CYCLE COSTING - BROWN & YANUCH  
FAIRMOUNT PRESS, 1980

N = 20 20 yrs  
D = 8% (COST OF \$) = DISCOUNT  
E = 4% OR 5% = ESCALATION  
; DEF = DISCOUNT-ESCALATION FACTOR

PW = A x DEF      PW = PRESENT WORTH, A = ANNUAL

$$DEF = \frac{(1+e)}{1+i} + \frac{(1+e)^2}{(1+i)^2} \dots \frac{(1+e)^n}{(1+i)^n} \quad \text{EQUA 10-1}$$

TABLE

N = 20  
D = 8  
E = 5 → DEF = 15.07582

CALCULATE EQUA 10-1

N = 20  
D = 8  
E = 4

DEF = 13.77





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 3  
Comm. No. 4485.00 Date 10/19/89

APPENDIX

WATER TREATMENT  
INSTALLATION AND OPERATING COSTS

A) FIRST COST

1) ACID PROGRAM

BASED ON DEARBORN CO. QUOTE 10/9/89

1800 GPM SYSTEM : COST = \$4033

INCREASE PUMPS + TANKS FOR LARGER

SYSTEMS : 2750 GPM

$$4033 + \left[ \text{PUMP } \$558 \times \left( \frac{2750}{1800} \right) + \text{TANK } \$123 \left( \frac{2750}{1800} \right) \right] - 558 - 123 = \$4392$$

3860 GPM =

$$4033 + \left[ (558 + 123) \left( \frac{3860}{1800} \right) \right] - 558 - 123 = \$4812$$

4050 GPM

$$4033 + \left[ (558 + 123) \left( \frac{4050}{1800} \right) \right] - 558 - 123 = \$4824$$

FIRST COST OF WATER TREATMENT IS SMALL  
RELATIVE TO TOWER COST (~53-60\$/TON)  
AND TOWER INSTALLATION — THE WATER  
TREATMENT FIRST COST WILL BE ROLLED INTO  
TOTAL 30% CONTINGENCY USED IN FIRST COST.

**OPERATING COSTS - CHEMICAL TREATMENT**

ASSUME: CITY OF ST. PAUL, TOTAL HARDNESS = 28.2

ALKALINITY = 56

ASSUME: TOWER WATER TEMP  $\Delta T = 95 - 85 = 10^\circ$ , WB =  $78^\circ$

THEREFORE RANGE =  $10^\circ$ , APPROACH =  $7^\circ$

CALCULATE MAKE-UP (MU) GALLONS

BASED ON DESIRED CHLORINE CONCENTRATION OF 750 PPM & CHLORINE CONCENTRATION OF MAKEUP WATER IS 250 PPM,

NUMBER CYCLES =  $750 / 250 = 3$

1) EVAPORATION RATES

2750 GPM  $10^\circ \Delta T \rightarrow 27.5$  GPM

3864 GPM  $10^\circ \Delta T \rightarrow 38.6$  GPM

4050 GPM  $\rightarrow 40.5$  GPM

2) BLOW-DOWN RATES @ 3 CYCLES

2750 GPM = 9 GPM

3864 GPM = 19.4 GPM

4050 GPM = 20.5 GPM

TOTAL MAKE-UP = EVAP + BLOW-DOWN = TOTAL

GARDAET	2750 :	27.5 + 9	= 36.5 GPM
GENERAL MILLS	3864 :	38.6 + 19.4	= 58.0
HONEYWELL	4050 :	40.5 + 20.5	= 61.0
METHODIST	3441 :	38.6 + 19.4	= 58



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 3 of 3  
Comm. No. 4485.00 Date 10/19/89

WATER TREATMENT COSTS (CONT'D)

SYSTEM GPM	MAX FLOW GPM	GAL/DAY	* GAL/YR
2750	36.5	$\frac{GAL}{MIN} \times \frac{60 MIN}{HR} \times \frac{24 HR}{DAY}$	52,560
3864	58.0		83,520
4050	61.0		87,840

\* LOAD FACTOR OF 90% ASSUMED.

ACID PROGRAM - (DEARBORN CO.)

PolyEph 975 @ \$ .04 / 100 GAL MU  
(SCALE & CORROSION INHIBITOR)

ACID @ .0266 / 100 GAL MU

DEARCIDE 712 @ \$ 22,500 ANNUAL ONE-TIME PURCHASE  
(BIOCIDE / ALGAEICIDE)

DEARCIDE 735 @ \$ 153 ANNUAL ONE-TIME PURCHASE  
(BIOCIDE / ALGAEICIDE) TTL = 378

TOTAL COSTS ANNUAL TREATMENT COST

SYSTEM GPM	GAL MAX FLOW	TOWER HRS	ACID + SCALE INHIB	ALGAEICIDE	TOTAL
2750	36.5 $\frac{GAL}{MIN} \times \frac{60 MIN}{HR}$	1450	$(.04 + .0266) / 100$	+ 378	= \$ 2493
3864	58 GPM	1700 HOURS		378	= 4318
4050	61 GPM	2700		378	= 6959
3864	58 GPM	2100 HOURS		378	= 5245

②

COOLING TOWERS — WATER MAKEUP

A) A MAXIMUM RATE OF MAKE-UP WATER AS A PERCENT OF TOTAL WATER CIRCULATED IS 5%. THIS WAS A FIGURE OFFERED BY MEMBERS OF ONCE-THROUGH ADVISORY GROUP AT JAN 9, 1990 MEETING AT MDNR AND GENERALLY AGREED AS ACCURATE.

THIS WAS USED IN "METHODS AND MEASURES" SECTION. IT IS A HIGH FIGURE REPRESENTING A MAXIMUM RATE OF MAKE-UP REQUIREMENTS.

EXAMPLE 1: GENERAL MILLS AT 1284 TONS =  $\frac{GPM \times 10}{30} \text{ RANGE} \Rightarrow GPM = 3852$   
 $MAKE-UP = 3852 \times .05 = 192.6 \text{ GPM}$

EXAMPLE 2: USED IN "METHODS & MEASURES"  
 A TYPICAL 100 TONS  
 $100 \text{ TONS} = \frac{GPM \times 10}{30} \Rightarrow GPM = 300$   
 $MAKEUP = 300 \times .05 = 15 \text{ GPM}$

B) ACTUAL RATES OF MAKE-UP

ARE TYPICALLY LESS THAN 5% — MAY BE 1.5% TO 2% DEPENDING ON CONDITIONS.



WATER MAKE-UP  
B) (CONTINUED) ACTUAL RATES OF MAKE-UP

1) SOURCE: "COOLING TOWER FUNDAMENTALS"  
MARLEY COOLING TOWER CO,  
MISSION, KANSAS  
ED. JOHN C. HENSLEY, 1982

PERCENT EVAPORATION = RANGE x .08 %  
PERCENT DRIFT = .02 %  
PERCENT BLOWDOWN = (GRAPH @ 10° RANGE &  
3<sup>#</sup> CONCENTR) = .4 %

FOR 10° RANGE, 25/15, 3<sup>#</sup> OF CONCENTRATIONS;  
E = 10 x .08 = .80 %  
D = .02 %  
B = .40 %  
1.22 %

EX, 1 GEN'L MILLS @ 3852 GPM @ 10° RANGE & 3<sup>#</sup> CON  
3852 x .0122 = 47.0 GPM MU

2) SOURCE: BETZ CO. OF TREBOURNE, PENN.

"COOLING WATER CALCULATIONS"  
CALCULATOR: © 1979

EX, 1 GEN'L MILLS @ 3852, 3 CONCENTR, 10° RANGE  
EVAP = 38.5  
BLOWDN = 19.4  
TTL 57.9 GPM

57.9 / 3852 = .01503 = 1.5 % MAKE-UP

THIS WAS THE METHOD USED TO CALCULATE  
MAKE-UP REQUIREMENTS IN THE ANNUAL  
COSTS OF CONVERSION FOR THE 4 FACILITIES.

APPENDIX

ECONOMIC & KW IMPACT

```

. SUM MBH
  125 records summed
    MBH
    567653.9

47304 TONS

. SUM R_MGY
  125 records summed
    R_MGY REPORTED 1987 MGY
    11158.0
. SUM MBH FOR USE='CW COIL'
  37 records summed
    MBH 9143 TONS
    109718.5
. SUM MGY FOR USE = 'CW COIL'
  Variable not found.
  ?
SUM MGY FOR USE = 'CW COIL'
. SUM R_MGY FOR USE='CW COIL'
  37 records summed
    R_MGY
    3399.0

. SUM MBH FOR USE='CHILLER'
  10 records summed
    MBH 10500 TONS
    126005.0
. SUM R_MGY FOR USE='CHILLER'
  10 records summed
    R_MGY
    2001.1
. SUM MBH FOR USE='HEAT P'
  11 records summed
    MBH 3953 TONS
    47440.6
. SUM R_MGY FOR USE='HEAT P'
  11 records summed
    R_MGY
    1490.6
. SUM MBH FOR USE='COND'
  43 records summed
    MBH 21778 TONS
    261339.8
. SUM R_MGY FOR USE='COND'
  43 records summed
    R_MGY
    4017.4
. QUIT
*** END RUN dBASE III PLUS

```



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 1  
Comm. No. 4485.00 Date 2/7/90

TOTAL ELECTRICAL REQMTS

KW IMPACT BASED ON A SUM  
OF KW OF EACH CATEGORY X KW/TON  
OF EACH CATEGORY —

KW/TON BASED ON CALCULATIONS AS USED  
IN "SEVEN TYPICAL SYSTEMS"

CW COIL (ITEM D) KW  
9143 x (50-105) KW = 3611.5  
TON

CHILLER (ITEM E)  
10,500 TON x .425 KW/TON x .20 INCREASE = 892.5

HEAT PUMPS (ITEM B)  
3953 x 1.086 KW/TON x .20 INCREASE = 858.6

CONDENSER (ITEM C) x .20 INCREASE = 1970.5  
21778 x .452 KW/TON

7333  
KW

TOTAL TONS = 47304

(11)

22 Dec '89

Kris Leaf:

Environmental impacts for "assessment of once-through well water systems" should use the following data for calculations:

assume load will be met with metro plants

heat rate is 11,200 Btu/kWh

emission rates to use are ← million

sulfur dioxide : 1.2 lbs SO<sub>2</sub>/MBtu

oxides of nitrogen : 0.9 lbs NO<sub>x</sub>/MBtu

particulates : 0.05 lbs part./MBtu

carbon dioxide : ~~call Patti Boyce @ 7630 for this #~~

→ 3,740 ~~1,970~~ lbs. / ton of coal ← (subbituminous, 51% carbon content) coal type

(Energy in coal = 8500 Btu/lb)

I have done some of the mark up on the draft of the report. Please do not include emissions of carbon monoxide, volatile organic compounds, lead, or PM-10. Their emission rates are estimates only.

Please send me a revised copy of the report for review. I apologize for the delay in getting you this information; other urgent issues came up as well. Call me @ 5628 w/ questions.

Regards,

Janet Anderson

Post-It™ brand fax transmittal memo 7671		# of pages ▶ 2
To: George Kofentzger	From: Kris Leaf	
Co.	Co. NSP	
Dept.	Phone # 330-6087	
Fax # 331-3806	Fax #	



12/27/89

~~\_\_\_\_\_~~  
The thermal effects of generating additional kilowatt-hours at peak periods by metro area plants:

To air: 1,548 Btu/kWh  
To river water: 5,000 Btu/kWh

Total thermal effects: 6,548 Btu/kWh

Kris

Metro plants (i.e. Riverside + Black Dog) discharge to river water, not towers.



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project WATER USE STUDY Sheet 1 of 1  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

ENVIRONMENTAL IMPACT

A) KW ADDED - ESTIMATES

OSM : 7.33 MW

SAM STEWART (BOMA) : 15 MW

NSP : (PRELIMINARY) : 5 MW

B) EQUIVALENT FULL LOAD HOURS -  
NSP : 876 HRS

ASSUMES 5 MW

$$5 \times 10^6 \text{ W} \times \frac{\text{KW}}{10^3 \text{ W}} \times 876 \text{ HR} = 4.38 \times 10^6 \text{ KWH}$$

C) HEAT RATE OF COAL, PER NSP = 11200 BTU/KWH

$$4.38 \times 10^6 \text{ KWH} \times \frac{11200 \text{ BTU}}{\text{KWH}} \times \frac{\text{MM (Million)}}{10^6} = 49056 \text{ MM (Million)}$$

D) EMISSION RATES PER NSP, ANNUAL

$$\text{SO}_2 : \frac{1.2 \text{ lbs SO}_2}{\text{MMBTU}} \times 49056 \text{ MMBTU} = 58867 \frac{\text{lbs}}{\text{yr}}$$

$$\text{NO}_x : \frac{.09 \text{ lbs}}{\text{MMBTU}} \times 49056 = 44150 \frac{\text{lbs}}{\text{yr}}$$

$$\text{PARTICULATES} : .05 \text{ lbs} \times 49056 = 2453 \frac{\text{lbs}}{\text{yr}}$$

$$\text{CO}_2 : \frac{1070 \text{ lbs CO}_2}{2000 \text{ lb coal}} \times \frac{16 \text{ coal}}{8500 \text{ BTU}} \times 49056 \times 10^6 \text{ BTU} = 9.8 \times 10^9 \text{ lbs}$$

Total Thermal EFFECTS:

$$65.98 \frac{\text{BTU}}{\text{KWH}} \times 4.33 \times 10^6 \text{ KWH} = 2.868 \times 10^{10} \text{ BTU}$$



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project WATER USE STUDY Sheet 2 of 2  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

ENVIRONMENTAL IMPACT CONTD

COST FOR PLANT  
PER KW'S LEAF @ NSP  
1990 CONSTR COSTS

@ ESTIM 5 MW

GAS  

$$\frac{\$536}{\text{KW}} \times 5000 \text{ KW} = \$2,680 \text{ MILLION}$$

BUT GAS IS  
EXPENSIVE

COAL  

$$\frac{\$139.5}{\text{KW}} \times 5000 = \$697.5 \times 10^6$$

BUT COAL IS  
CHEAP TO BURN

TABLE 24:  
DETERMINATION OF ELECTRIC AND WATER USAGE  
EFFICIENCIES FOR SEVEN COMMON HVAC SYSTEMS  
-----

SYSTEM DESCRIPTION  
=====

- A CHILLED WATER  
50 DEG WELL WATER ENTERING EVAPORATOR AND LEAVING AT 45 DEG, THEN FLOWING THROUGH SYSTEM LOAD AND DISCHARGING TO STORM AT 55 DEG.  
(NOT USED IN FOUR FACILITIES; FOR EXAMPLE ONLY.)
- B HEAT PUMP  
50 DEG WELL WATER ACTS AS HEAT SINK FOR HEAT PUMP WHICH DISCHARGES TO STORM AT 85 DEG.
- C CONDENSER  
50 DEG WELL WATER ENTERING CONDENSER AND DISCHARGING TO STORM AT 80 DEG.
- D COOLING COILS  
50 DEG WELL WATER ENTERING COOLING COILS AND DISCHARGING TO STORM AT 60 DEG.
- E EVAPORATOR TO CHILLED WATER COILS TO CONDENSER  
50 DEG WELL WATER ENTERING EVAPORATOR AND LEAVING AT 45 DEG, THEN FLOWING THROUGH COOLING COILS AND LEAVING AT 55 DEG., THEN FLOWING TO CONDENSER AND DISCHARGING TO STORM AT 67.5 DEG.
- F COOLING TOWER  
50 DEG WELL WATER ENTERING COOLING TOWER AS MAKEUP WATER.
- G COOLING COILS TO CONDENSER  
50 DEG WELL WATER ENTERING COOLING COILS AND LEAVING AT 60 DEG., THEN FLOWING TO CONDENSER AND DISCHARGING TO STORM AT 85 DEG.

\*\*\*\*\*

-----> COST FACTOR: \$0.045 / KW <-----

SYSTEM	TONS	D.T.	GPM	KW	ELEC COST	GPM/TON	KW/TON
=====	=====	=====	=====	=====	=====	=====	=====
A	100	10.0	240	51.5	\$2.32	2.40000	0.51500
B	100	35.0	86	108.6	\$4.89	0.85714	1.08640
C	100	30.0	100	45.2	\$2.04	1.00000	0.45240
D	100	10.0	240	10.5	\$0.47	2.40000	0.10500
E	100	17.5	240	42.5	\$1.91	2.40000	0.42500
F	100	10.0	15	82.0	\$3.69	0.15000	0.82000
G	150	35.0	120	54.9	\$2.47	0.80000	0.36593

NOTE: THESE COSTS DO NOT INCLUDE WATER TREATMENT AND MAKE-UP WATER COSTS, SYSTEM EFFICIENCY LOSSES, ETC., BUT ARE ONLY EXAMPLES OF AFFECT OF WELL-WATER USAGE.



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER/OPB  
Project WATER USE STUDY Sheet 1 of 6  
Comm. No. 4435.00 Date 1/10/96

YIC

TABLE 24  
SEVEN COMMON SYSTEMS - CALCULATIONS

A) CHILLED WATER CRITERIA

ASSUME: CHILLER TONS = 50 @ 50/45 WELL WATER ENT/LWT  
SYSTEM TONS (TO BLVD): 100 TON COIL LOAD.

COIL @ 45/55

1) GPM OF COIL:

$$\text{TONS} = \frac{\text{GPM } \Delta T}{2.4}$$

GPM = 240

50'

WELL PUMP @ 240 GPM

2) YW

- 1) CHILLER @ 85/95 : .6 kW/TON x 50 TONS = 30 kW
  - 2) WELL PUMP B16 1510-3E 10 HP = 8.53 kW
  - 3) COND PUMP B46 1510-3BB 5 HP = 4.2 kW
  - 4) TOWER FANS EVAPCO "AT 4-94" TOTAL 6 HP = 4.2 kW
- 46.9

ASSUME : 51.4

3) 100 TONS COOLING



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers

Client MDNR By GER/  
Project WATER USE STUDY Sheet 2  
Comm. No. 4435.00 Date 1/10

B) HEAT PUMP DESIGN CRITERIA -

50 ENT / 85° LWT Heat exch, WELL WATER SIDE

1) GPM

100 TONS COOLING 125 TONS HEAT REJECTION

$$\frac{\text{HEAT EXCH}}{125} = \frac{\text{GPM} \cdot 35}{24} = \boxed{86 \text{ GPM}} \rightarrow .86 \frac{\text{GPM}}{\text{TON}}$$

WELL WATER

2) KW

i) WELL WATER: 86 GPM @ 100' HEAD (WELL HD + SYSTEM HD)

1750 RPM

B/C 1510

5 HP 59% EFFIC

$$5 \text{ HP} \times 1.746 \times \frac{.80 \text{ LOAD}}{.59 \text{ EFFIC}} = 7.9 \text{ kW} = .079 \frac{\text{kW}}{\text{TON}}$$

ii) WATER SOURCE PUMP

100 TONS COOLING, 125 TONS HEAT REJECTION

$$125 = \frac{\text{GPM} \cdot (\Delta T)}{24} \quad \text{ASSUME } 15^{\circ}\Delta T \text{ WATER SIDE PER T.A. PERRY}$$

200 GPM @ 50' HD 1750 RPM

4 BHP = 5 HP 80% LOAD

B/C 1510 - 2'BC, 63% eff.

$$5 \text{ HP} \times 1.746 \times \frac{.80}{.63} = 4.74 \text{ kW} = .047 \frac{\text{kW}}{\text{TON}}$$

iii) HEAT PUMPS - per T.A. PERRY CO @ 70°/85° SOURCE

$$12.5 \text{ EER} = 12.5 \frac{\text{BTUH}}{\text{WAT}}$$

$$\frac{1}{\left(12.5 \frac{\text{BTUH}}{\text{WAT}} \cdot \frac{1 \text{ TON}}{12000 \text{ BTUH}} \cdot \frac{1}{100 \text{ TONS}} \cdot \frac{1000 \text{ W}}{1 \text{ KW}}\right)} = 96 \text{ KW}$$

2) 1.000 ...

(18)

C) CONDENSOR

ASSUME: 100 COOLING TONS (1.25 HEAT REJECTION FACTOR)  
50/80 WELL WATER TEMP

.4 kW/TON CHILLER

1) GPM:  $100 = \frac{\text{GPM} \cdot 30 \cdot 4.17}{30 \cdot 24 \cdot 1.25} \Rightarrow \text{GPM} = 100 \cdot \frac{1.10 \text{ GPM}}{\text{TON}}$

2) Kw

1) CHILLER  $.4 \text{ kW/ton} \times 100 = 40 \text{ kW}$

2) WELL PUMP = CONDENSE = SINGLE PUMP  $B\&G, 150-2E = 5.24 \text{ kW}$

3) 100 TONS

D) COOLING COILS

ASSUME: 100 TONS, COILS @ 50/60 ENT/LWT

1) GPM  $100 = \frac{\text{GPM} \cdot 10}{24} \Rightarrow \text{GPM} = 240$

2) Kw

WELL PUMP @ 240 GPM = 8.53 kW

ASSUME: 10.5 kW

3) TONS 100

E) EVAP TO CHW COILS TO COND

ASSUME: 1) 50 TONS AT CHILLER, 50/45 EWT/LT

2) 45° SUPPLY TO CH. W. COILS PICK UP 100 TON BUILDING LOAD @ 45/55 EWT/LWT

3) 55° WATER TO CONDENSER

GPM

COIL REQMT DICTATES GPM

$$100 = \frac{\text{GPM} \times \Delta T}{24}$$

$$\boxed{\text{GPM} = 240}$$

$$\frac{2.4 \text{ GPM}}{\text{TON}}$$

EVAP 50 =  $\frac{240 \Delta T}{24}$

$\Delta T = 5^\circ$  OK, AS ABOVE

COND 50 =  $\frac{240 \Delta T}{30}$

$\Delta T = 6.25 \rightarrow 55/67.5$  EWT/LWT

KW

CHILLER USE

USE  $.34 \text{ KW/TON}$


= 34

WELL PUMP, SINGLE PUMP FOR COND = 240 GPM PUMP

8.53 KW

TONS

100





F) COOLING TOWER

EVAPCO 'AT'  
85/95 = 10° RANGE  
78° WB - 85 = 7° APPROACH

) CAP CORRECTION = 1.0

1) GPM

100 TONS =  $\frac{GPM (85-95)}{30}$

$\Rightarrow \frac{GPM = 3000}{\text{Recirculated}} \times .05 \text{ MAKE UP} = 15 \text{ GPM}$

2) KW

i) FAN HP MODEL

AT 4-94

2 FANS @ 3 HP = 6 HP TOTAL, BELT DRIVEN

$KW = 6 \text{ HP} \times .746 \times \frac{.80 \text{ LOAD}}{.85 \text{ EFFIC}} = 4.21 \text{ kW}$

$\approx .042 \frac{KW}{TON}$   
FANS

ii) TOWER WATER (CONDENSATE) PUMP

300 GPM PUMP @ 50' HEAD

1750 RPM

SERIES 1510 B/G 3" BPS: (5 HP) 71% IMPELLER EFFIC.

$KW = 5 \text{ HP} \times .746 \frac{KW}{HP} \times \frac{.80 \text{ LOAD}}{.71 \text{ EFFIC}} = 4.203 \text{ kW} \approx .042 \frac{KW}{TON}$

iii) chiller at .70  $\frac{KW}{TON} \times 100 \text{ TONS}$

70 kW

3) TONS 100

TOTAL = 78.4 kW  
ASSUME: 82.0 kW

GPM is WELL WATER @ 15 GPM MD

ADD 1.0  
1.02 kW/TON

6) COOLING COILS TO CONDENSER

ASSUME: 50° WELL WATER

100 TONS CHILLER CAP  
COND: 60° EWT / 85° LWT = 25° AT  
1.25 HEAT REJECT FACTOR,  
 $100 = \frac{\text{GPM} \times 25}{30} \rightarrow \text{GPM} = 120$  REQUIRED  
1.2 GPM  
COILS: 50° EWT / 60° LWT

120 GPM

TONS =  $\frac{120 \times 10}{24} = 50$  TONS

1) GPM 120 WELL W

2) KW

WELL PUMP 120 GPM @ 1750 RPM, 100' HD  
B&G 1510-2E 5HP, 61% EFF  
 $5 \times \frac{1.746 \times 1.8}{.61} = 4.89$  KW

CHILLER .5 KW/TON x 100 TONS = 50 KW

3) TONS

COILS = 50  
CHILLER = 100  
150 TONS

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 2  
Comm. No. 4485 Date 2/7/90

TABLE 33

MUNICIPAL WATER INSTEAD OF WELL W  
IN EXISTING DESIGNS,  
- ANNUAL COST -

FACIL	M/GY	COST ORIGINAL	ADD'L COST	ORIGINAL ANNUAL	NEW ANNUAL	NEW \$/TON HR
GENL M/LCS	238	\$ 1.14	271,320	86011	357331	.14126
GRINDAE	525.6	↓		42692		.9313
NIMBYWELL	246.3	↓		242,870		.0742
MULTIPLI	227.0	↓		209,304		.1213

TABLE 3A

WELL WATER VS AIR COOLED TOWER  
ANNUAL COST COMPARISON - OPER COST

ASSUME WELL WATER IS AVAILABLE AS  
A SOURCE FOR MAKE-UP; COST IS \$1.05/1000G

EXAMPLE CALCULATION

GENERAL MILLS

$$\frac{58 \text{ GAL}}{\text{MIN}} \times \frac{60 \text{ MIN}}{\text{HR}} \times 2100 \text{ HR} = 7.308 \times 10^6$$

$$\begin{aligned} & \times \frac{\$1.14 \text{ CITY W}}{1000} \\ & = 8331 \text{ \$} \end{aligned}$$

$$- 7.308 \times 10^6 \text{ GAL} \times \frac{\$1.05}{1000} = 365 \text{ \$}$$

ORIGINAL OPER COST IS 100,862

$$\text{NEW OPER} = 100862 - 8331 + 365 = 92896$$

$$\frac{\$92896}{2,355,610 \text{ TON HR}} = .039436 \text{ \$/hr}$$

FACIL	ORIGINAL ANNUAL	CITY W	WELL W	NEW ANNUAL	NEW \$/HR
GENERAL MILLS	\$100862	- 8331	+ 365	92896	.039
CAWIDARE	48030	- 4862	292	43460	.063
HONEYWELL	387227	- 20265	915	367,272	.042
MISTMODIST	169072	- 8331	365	152,106	.04

**A P P E N D I X**

**GENERAL MILLS**



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 1  
Comm. No. 4485.00 Date 12/12/12

GENERAL MILLS  
ANNUAL OPERATING COSTS - SUMMARY

A) EXISTING OPERATION

PUMPING	14,907
COMPRESSORIZED EQPT	55,304
WATER TREATMENT	15,800
TOTAL	*86,011

B) CONVERSION

PUMPING	10,192
TOWER	3,859
COMPRESSORIZED EQPT	69,689
WATER TREATMENT	4,318
WATER MAKE-UP & SEWER	12,304
	100,862

**I GENERAL MILLS**  
**TON-HOUR CALCULATIONS**

**A) EXISTING DESIGN**

CHILLER #	TONS	LOAD*	ANNUAL HRS OPERATION*	TON HOURS
1	360	.70	2100	529,200
2	360	.70	2100	529,200
3	STANDBY			
4	150	.60	250	22,500
5	410	.85	3000	1,045,500
6	160	.40	50	3,200
COILS	400	1	1000**	400,000

\* PER GENERAL MILLS

\*\* ASSUMED

TOTAL ANNUAL TON HRS = 2,529,600

**B) CONVERSION**

CHILLER #	TONS	LOAD	HRS OPER	TON HOURS
1	319	.70	2100	468,930
2	319	.70	2100	468,930
3	350*	1	1000**	350,000
4	127	.60	250	19,050
5	410	.85	3000	1,045,500
6	160	.40	50	3,200
COILS	0			0

\* CHILLER ON-LINE TO REPLACE WELL WATER COILS

TOTAL TON HR 2,355,610

**II ANNUAL COST / TON HOUR**

**A) EXISTING**

$$\frac{\$86011}{2,529,600} = .0340 \text{ \$/TON H}$$

**B) CONVERSION**

$$\frac{\$102,862}{2,355,610} = .0423 \text{ \$/TON H}$$



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 1  
Comm. No. 4485.00 Date 12/11/11

GENERAL MILLS - WELL WATER OPERATING COSTS

A) LUMPING COSTS - ANNUAL

· CALC: 
$$\frac{\text{HP} \times .746 \text{ KW}}{\text{HP}} \times .85 \text{ BHP FACTOR FROM NAMEPLATE} \times \frac{1}{.90 \text{ PUMP EFFICIENCY}} = \text{KW}$$

CONDENSER WATER PUMP - CHILLER #1

$$20 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \$ .045 \times 2100 \text{ HR} \times .70 = 12$$

\* MODULATING VALVES REDUCE HP

CONDENSER WATER PUMP - CHILLER #2

$$20 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \$ .045 \times 2100 \text{ HR} \times .70 = 12$$

\* MODUL VALVES

CONDENSER WATER PUMP - CHILLER #3

STANDBY

CONDENSER WATER PUMP - CHILLER #4

$$5 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \$ .045 \times \frac{250 \text{ HR}}{\text{YR}} \times .60 = 29$$

\* MODUL VALVES

SUB TOTAL 249



CONDENSER WATER PUMP - CHILLER # 5

$$10 \text{ HP} \times 1746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times 3000 \text{ HR} \times .85 = 808$$

\* MODUL VALUE

CONDENSER WATER PUMP - CHILLER # 6

- NONE -

2100  
 2100

WELL PUMPS

#3 AND #4 = 2800 HRS TOTAL TIP PUMPS

$$100 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times 2100 \text{ HR} = \$ 6658$$

A/C BOOSTER PUMPS

$$75 \text{ HP} \times 1746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times 2100 \text{ HR} = \$ 4994$$

SAME UNDER  
 SOME HAS  
 MULTIPLE  
 PUMPS

PER MOTOR PUMP - FIVE (5) PUMPS, TYPICAL

$$10 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times 1000 \times 5 = 0$$

STTL 12,460

1000  
 7-6  
 14



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project WATER USE STUDY Sheet 3 of 10  
Comm. No. 4485.00 Date 12/11

B) ANNUAL EQUIPMENT OPERATING COSTS

CHILLER #1

$$.493 \frac{\text{KW}}{\text{TON}} \times 360 \text{ TONS} \times .70 \text{ LOAD} \times \frac{\$.045}{\text{KWH}} \times 2100 \text{ HR} = \$ 11,740$$

CHILLER #2

$$.493 \frac{\text{KW}}{\text{TON}} \times 360 \text{ TONS} \times .70 \times \frac{\$.045}{\text{KWH}} \times 2100 \text{ HR} = \$ 11,740$$

CHILLER #3

STANDBY

CHILLER #4

$$102.9 \text{ KW} \times .60 \text{ LOAD} \times \frac{\$.045}{\text{KWH}} \times 250 \text{ HR} = \$ 695$$

CHILLER #5

$$26.5 \frac{\text{KW}}{40 \text{ TONS}} \times .85 \text{ LOAD} \times \frac{\$.045}{\text{KWH}} \times 3000 \text{ HR} = \$ 30,409$$

CHILLER #6

$$1816 \frac{\text{TON-H}}{1000 \text{ LB}} \times 160 \text{ TON} \times 50 \text{ HR} \times \frac{\$.5}{1000 \text{ LB}} = \$ 720$$

~~\$/1000~~ IS PER GENERAL MILLS, INCLUDING FUEL, BOILER MAIN SERVICE CONTRACTS, LABOR, DEPRECIATION).

C) WATER TREATMENT COSTS

ST TOTAL 553

PER GENERAL MILLS:

PHOSPHATE COSTS \$ 13,300 /YR

CHLORINE COSTS \$ 2000 /YR

ST. TOTAL 153

TOTAL MGAY REPORTED 1987: 238

WATER TREATMENT COST

$$\text{COST PER MGAY} = \frac{15300}{238} = 66.39 \approx \frac{\$ 67}{\text{MGAY}}$$

(30)

CONVERSION - ANNUAL OPER.

CHILLER OPERATION

#1 & 2: CIRRIER

NEW MACHINE

319 TONS @ .6019 kW/TON

REDUCED FROM .493 kW/TON = 22% MORE kW/TON

$$319 \times \frac{.602 \text{ kW}}{\text{TON}} \times \frac{.045 \text{ kW}}{\text{KW}} \times .70 \times 2100 \text{ HRS} \times 2 = 25407$$

$$350 \times \frac{.602 \text{ kW}}{\text{TON}} \times .045 \times 1000 \text{ EQUIV FL HRS} = 9481$$

#3 STANDBY - 0

Same as 1000  
EXISTING OPER LOAD  
OF CHILLS.

#4 NOTE: NEW OPER kW = .790 kW/TON

$$127 \text{ TONS} \times .790 \times .045 \times .60 \text{ (LOAD)} \times 2500 \text{ HRS} = 677$$

#5 TILANE - NO kW DATA

ASSUME 10% MORE kW/TON; .646 kW/TON  
< 1.1 = NEW MACHINE ⇒ .71 kW/TON

$$410 \text{ TONS} \times .71 \times .045 \times .85 \text{ (LOAD)} \times 3000 \text{ HRS} = 3704$$

#6 STANDBY - COSTS SAME AS BEFORE = 720

TOTAL

69689

Add #3  
Machines  
to rep  
well  
water

CONVERSION - ANNUAL OPER

GENERAL MILLS - GPM OF COOLING TOWER

1280 TR x 3 = 3864 GPM

PUMP SELECTION

BELL & GOSSET SERIES VSCS - 12x14x12 1/2

ASSUME: 100' HEAD

1750 RPM, 120 BHP, 83% EFFIC

PUMPING COSTS

TOWER PUMP

$$120 \text{ BHP} \times \frac{746}{.83} \times 1 \times 1 \times \frac{1}{\text{GWH}} \times \frac{1.045}{\text{GWH}} \times 2100 = 10192$$

~~CONDENSER PUMPS~~ NOT USED NOW

~~CHILLERS 1, 2, 4 & 5~~ = 0

TOTAL 10192



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By \_\_\_\_\_  
Project GENERAL MILLS Sheet 3 of 5  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

CONVERSION - ANNUAL OPER  
TOWER FANS -

TWO FANS @ 40 HP EACH

ASSUME 80% LOAD, 95% EFF, 1/2 TIME LOW SPEED.

a) HIGH SPD

$$80 \text{ HP} \times .80 \times .746 \times \frac{1}{.95} \times .045 \times 1050 = 9906 \text{ kWh}$$

b) LOW SPD FULL LOAD

$$20 \text{ HP} \times 1 \times .746 \times \frac{1}{.95} \times .045 \times 1050 = 6191 \text{ kWh}$$

~~16097 kWh~~

7100 TOTAL

TOWER WATER

ANNUAL OPER COST - TOWER MAKEUP = EVAP + BLOWDOWN

SEWER COSTS = BLOW-DOWN ONLY

Ⓢ ASSUMED \$1.14 / 1000 GAL

WHERE TOWER OPER HRS = AVERAGE OF:  
FULL LOAD HRS + TOTAL OPER HOURS  
2

EVAP  
GPM

Ⓢ 1284 x 3 = 3852 GPM

TOWER

10° ΔT → 38.6 EVAP GPM

BLOWDOWN

Ⓢ 3 cycles = CONCENTRATION IN CIRC = 3% CONCL IN MAKEUP

19.4 GPM

SUM 58 GPM

COST

MAKEUP = 58  $\frac{GAL}{MIN}$  x  $\frac{60 MIN}{H}$  x 367 HRS x  $\frac{1.14}{1000 GAL}$  = 3.3

TOTAL OPER

HOURS =  $\frac{2100, 2100, 3000}{3}$  = 2400 HRS

Avg = 2100

FL H = 1830

Blow Down @ avg sewer rate \$1.83 / 1000 gal

19.4  $\frac{GAL}{H}$  x  $\frac{60 MIN}{H}$  x  $\frac{2100}{1000}$  = 1.83 = 447

34

TOTAL

12,804



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 5 of 5  
Comm. No. 4485.00 Date \_\_\_\_\_

TOWER CONVERSION — ANNUAL OPERATION

COST OF WATER TREATMENT

\$4313

(SEE CALCULATIONS FOR WATER  
TREATMENT COST IN GENERAL  
SECTION OF APPENDIX)



CAPACITY: PEAK DAY TONS

A) COMPRESSORIZED

PER GEN'L MILLS:

CHILLERS 1, 2, 3 ARE 200% STANDBY.  
AT ANY ONE TIME THE LOAD  
IS ONLY 328 TONS - PEAK

SEE AIR-SIDE CALC OF CHW LOOP.

CHILLERS 5 & 6 HAVE PEAK BLDG LOAD  
OF 405 TONS - PEAK

CHILLER 4 HAS PEAK LOAD SAME AS  
CHILLER OF 150 TONS PEAK

SUM = 328 + 405 + 150 = 883 TONS

B) AIRSIDE, WELL WATER COILS (CHILLED WATER  
LOAD BASED ON ASSUMED 55/62° = 7°ΔT)

C1, C5, C9 = 219 GPM × 7/24 = 63.5 TONS

C31, C17, C18, C20, 21, 22 = <sup>GPM</sup> 294 × 7/24 = 80 T

C7, C8, C10, 11, 13 (290) 7/24 = 84.5

PERIMETER UNITS

P3 100  
P1 + P8 = 225 } (258) 7/24 = 75 TR  
P2 + P2A = 190

C4 + C6 = 222 7/24 = 65

C2 + C3 = 92 7/24 = 27

36 1375 401 770





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By \_\_\_\_\_  
Project GENERAL MILLS Sheet 2 of 2  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

PEAK DAY TONS AND DESIGN GPM:

$$\text{TONS} = \frac{\text{GPM AT CONDENSER SIDE}}{30} \quad \text{WHERE; HEAT REJECTION FACTOR OF COMPRESSOR HEAT} = 1.25 \times 24 = 30$$

CALCULATE GPM (DESIGN) AT 'PEAK DAY' TONS:

CHILLER 1

$$\frac{328 \cdot 30}{20} = 492 \text{ GPM}$$

CHILLER 5

$$\frac{405 \cdot 30}{20} = 607.5$$

CHILLER 4

$$\frac{150 \cdot 30}{10} = 450$$

WELL WATER COILS

$$\frac{401 \cdot 24}{7} = 1375$$

TOTAL 2924.5 GPM

WELL WATER USE -  
DESIGN, EXISTING  
SYSTEM

$$\frac{\text{GPM}}{\text{TON}} = \frac{2924.5}{1284} = 2.2776 \text{ GPM/TON}$$

TOTAL FIRST COSTS FOR CONVERSION

A) CHILLERS 63,600

B) TOWERS 68116

C) PIPE & INSUL 78800

D) PUMP 9010

E) INSTALLATION = B+C+D = 155926 SBTOTAL = 37545

F) 30% CONTINGENCY = 0.30X(A+B+C+D+E) = 112630

TOTAL ESTIMATED CONSTR. COST \$ 488,088

G) RECALCULATED 1/26/90

NEW TOTAL FIRST COST = 1,500,000  
 - 68,116 TOWER  
1,431,884

AG = 715,942  
 TOWER = 68,116  
 INSTALL = 715,942  
 TOTAL = \$ 1,500,000



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client \_\_\_\_\_ By \_\_\_\_\_  
Project GENERAL MILLS Sheet \_\_\_\_\_ of \_\_\_\_\_  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

CONVERSION FIRST COSTS

A) A/C EQPT FIRST COSTS - CHANGES

CENTRIFUGAL - CHANGES

1) CARRIER

IMPELLERS 5500 x 2 = 11,000

COND VESSELS 3800 x 2 = 7600

2) MCQUAY

1) GEARS 1500.0 x 1 = 1500.0 (ESTIM. - SEE 10RV  
VESSEL (UNKNOWN) ? (QUOTE GEAR CHANGE 260TH

3) TRAMET

IMPELLER 30,000 x 1 = 30,000

VESSEL - 0

B) ADD TOWERS - per MARLEY COOLING TOWER (622422)

71 68,116

C) ADD PIPING & INSULATION

3864 GPM @ 10 FPS = 12" PIPE

500' @ 12" = 500 x 87.95 = 43975

500' @ 8" = 500 x 55.80 = 27900

250' @ 4" = 27.70 = 6925

78,800

D) ADD NEW PUMP

\$9010

Per Bell & Ross

USCS 104' @ 125 HP

E) TOWER INSTALLATION (1987 "MEANS" P226) @ 3.70/TON = 4758 NOT USED

- 110T 1987 + 20% 30TH CONTINGENCY



**General Mills, Inc.**  
**James Ford Bell Technical Center**

9000 Plymouth Avenue North  
Minneapolis, Minnesota 55427

BJO/2/90

January 24, 1990

James Japs, Coordinator  
Water Allocation Program  
State of Minnesota  
Department of Natural Resources  
500 Lafayette Road  
St. Paul, MN 55155

Dear Mr. Japs:

We have received a draft copy of MDNR CONSUMPTIVE WATER USE STUDY prepared by O-S-M & Assoc., Inc. After reviewing the report, we would like to make some comments regarding the portion of the report concerning General Mills, Inc. They are as follows:

**BUILDING TOTAL COOLING LOAD**

The total building cooling loads are close, but there is a large difference in the cooling load supplied by well water that is used directly in the coils. The capacity of each system is as follows:

<u>Cooling Water System</u>	<u>O-S-M Report</u>	<u>GMI Calculation</u>
Well Water - direct	401 tons	700 tons
Well Water - chilled	150 tons	150 tons
<u>Circulating Chilled Water</u>	<u>883 tons</u>	<u>760 tons</u>
<b>Total Load</b>	<b>1,434 tons</b>	<b>1,610 tons</b>

**CONVERSION COSTS**

The O-S-M Report states that there are two 360 ton chillers at full standby so no new chillers are necessary. The chillers noted are installed in our East Wing Building (separate from the General Office) which houses our corporate computer system. The two new 360 ton Carrier chillers provide cooling to the computer building with a 100% back-up capacity. The third chiller is a 350 ton Dunham Bush unit which is an old, inefficient, and unreliable chiller used only in emergencies.

A recent cost estimate to change over from the well water system includes 3 - 300 ton chillers, cooling towers, pumps, piping and electric power wiring for a cost of \$1,500,000. The 3 - 300 ton chillers are for the 700 tons of cooling provided by the well water and for the less efficient operation of our existing chillers when they are converted from well water to cooling tower water for the condensers on the chillers.

(10)

OPERATING COSTS AND LIFE CYCLE COSTS

The new 900 tons of water chillers and associated equipment would change the annual operating cost and life cycle costs as noted in the report. The installation cost would change from \$347,362 to \$1,500,000 to have General Mills, Inc. corporate office air conditioning system be removed from the well water system.

Sincerely,

*John Bjoim*

John Bjoim, P.E.  
Senior Mechanical Engineer

BJO:PKP

$$\begin{array}{r}
 1,500,000 \\
 - 68,116 \text{ TOWER} \\
 \hline
 \end{array}$$
 = A/C EQPT + INSTALL  
 (DIVIDED EQUALLY)

= \$715,942 EACH

+ 68,116

TOTAL FIRST COSTS

GENERAL MILLS

ORIGINAL CAPACITY 360 TONS  
CHILLERS #1 / #2

VERSION 4.0 - NOVEMBER 1, 1988

SALESMAN CODE : 902  
DATE 12/22/89

JOB ID : OSM

DNR WATER USE STUDY

ANS PROBLEM ALTERNATES	CH-1 MAX. CAP	CH-1 PERF-TON
UNIT-UNISHEL	19DK76	19DK76
HT.XCH.GROUP	76	76
CMPSR-MOTOR	<u>313CD</u>	<u>313CL</u>
CLR-CND PASS	2-2	2-2
ALTRNAT. SURF	CND	CND
CLR TUBING	SUPER-B	SUPER-B
CND/SUBC.TBC	TURBOCHL*	TURBOCHL*
CND/SUBC.TBC	10-.028*	10-.028*
SURFACE NBR	12*	12*
VOLTS-HERTZ	480-60	480-60
REFR.NBR-LBS	11-1100	11-1100
COOLING TONS	319	360
IN.KW	192	220
IKW/TON	.603	.610
TOTAL RIG.WT	16500	16580
TOTAL OP.WT	19000	19080
COOLER FLUID	FW	FW
ARI550-FF	STD	STD
CLR ENT.TEMP F	54.60	55.96
CLR LVG.TEMP F	44.00	44.00
FLOW,U.S.GPM	720	720
PD, FT.W.G.	9.5	9.4
CNDNSR FLUID	FW	FW
HT.RJCTN MBH	4484	5070
ARI550-FF	STD	STD
CND LVG.TEMP F	93.32	94.41
CND ENT.TEMP F	85.00	85.00
FLOW,U.S.GPM	1080	1080
PD, FT.W.G.	15.8	15.8
MOTOR IN.KW	192	219
RATED-L.AMP	269	309
O.L.T.AMPS	290	334
L.R.Y.AMPS	507	570
L.R.D.AMPS	1585	1781
CNDNSNG.TEMP F	96.01	97.52
CLR WLL.TEMP F	42.5	42.4
SUCTION TEMP F	40.66	40.44
CLR TUBE VEL F/S	4.60	4.60
CND TUBE VEL F/S	6.63	6.63

EXISTING: 19DK76 312 CD  
4PASS CONDENSER

IMPELLER CHANGE

EXISTING: 312

NEW: 313

COST \$5500 PER MACHINE

PASS CHANGE

CHANGE EXISTING 4PASS CONDE  
TO A 2PASS CONDENSER

COST \$3800 PER MACHINE

MOTOR CHANGE

EXISTING MOTOR WILL ALLOW  
319 TONS ON TOWER. TO BE  
ABLE TO HAVE 360 TON CAPACIT  
A NEW MOTOR IS NECESSARY  
(CL SIZE).

COST: \$22500 EACH

(tr)



# DATA FAX

**SCHWAB · VOLLHABER · LUBRATT, INC.**  
4800 CHURCHILL STREET · ST. PAUL, MINNESOTA 55128 · PHONE: (612) 481-8000

NUMBER OF PAGES TO FOLLOW: 1 DATE: 1-3-90

COMPANY: OSM LOCATION: \_\_\_\_\_

ATTENTION: George R. Lundberg DEPARTMENT: \_\_\_\_\_

REGARDING: General Mills Chiller  
Data.

FROM: MATT HOLLAND Schwab-Vollhaber-Lubtratt, Inc.  
Fax Number (612) 481-8621

## MESSAGE

EXISTING	NEW 085/95
150 TONS	127 TONS
EVAP 51.5/43	51.5/43
COND	COND
450 GPM	450 GPM
60/70	85/93.4
HW/TON .686	HW/TON .790





OFFICE Garyco MADE BY Dale Schmalz CHECKED BY \_\_\_\_\_ DATE 12-22-89

GPM 3864  
 HW 75  
 SW 85  
 WB 78  
 WIND MPH \_\_\_\_\_  
 S MANUAL \_\_\_\_\_

QUOTATION: FORMAL  LETTER  VERBAL  WORK SHEET  
 COPIES TO: K.C. \_\_\_\_\_  
 PARTY QUOTED George Rothberger  
 ADDRESS \_\_\_\_\_  
 JOB General Mills 1288 Tons  
 ADDRESS \_\_\_\_\_  
 ENG'D BY DSM

EQUIPMENT TO SERVE \_\_\_\_\_

NOTE BELOW: SALES COMMENTS - KEY MEN - TITLES - ADDRESSES - ETC  
 SHOW TOWER ORIENTATION IF LOCATED WITHIN ENCLOSURE

1932 GPM - 2 Cells.

NE-812	28330	56660
etc Values	590	1180
Basin Covers	370	740
Sub Lines	310	620
Material at B-Stream	1300	2600
M-1 Vibrator Sw.	130	260
Hand Pail & Ladder		930
		<u>62990</u>
Freight:	1403	2806
		<u>65796.</u>

Add For 2-40HP 2 Speed 1 banding High Efficiency rates.  
 #2320.48

68110

32,090 Ship Wt.  
 72,240 Operating Wt.

NOV 16.

SUPPLEMENTAL INFORMATION TO:  
GEOTHERMAL HEATING AND COOLING SURVEY

November 2, 1989

RECEIVED

NOV 16 1989

COMM. #

Permit Number 74-5231 General Mills Inc.  
One General Mills Blvd  
Golden Valley, MN 55426

10/17/89  
JAS  
BER

1. Well Pump #3:  
Variable Speed  yes  no  
HP 100 GPM 1000 KW Input 74.4  
Efficiency Rating 95% (if known)  
Average Operation Hours per year 1400

Well Pump #4:  
Variable Speed  yes  no  
HP 100 GPM 1000 KW Input 74.4  
Efficiency Rating 95% (if known)  
Average Operation Hours per year 1400

2. Chillers :  
Chiller #1 Type Carrier #1 Centrifugal  
Capacity 360 Tons KW Input .493/Ton at 100% Load  
Peak Load 324 Tons Average Hours/Year 2100  
Condenser Water  
Temperature Entering 55°-60°  
Temperature Leaving 75°-80°  
GPM 493

Each  
2100 hrs x .70

Chiller #2 Type Carrier #2 Centrifugal  
Capacity 360 Tons KW Input .493/Ton at 100% load

46

meo 11/13/89

Peak Load 324 Tons Average Hours/Year

2100 @ .7 LOAD

Condenser Water

Temperature Entering 55° - 60°

Temperature Leaving 75° - 80°

GPM 493

2100 @ .7 LOAD  
PLUS  
#1

Chiller #3 Type Dunham-Bush Rotary Screw

Capacity 350 Tons KW Input N/A

Peak Load 350 Tons Average Hours/Year 0

Condenser Water

Temperature Entering 55° - 60°

Temperature Leaving 80°

GPM 550

STANDBY FOR #1 & 2

Chiller #4 Type Mcquay Centrifugal

Capacity 150 Tons KW Input 102.9

Peak Load 97.5 Tons Average Hours/Year 250

Condenser Water

Temperature Entering 55°

Temperature Leaving 85°

GPM 450  $10^{\circ}\Delta T$ , i.e.  $60^{\circ}$  to  $70^{\circ}$

$150 \times 1.25 \times 24 = 450$

= .686 kW/TON

.55 to .60 LOAD

Chiller #5 Type Trane Centrifugal

Capacity 410 Tons KW Input 265

Peak Load 410 Tons Average Hours/Year 3000

Condenser Water

Temperature Entering 60° - 65°

Temperature Leaving 80° - 85°

GPM 1143

(At 85° Enter/95.3° Leave)

.55 @ LOAD

= 1646 kW/TON

1570 load

AT WGBR WATER 60/30

IS 650 GPM PLS IS 650 GPM ✓  
(47)

18 15/TON.H

400 LOAD

STEAM INPUT -

Chiller #6                      Type Carrier (Absorption)  
 Capacity 160 Tons              KW Input 3 KW  
 Peak Load 160 Tons  $\times 4 = 64$       Average Hours/Year 50  
 Condenser Water  
 Temperature Entering 60°  
 Temperature Leaving 80°  
 GPM 552

~~Chiller #7                      Type \_\_\_\_\_  
 Capacity \_\_\_\_\_ Tons              KW Input \_\_\_\_\_  
 Peak Load \_\_\_\_\_ Tons              Average Hours/Year \_\_\_\_\_  
 Condenser Water  
 Temperature Entering \_\_\_\_\_  
 Temperature Leaving \_\_\_\_\_  
 GPM \_\_\_\_\_~~

Please list the unit numbers above, that are chilling well water only: #4

3. For the closed loop chilled water system, please indicate (for each pump in CW loop) GPM, KW input, HP, Efficiency, and whether it is a fixed or variable volume pump. See Attached
4. Once through Chilled Well Water coils: Please itemize the GPM's and Delta T for each coil. See Attached
5. Closed loop chill water coils: Please itemize the GPM's and Delta T for each coil. See Attached
6. Water treatment costs: \_\_\_\_\_  
 Phosphate Costs      \$13,800. Per year  
 Chlorine Costs        \$ 2,000. Per year

(48)

QUESTION #3

CLOSED LOOP CHILLED WATER PUMPS

CHILLER #  
1, 2, 3

ONLY OPERATES

CHILLERS 1, 2, 3

1) E. W. (2) Carriers (1) Dunham Bush has (3) chilled water pumps all:

EVAP  
40 H.P. 360 GPM FIXED VOLUME  
KW Input 31.5 Effic. 95%

COND PUMP 7 speed  
50 HP, Rakt 900 GPM @ High  
26 HP, ~ 450 GPM @ low speed) two pumps of which only one runs. - other standby

5

2) Trane Chiller #5  
EVAP 410 TON  
P-13  
10 H.P. 794 GPM FIXED VOLUME  
KW Input 7.4 Effic. 95%

EVAP  
P-14  
25 H.P. 1114 GPM VARIABLE VOLUME  
KW Input 19.6 Effic. 95%

COND PUMP  
P-15 10 HP, 650 GPM 95% CONTINUOUS KW not

6

3) Carrier Absorber #6  
EVAP 160 ton 50 HR/YR  
P-12  
3 H.P. 320 GPM FIXED VOLUME  
KW Input 2.3 Effic. 95%

COND  
NO PUMP

4

4) CHILLER #4 McQUAY - (250 HR/YR, 150 ton)  
COND. WATER PUMP:  
5 HP . 450 GPM 250 HRs/YR

there is old pump - interlocked w/ chiller

CHILLED WATER PUMP:


7 1/2 HP 302 GPM 250 HRs/YR

# QUESTION # 4

## GEO THERMAL HEATING AND COOLING SURVEY

### ONCE THRU WELL WATER W/ CHILLER

### CHILLER NO 4




<u>COIL NO</u>	<u>WELL WATER GPM</u>	<u>TEMP IN °F</u>	<u>TEMP OUT °F</u>	<u>RISE °F</u>	<u>COOLING TONS</u>
C-9	62	43°F	53°F	10°F	26 ✓
C-5	157	43°F	53°F	10°F	65
C-1	218	43°F	53°F	10°F	91
<b>TOTALS</b>	<b>437</b>				<b>182 TON.</b> 150 TON

THE 150 TON CHILLER (CHILLER NO 4) WAS INSTALLED TO PROVIDE A LOWER WELL WATER TEMPERATURE TO THE COILS. THIS GIVES MORE DEHUMIDIFICATION IN THE SUPPLY AIR TO CRITICAL AREAS WITHIN THE BUILDING.

# QUESTION # 5

## GEOHERMAL HEATING AND COOLING SURVEY

### BELL TOWER SYSTEM




COIL NO	WATER FLOW GPM	TEMP IN °F	TEMP OUT °F	RISE °F	COOLING TONS
C-25	318	44°F	52°F	8°F	106
C-26	336	44°F	52°F	8°F	112
C-27	286	44°F	52°F	8°F	95
C-28	276	44°F	52°F	8°F	92
					1216
					405

NORMAL OPERATION, CHILLER NO 5 OPERATES WITH CHILLER NO 6 OFF. DURING PEAK COOLING LOADS, THE STEAM ABSORPTION CHILLER NO 6 IS OPERATED TO PROVIDE ADDITIONAL COOLING CAPABILITY FOR A TOTAL COOLING LOAD OF 570 TONS.

# QUESTION # 5

## GEOTHERMAL HEATING AND COOLING SURVEY

EAST WING SYSTEM - CLOSED LOOP  
EVAP SIDE



NOTE:

3-350 TON CHILLERS

HAVE 200% STANDBY.

CHILLERS LOAD = 1 CHILLER AT FULL LOAD  
1, 2, 3 OR 2 CHILLERS AT 1/2 LOAD

3-360 GPM  
PUMPS

15 kW  
SCHEMATIC  
DRAWING

COIL NO	WATER FLOW GPM	TEMP IN °F	TEMP OUT °F	RISE °F	COOLING TONS
C-33	123	42°F	53°F	11°	56
C-34	270	42°F	53°F	11°	123
C-35	270	42°F	53°F	11°	123
FC-1	3.8	42°F	53°F	11°	1.7
FC-2	5.2	42°F	53°F	11°	2.4
FC-3	14.5	42°F	53°F	11°	6.6
C-27	33	42°F	53°F	11°	15.1
<b>TOTALS</b>	<b>720</b>				<b>328</b>





OCT 19.

**GEOHERMAL HEATING AND COOLING SURVEY**

PERMIT NUMBER 74-5231

PERMITTEE General Mills Inc.

SYSTEM LOCATION Golden Valley, Minnesota

RECEIVED

Orr-Schelen-Mayeron & A

NAMES AND LOCATIONS OF FACILITIES:

COMM. # \_\_\_\_\_

Minneapolis General Office

OCT 23 1989

One General Mills Boulevard

Golden Valley, Minnesota 55426

Name	REV'd	Copy	Name	REV'd

(Enclosed)

TOTAL AREA SERVICED: 420,000 Square feet

**WATER SOURCE**

Number of wells connected to the system 4

Enclosed is the well information we have on file regarding this installation. Please indicate if this data is accurate and/or submit any additional well data that is available. If no information is enclosed or available, please complete the enclosed Water Well Information form(s).

Are water level measurements taken on the production well(s) or observation well(s)?  Yes  No If yes, please submit a summary of the data.

**SYSTEM INFORMATION**

Number of years since original system was installed: 32

Date system was put on line: Fall of 1957

Is this a once through or closed loop system (describe and attach a simple schematic drawing) ?

Portion is once through - main building, east & west penthouse

systems are once through. All other systems are closed loop or

double usage in splash tanks for re-use as consensor water and/or

lawn irrigation water

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

57

**Describe any major system modifications and give the completion date:**

Original system: Main Bldg. & North Wing 1957-58 Deep Wells.1 & 2 only. Deep Well #3 added in 1964-65 with 4 story West Wing addition. Deep Well #4 added in 1979 with 6 story addition to West Wing Tower. (Total 10 story tower) Added computerized automation & replaced controls in 1979.

Fall/Winter 88 converted East Wing HVAC to outside air cooling instead of refrigeration cooling. Replaced inefficient Dunham-Bush rotary screw chillers w/new Carrier Centrifugal chillers for summer operation.

**Average water temperature:**

Heating 50° intake; NONE discharge  
Cooling 50° intake; 75% discharge

**System size rating:**

Heating 14,155,000 (BTU/H)      Cooling 1600 (Tons/H)

**Actual peak load:**

Heating 9,900,000 (BTU)      Cooling 1450 (Tons)

**Energy efficiency of systems:**

Number of chillers/heat-pumps in system 6  
Coefficient of Performance (COP) for heat pump N/A

Average Energy Efficiency Ratio (EER) for heat pump N/A

If no heat pump, chiller efficiency rating 0.49 Kw/ton @max load for last chiller purchased.

Number of chillers or heat pumps in system 6  
Size rating of chillers/heat pumps See tabulation below

3 @ 350 T, 1 @ 410 T, 1 @ 150 T, and 1 @ 165 T

**General Water Use Efficiency:**

Average Efficiency of Water Use 3.39 (GAL/TON) Cooling-Well Water  
2.37 (gal/ton) cooling-Closed Loop  
\* See Note below on heating 0.00012 (gal/BTU) heating

How much water is recirculated? 1800 GPM Closed Loop Cooling, 1200 GPM  
How much water is lost in the system, where is it lost and how is the amount of water loss determined? Condensing

All once thru well water used for cooling is lost. Some water is recirculated to chillers condensers and all water goes to the pond system for lawn sprinkling system. Volume of water used varies based on outside temperature conditions for air conditioning.

If cooling towers are part of the system, how many are there, how much evaporative loss occurs in this loop, and how is the amount of water loss determined?

No cooling towers

\* NOTE - East Wing at this facility is an all electric building with electric heaters in ductwork, electric baseboard and electric chillers for cooling

What is the design capacity of the towers? N/A  
If cooling towers are not present in the system please describe the feasibility of adding towers including any site and/or system limitations.

A study is now being made to evaluate the existing well water air conditioning systems and develop several proposals and cost estimates for improving our systems and to reduce or eliminate the use of well water for cooling.

$$1000 \frac{\text{GAL}}{\text{MIN}} \times \frac{60 \text{M}}{\text{H}} \times \frac{24 \text{H}}{\text{D}} \times \frac{365 \text{D}}{\text{Y}}$$

### WATER USAGE

Indicate the percentage of all primary and secondary uses of the water:

2% Heating                      73% Air conditioning  
-0- Processing                    25% Other: Domestic

Average pumpage: 1,000 gpm; 24 hours/day; 12 months/year

Are flow meters used to determine water usage?  Yes    No

If meters are not used, describe how the amount of water appropriated is determined.

### WATER DISPOSAL

Indicate any water treatment that is done before or after the water goes through the system.

Before Chlorine and Phosphate  
None after

What percentage of the water is discharged and what is the water discharged to?

75% Bassett Creek & 2nd usage for irrigation

If water is discharged into a storm sewer indicate the receiving water for the sewer outlet, if known.

Bassett Creek to Mississippi River

List any discharge authorizations required for the system.

Minnesota Pollution Control Agency NPDES Permit No. 0000671, permit  
reissued 2/8/88. and Metropolitan Sewer Board registration dated May 31, 1974.

Indicate any regulated discharge limitations relating to water temperature, quality or quantity.

Temperature 30C (86f) daily max, total residual chlorine daily maximum effluent  
limitation of 0.10 mg/l and 4.6 lbs/day for each outfall (2), and pH shall  
not be less than 6.0 nor greater than 9.0. No floating solids or visible  
foam, discharges shall not contain oil or other substances in amounts sufficient  
to create a visible color film on the surface of the receiving waters.

**WATER CONSERVATION**

Does the system use variable speed pumps? [] Yes [ ] No  
Are any load or system controls used to reduce water requirements by reducing the operating load conditions (i.e. load shedding, temperature set points)?

Set points but no load shedding  
\_\_\_\_\_  
\_\_\_\_\_

List any other measures utilized to reduce water use:

Automatic level control valve on splash tank make-up water valve.  
\_\_\_\_\_  
\_\_\_\_\_

What changes can be done to the system to reduce water use?

Study initiated to determine best methods  
\_\_\_\_\_  
\_\_\_\_\_

What alternatives exist for reuse of the discharge water?

Re-used for condensor water  
Re-used for irrigation of lawn  
Returned to ground water and to maintain pond levels  
\_\_\_\_\_

(57)

Indicate any anticipated future changes in water use and state reasons for projected increases or decreases.

Study initiated to determine best methods of obtaining future decreases  
in water usage

Please provide us the following information about the person that completed the survey.

Name Merle C. Olson

Title Manager, Facility Systems & Space Planning

Telephone Number 540-3395

Please give the name and phone number of someone that can provide additional information, if different than above.

Contact Person John Bjoin - JFB Mechanical Engineer

Telephone Number 540-2494

*20 July 1988*  
*Research*  
*GREEN SE WAW*  
*MINT*  
*COPI*  
*GREEN*

**This survey is to be completed and mailed by September 15, 1989 to:**


Department of Natural Resources - Division of Waters  
Attn: Jim Japs  
Geothermal Heating and Cooling Survey  
Box 32, 500 LaFayette Road  
St. Paul, MN 55155-4032

(1)

WELL WATER FLOW DIAGRAM  
GENERAL MILLS, INC  
ONE GENERAL MILLS BLVD  
GOLDEN VALLEY, MN

10/18/89  
J. BOJIN

NO A/C  
for 150T



DEEP WELLS

NO. 1

NOTES

- ① 18 COOLING COILS + PERIMETER INDUCTION UNITS ON WELL WATER FOR MAX FLOW OF 2375 GPM AT 7°F AT = 700 TONS (EST)
- ② 14 COOLING COILS ON CLOSED LOOP CHILLERS, CONNECTED LOAD 1 @ 165 3 @ 350T AND 1 @ 410T. OPERATING LOAD 1 @ 350 AND 1 @ 410 = 760T
- ③ 3 COOLING COILS ON ONCE THRU SYSTEM WITH 1-150TON CHILLER TO LOWER WELL WATER TEMP.

## SYSTEM SIZE RATING

### HEATING - CONNECTED LOAD

CV-1	325 GPM	1625 MBH
CV-2	275 GPM	1350 MBH
CV-3	100 GPM	500 MBH
CV-4	244 GPM	2440 MBH
CV-8	165 GPM	1650 MBH
CV-8A	165 GPM	1650 MBH
CV-6	125 GPM	1260 MBH
CV-7	40 GPM	400 MBH
CV-11	328 GPM	3280 MBH
	<u>1762 GPM</u>	<u>14,155 MBH</u>

### ESTIMATED ACTUAL PEAK LOAD

ASSUME MAXIMUM PEAK IS 70% OF CONNECTED

$$\begin{aligned}\text{PEAK LOAD} &= 70\% \times 14,155 \text{ MBH} \\ &= 9,908 \text{ MBH}\end{aligned}$$

### COOLING - CONNECTED LOAD

WELL WATER - ONCE THRU	2375 GPM @ 7°FAT	=	700 T
CLOSED LOOP - CHILLED WATER		=	760 T
WELL WATER - ONCE THRU - CHILLED		=	<u>150 T</u>
			1610 T

### ESTIMATE ACTUAL PEAK LOAD

ASSUME MAXIMUM PEAK IS 90% OF CONNECTED

$$\begin{aligned}\text{PEAK LOAD} &= 90\% \times 1610 \\ &= 1450 \text{ TONS}\end{aligned}$$

(6)



(3)

GENERAL WATER USE EFFICIENCY

AVERAGE EFFICIENCY OF WATER USE

$$\text{WELL WATER} = \frac{2375 \text{ GAL}}{700 \text{ TON}} = 3.39 \text{ GAL/TON}$$

$$\text{CLOSED LOOP} = \frac{1800 \text{ GAL}}{760 \text{ TON}} = 2.37 \text{ GAL/TON}$$


$$\text{HEATING} = \frac{1762 \text{ GAL}}{14,155,000 \text{ BTU}} = 0.00012 \text{ GAL/BTU}$$

(61)

# WATER WELL INFORMATION

WELL #

PART A		WELL LOCATION			
<input checked="" type="checkbox"/> Owners Name <input type="checkbox"/> Authorized Agent		General Mills, Inc		Telephone Number: Home ( ) Work (612) 540-2184	
Mailing Address: Number One General Mills Blvd Golden Valley, MN 55426		Place an "x" on the grid showing the exact location of your well. The grid is one section (640 acres divided into 1/4, 1/4, 1/4 sections). (160, 40, 10 acres).			
County: Hennepin	Township Name: Golden Valley	Township No.: 117 <sup>N</sup> <sub>S</sub>	Range Number: 21 <sup>E</sup> <sub>W</sub>	Section: 6	Fraction: NW 1/4 SE 1/4 NW 1/4



PART B		WELL CONSTRUCTION			
Name of Company which Drilled Well: Bergerson-Caswell, Inc		Date Completed: 1957	Drilled Depth: 478'	Present Depth: 478'	
CASING	MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Concrete <input type="checkbox"/> Wood <input type="checkbox"/> Other	Height Above(Below) Land Surface: 1 ft	Interval: from _____ feet to _____ feet	DRILLING METHOD: (If known): <input type="checkbox"/> Mud Rotary <input type="checkbox"/> Air Rotary <input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Bored/Augered <input type="checkbox"/> Dug <input type="checkbox"/> Other	
	Diameter: 16 inches	Length: _____ feet	Diameter: _____ inches	USE: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Livestock <input type="checkbox"/> Irrigation <input type="checkbox"/> Public Supply <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Industrial	
	<input type="checkbox"/> Yes (if yes, complete all of this section) <input checked="" type="checkbox"/> No <input type="checkbox"/> Open Hole from _____ feet to _____ feet	Length: _____ feet	Interval: from _____ feet to _____ feet	Non-Pumping Water Level Below(Above) Land Surface: 53 feet 1957 date measured tape how measured (steel tape, etc.)	
SCREEN	MATERIAL: <input type="checkbox"/> Stainless Steel <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Other	Age: 7 years	Pumping Rate: 800 gpm	Pumping Water Level Below Land Surface: 80 feet 1982 date measured tape how measured (steel tape, etc.)	
	TYPE: <input type="checkbox"/> Submersible <input type="checkbox"/> Jet, Shallow <input type="checkbox"/> Jet, Deep <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input type="checkbox"/> Other	Pump Setting - submersible (Below Ground Level) 150 ft.	Drop Pipe Length - non-submersible (Below Ground Level) 150 ft.	Flowing Well: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	<input type="checkbox"/> Yes (if yes, complete all of this section) <input checked="" type="checkbox"/> No <input type="checkbox"/> Open Hole from _____ feet to _____ feet	Length: _____ feet	Interval: from _____ feet to _____ feet	Non-Pumping Water Level Below(Above) Land Surface: 53 feet 1957 date measured tape how measured (steel tape, etc.)	

PART C		WELL CONDITION	
Note: Attach additional sheets as needed.			
CASING: <input type="checkbox"/> Cracked <input type="checkbox"/> Holes <input type="checkbox"/> Filled with Sediments <input type="checkbox"/> Incrusted <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection		
SCREEN: (if one exists): <input type="checkbox"/> Incrusted <input type="checkbox"/> Plugged <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Other	Comment (describe method of inspection): N/A		
PUMP: <input type="checkbox"/> Incrusted <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Electrical <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection		
DROP PIPE: <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Holes/Cracks <input type="checkbox"/> Water Marks <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - reworked in 1982		
DISTRIBUTION: <input type="checkbox"/> Plugged Lines <input type="checkbox"/> Vacuum in Lines <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition		
Other (describe method of inspection):			

PART D		SIGNATURES	
Well Owner or Agent: 	Date: 10/18/89	Driller: 	Date: 10/17/89

(62)

# WATER WELL INFORMATION

PART A WELL LOCATION					
<input checked="" type="checkbox"/> Owners Name <input type="checkbox"/> Authorized Agent    General Mills, Inc			Telephone Number: Home (    ) Work (612) 540-2184		
Mailing Address: Number One General Mills Blvd Golden Valley, MN 55426			Place an "x" on the grid showing the exact location of your well. The grid is one section (640 acres divided into 1/4, 1/4, 1/4 sections). (160, 40, 10 acres).		
County: Hennepin	Township Name: Golden Valley	Township No.: 117 <sup>N</sup> <sub>S</sub>	Range Number: 21 <sup>E</sup> <sub>W</sub>	Section: 6	Fraction: SE 1/4 SW 1/4 NW 1/4

PART B WELL CONSTRUCTION				
Name of Company which Drilled Well: Bergerson-Caswell, Inc		Date Completed: 1957	Drilled Depth: 465'	Present Depth: 465'
CASING	MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Concrete <input type="checkbox"/> Wood <input type="checkbox"/> Other	Height Above(Below) Land Surface: 1 ft	Interval: from _____ feet to _____ feet	DRILLING METHOD: (if known): <input type="checkbox"/> Mud Rotary <input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Dug <input type="checkbox"/> Air Rotary <input type="checkbox"/> Bored/Augered <input type="checkbox"/> Other
	Diameter: 16 inches	Length: _____ feet	USE: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public Supply <input type="checkbox"/> Other <input type="checkbox"/> Livestock <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Irrigation <input type="checkbox"/> Industrial	
	<input type="checkbox"/> Yes (if yes, complete all of this section) <input checked="" type="checkbox"/> No <input type="checkbox"/> Open Hole from _____ feet to _____ feet		Diameter: _____ inches	
SCREEN	MATERIAL: <input type="checkbox"/> Stainless Steel <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Other	Length: _____ feet	Interval: from _____ feet to _____ feet	Non Pumping Water Level Below(Above) Land Surface: 50 feet 1957 date measured tape how measured (steel tape, etc.)
	<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Jet, Shallow <input type="checkbox"/> Jet, Deep <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		Age: 2 years	Pumping Rate: 800 gpm
	Pump Setting - submersible (Below Ground Level) 160 ft. Drop Pipe Length - non-submersible (Below Ground Level) 160 ft.		Pumping Water Level Below Land Surface: 95 feet 1987 date measured tape how measured (steel tape, etc.)	Flowing Well: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

PART C WELL CONDITION	
Note: Attach additional sheets as needed.	
CASING: <input type="checkbox"/> Cracked <input type="checkbox"/> Filled with Sediments <input type="checkbox"/> Holes <input type="checkbox"/> Incrusted <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - video inspection
SCREEN: (if one exists): <input type="checkbox"/> Incrusted <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Plugged <input checked="" type="checkbox"/> Other	Comment (describe method of inspection): N/A
PUMP: <input type="checkbox"/> Incrusted <input type="checkbox"/> Electrical <input type="checkbox"/> Rusted/Corroded <input checked="" type="checkbox"/> Other	Comment (describe method of inspection): New in 1987
DROP PIPE: <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Water Marks <input type="checkbox"/> Holes/Cracks <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection
DISTRIBUTION: <input type="checkbox"/> Plugged Lines <input checked="" type="checkbox"/> Other <input type="checkbox"/> Vacuum in Lines <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection
Other (describe method of inspection):	

PART D SIGNATURES			
Well Owner or Agent: 	Date: 10/18/89	Driller: 	Date: 10/17/89

# WATER WELL INFORMATION

JUNE 1986

PART A WELL LOCATION						
<input checked="" type="checkbox"/> Owners Name <input type="checkbox"/> Authorized Agent				Telephone Number: Home ( ) Work (612) 540-2184		
Mailing Address: Number One General Mills Blvd Golden Valley, MN 55426				Place an "x" on the grid showing the exact location of your well. The grid is one section (640 acres divided into 1/4, 1/4, 1/4 sections). (160, 40, 10 acres)		
County: Hennepin	Township Name: Golden Valley	Township No.: 117 (N) S	Range Number: 21 E	Section: 6	Fraction: SW 1/4 NE 1/4 NW 1/4	

PART B WELL CONSTRUCTION						
Name of Company which Drilled Well: Bergerson-Caswell, Inc			Date Completed: 1957	Drilled Depth: 452'	Present Depth: 452'	
CASING	MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Concrete <input type="checkbox"/> Wood <input type="checkbox"/> Other	Height Above(Below) Land Surface: 1 ft.	Interval: from _____ feet to _____ feet	DRILLING METHOD: (if known): <input type="checkbox"/> Mud Rotary <input type="checkbox"/> Air Rotary <input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Bored/Augered		
	Diameter: 16 inches	Length: _____ feet	Diameter: _____ inches	USE: <input type="checkbox"/> Domestic <input type="checkbox"/> Livestock <input type="checkbox"/> Irrigation <input type="checkbox"/> Public Supply <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Industrial		
	<input type="checkbox"/> Yes (if yes, complete all of this section) <input checked="" type="checkbox"/> No <input type="checkbox"/> Open Hole from _____ feet to _____ feet	MATERIAL: <input type="checkbox"/> Stainless Steel <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Other	Length: _____ feet	Interval: from _____ feet to _____ feet	Non-Pumping Water Level Below(Above) Land Surface: 86 feet 1957 date measured tape how measured (steel tape, etc.)	
SCREEN	TYPE: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Jet, Shallow <input type="checkbox"/> Jet, Deep <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	Age: 6 years	Pumping Rate: 1000 gpm	Pumping Water Level Below Land Surface: 120 feet 1983 date measured tape how measured (steel tape, etc.)		
	Pump Setting - submersible (Below Ground Level) 165 ft.	Drop Pipe Length - non-submersible (Below Ground Level) 165 ft.	Diameter: _____ inches	Flowing Well: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		

PART C WELL CONDITION	
Note: Attach additional sheets as needed	
CASING: <input type="checkbox"/> Cracked <input type="checkbox"/> Holes <input type="checkbox"/> Filled with Sediments <input type="checkbox"/> Incrusted <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection
SCREEN: (if one exists): <input type="checkbox"/> Incrusted <input type="checkbox"/> Plugged <input type="checkbox"/> Rusted/Corroded <input checked="" type="checkbox"/> Other _____	Comment (describe method of inspection): N/A
PUMP: <input type="checkbox"/> Incrusted <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Electrical <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - rebuilt in 1983
DROP PIPE: <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Holes/Cracks <input type="checkbox"/> Water Marks <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection
DISTRIBUTION: <input type="checkbox"/> Plugged Lines <input type="checkbox"/> Vacuum in Lines <input checked="" type="checkbox"/> Other <u>Good</u>	Comment (describe method of inspection): Good condition - visual inspection
Other (describe method of inspection):	

PART D SIGNATURES			
Well Owner or Agent: 	Date: 10/18/89	Driller: Carl L. Nitt	Date: 10/18/89

64

# WATER WELL INFORMATION

WELL #46

## WELL LOCATION

Telephone Number: Home (     ) Work (612) 540-2184					
Agent: General Mills, Inc					
Address: Number One General Mills Blvd Golden Valley, MN 55426		Place an "X" on the grid showing the exact location of your well. The grid is one section (640 acres divided into 1/4, 1/4, 1/4 sections). (160, 40, 10 acres).			
Township Name: Hennepin	Township No.: Golden Valley	Range Number: 117 <sup>N</sup> <sub>S</sub>	Section: 21 <sup>E</sup> <sub>W</sub>	Fraction: NW 1/4 NE 1/4 NW 1/4	

## PART B WELL CONSTRUCTION

Name of Company which Drilled Well: Bergerson-Caswell, Inc		Date Completed: 1979	Drilled Depth: 455'	Present Depth: 455'	
C A S I N G	MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Concrete <input type="checkbox"/> Wood <input type="checkbox"/> Other	Height Above(Below) Land Surface: 1 ft Diameter: 16 inches Length: 271 feet	Interval: from +1 feet to 270 feet	DRILLING METHOD: (If known): <input type="checkbox"/> Mud Rotary <input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Dug <input type="checkbox"/> Air Rotary <input type="checkbox"/> Bored/Augered <input type="checkbox"/> Other	
	<input type="checkbox"/> Yes (if yes, complete all of this section) <input checked="" type="checkbox"/> No <input type="checkbox"/> Open Hole from _____ feet to _____ feet		Diameter: _____ inches Length: _____ feet	USE: <input type="checkbox"/> Domestic <input type="checkbox"/> Public Supply <input type="checkbox"/> Other <input type="checkbox"/> Livestock <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Irrigation <input type="checkbox"/> Industrial	
S C R E E N	MATERIAL: <input type="checkbox"/> Stainless Steel <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Other	Interval: from _____ feet to _____ feet	Non-Pumping Water Level Below (Above) Land Surface: _____ 73 feet _____ 1979 date measured _____ tape how measured (steel tape, etc.)		
	TYPE: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Jet, Shallow <input type="checkbox"/> Jet, Deep <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	Age: 1 years	Pumping Rate: 1000 gpm	Pumping Water Level Below Land Surface: _____ 97 feet _____ 1979 date measured _____ tape how measured (steel tape, etc.)	
P U M P	Pump Setting — submersible (Below Ground Level) 165 ft.		Flowing Well: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
	Drop Pipe Length — non-submersible (Below Ground Level) 165 ft.				

## PART C WELL CONDITION

Note: Attach additional sheets as needed.

CASING: <input type="checkbox"/> Cracked <input type="checkbox"/> Filled with Sediments <input type="checkbox"/> Holes <input type="checkbox"/> Incrusted <input checked="" type="checkbox"/> Other Good	Comment (describe method of inspection): Good condition - visual inspection
SCREEN: (if one exists): <input type="checkbox"/> Incrusted <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Plugged <input type="checkbox"/> Other	Comment (describe method of inspection): N/A
PUMP: <input type="checkbox"/> Incrusted <input type="checkbox"/> Electrical <input type="checkbox"/> Rusted/Corroded <input checked="" type="checkbox"/> Other Good	Comment (describe method of inspection): Good condition - rebuilt in 1988
DROP PIPE: <input type="checkbox"/> Rusted/Corroded <input type="checkbox"/> Water Marks <input type="checkbox"/> Holes/Cracks <input checked="" type="checkbox"/> Other Good	Comment (describe method of inspection): Good condition - visual inspection
DISTRIBUTION: <input type="checkbox"/> Plugged Lines <input checked="" type="checkbox"/> Other Good <input type="checkbox"/> Vacuum in Lines	Comment (describe method of inspection): Good condition - visual inspection
Other (describe method of inspection):	

## PART D SIGNATURES

Well Owner or Agent: 	Date: 10/18/89	Driller: 	Date: 10/17/89
--------------------------	-------------------	--------------	-------------------

(65)

**A P P E N D I X**

**GAVIIDAE COMMONS**



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 2  
Comm. No. 4435.00 Date 3/1/90  
GAVIINDAE

GAVIINDAE

ANNUAL OPERATING COSTS - SUMMARY

A) EXISTING OPERATION

<u>PUMPING</u>	<u>12,838</u>
<u>CHILLERS</u>	<u>5,367</u>
<u>HEAT PUMPS</u>	<u>12,487</u>
<u>WATER TREATMENT</u>	<u>12,000</u>
	<u>42,692</u>

B) CONVERSION TO COOLING TOWER

<u>PUMPING (TOWER)</u>	<u>= 11,078</u>
<u>CHILLERS (EXIST)</u>	<u>6,814 + 1,969 = 8,783</u>
<u>CHILLER (NEW)</u>	<u>= 3,686</u>
<u>HEAT PUMPS</u>	<u>= 13,736</u>
<u>WATER MAKEUP + SEWER</u>	<u>6,796</u>
<u>TOWER OPER</u>	<u>1,453</u>
<u>WATER TREATMENT</u>	<u>2,493</u>
	<u>48,030</u>

GAUILLAGE  
TON-HOUR CALCULATIONS

A) EXISTING DESIGN

CHILLER #	TONS	LOAD*	HRS OPERATION*	TON HOURS
1	265	.943	900	225,000
2	265	.943	260	65,000
HEAT PUMPS	284	1.0	1000**	284,000
WELL WATER HK	128	1.0	900	115,200
		912 TONS		

\* PER GAUILLAGE

\*\* ASSUMED

TOTAL TON HOURS 689,200

B) CONVERSION

CHILLER #	TONS	LOAD	HRS OPER	TON HOURS
1	265	.943		
2	265	.943		
3 (NEW)	128	1.0		
4 HEAT PUMPS	284	1.0		
5				
6				
COILS	0			

TOTAL TON HR 689,200

NOTE: FOR DISTRICT COOLING THE COOLING ANNUAL COSTS AND ANNUAL \$/TON HR COST RATIOS ARE BOTH BASED ON 900 FULL LOAD HOURS. MPLS ENERGY CR ESTIMATED A 400 TON ANNUAL LOAD BASED ON CITY CENTER:  $400 \text{ TONS} \times 900 \text{ FL HR} = 360,000 \text{ FL HRS}$





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project CONSUMPTIVE WATER STUDY Sheet 1 of 3  
Comm. No. 4485.02 Date 1/31/90

GAUVADE COMMONS

WATER SOURCE HEAT PUMPS, STEAM REQMT

STEAM HEAT EXCH TO SUPPLY SOURCE W. HEAT FOR H.P.'S:

HEAT CALCULATIONS - HOURS OF OPERATION IN HEAT MODE

ASSUME FOR HIGH-RISE BLDG A  $15 \text{ BTU/SF}$  NET HEAT LOAD

CALC:  $30 \text{ BTU/SF LOSS} - \text{INTERNAL GAINS} = \text{NET LOAD}$

WHERE:  $0.5 \text{ CFM/SF INTERNAL COOLING} \times \frac{\text{TON}}{442 \text{ CFM}} \times 12000 \frac{\text{BTU}}{\text{TON}} = 15 \text{ BTU/SF}$  INTERNAL LOAD

THEFORE:  $30 - 15 = 15 \text{ BTU/SF NET HEAT LOAD}$

$125,000 \text{ SF} \times 15 \frac{\text{BTU}}{\text{SF}} = 1,875,000 \text{ BTUH}$

HEATING DEGREE DAYS

ASHRAE 1931 CH28

$$1) E = \frac{H_L \times D \times 24}{\Delta T \times K \times V} \text{ CB}$$

$D = 9332 = \text{Degree Days, } 65^\circ$

$G_D = \text{Adjustment to } 65^\circ 24$   
 $= .64$

$H_L = 1,875,000 \text{ BTUH}$

= BTU INPUT REQ'D  
FOR SEASON.

$\Delta T = \text{Design Temp D.F.}$   
 $= (68 - (-16)) = 84^\circ \text{F}$

$K = .6 \text{ per ASHRAE Ch. 55}$

$V = \text{Heating value of fuel}$   
 $= 3.5 \text{ COP Heat Pump}$

$= \frac{\text{BTUH}_{\text{heating output}}}{\text{BTUH}_{\text{heating input}}}$

$24 = \text{HRS/DAY}$

2) KNOW TOTAL BTU/H CAPACITY OF HEAT PUMPS.

$$\frac{\text{BTU}_{\text{REQ'D}}}{\text{BTU/H capacity}} = \text{HRS.}$$

(11)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GJR  
Project STUDY Sheet 2 of      
Comm. No. 4485.00 Date 2/2/91

STEAM FOSC HP SOURCE WATER

$$E = \frac{1,875,000 \times 8382 \times 24 \times .64}{84 \times .6 \times 3.5}$$

$$= 1.3685 \times 10^9 \text{ BTU INPUT} \times \frac{\text{COP}}{\text{BTUH INPUT}} = 4.7897$$

2) TOTAL HEATING CAPACITY OF 105 HEAT PUMPS =  $\frac{3142100 \text{ BTU}}{\text{H}} \text{ OUTPUT}$

$$\frac{4.7897 \times 10^9 \text{ BTU}}{3142100 \text{ BTU/H}} = 15244 \text{ H} = \boxed{1524 \text{ HOURS}}$$

USE 1500 HOURS HEATING

TOTAL GPM FOR 105 EXISTING HEAT PUMPS IS BALANCED AT 778 GPM :

CHECK 778 GPM AGAINST 3,142,100 BTUH  
3142100 = 500 GPM AT  
 $\Delta T = 8.077 \text{ OK}$

KNOW TOTAL CAPACITY = 3142100 BTU/H

STEAM REQUIREMENT

$$\frac{3142100 \text{ BTU}}{\text{H}} \times \frac{1 \text{ lb STEAM}}{1000 \text{ BTU}} = 3142.1 \text{ lbs STM} \times 1500 \text{ H}$$

$$= 4.7163 \times 10^6 \text{ lbs STM}$$

PER MPLS ENERGY CR, STEAM COST = \$5.51/1000 lbs STM

$$4.7163 \times 10^6 \text{ lbs STM} \times \frac{\$5.51}{1000 \text{ lbs STM}} = \$25,969 \text{ STEAM COST}$$

(70)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project STUDY Sheet 3 of 3  
Comm. No. 4485.00 Date 2/2/90

STEAM

CREDIT FOR STEAM COST BASED ON IMPROVED HEAT PUMP  
COP: 90° SOURCE WATER TO HEAT PUMPS  
RESULTS IN ~20% MORE CAPACITY. ASSUME  
PREVIOUS CAPACITY AT 70° SOURCE WATER  
SUPPLIED THE LOAD ADEQUATELY. TAKE  
CREDIT ON EXTRA CAPACITY AT 90° SOURCE W:

HEAT PUMPS BOOST HEAT CAPACITY ~25%  
FROM SOURCE CAPACITY, WITH COMPRESSOR  
WORK HEAT:

$$3.1421 \times 10^6 \text{ BTU/H} \times 1.25 = 7.855 \times 10^6 \text{ BTU/H}$$

$$7.855 \times 10^6 \text{ BTU/H} \times \frac{1 \text{ BTU/elec}}{3.5 \text{ BTU output}} \times \frac{1 \text{ W}}{3.412 \text{ BTU/elec}} \times \frac{1000 \text{ W}}{1 \text{ KW}} \\ \times 1500 \frac{\text{HR}}{\text{YR}} \times \frac{\$.045}{\text{KWH}} \times .20 \text{ CREDIT} = \frac{\$888}{\text{YR}}$$

ANNUAL OPERATING COST OF HEAT PUMPS @  
1500 HRS / SEASON:

A) STEAM COST FOR SOURCE WATER @ 90° = \$25,969

B) CAPACITY CREDIT FOR COP @ 90° F VS 70° F = (\$888)

C) ELEC COST FOR HEAT PUMPS IN = 0

HEATING MODE — ASSUME HEAT PUMPS  
OPERATE IN SAME MANNER, WHETHER  
USING WELL W., TOWER W., OR DISTR. HT.  
THE COST DIFFERENTIAL WAS  
CALCULATED AS A HEAT PUMP CREDIT.

TOTAL OPER COST HEAT PUMPS HEATING = 25,081

(71)

Client DNR

Project CONSUMPTIVE WATER STUDY

Comm. No. 4485.00

By GER

Sheet 1 of 1

Date 1/29/90

GAULDAE COMMONS

ANNUAL OPERATING COST -  
USING WELL WATER

A) PUMPS

WELL PUMP

NOTE 1) PER GAULDAE, WELL PUMP EFFIC IS 84.5%

2) 75 HP PUMP BASED ON INSTALLED 100 HP  
 - 25 HP DEVOTED TO SALES BLDG

$$75 \text{ HP} \times \frac{746 \text{ W}}{\text{HP}} \times \frac{.85 \text{ LOAD}}{.845 \text{ EFFIC}} \times \frac{\$ .045}{\text{KWH}} \times \frac{3000 \text{ HRS}}{\text{YR}} = 7598$$

$$* 10 \text{ HRS Day} \times 300 \text{ DAY} = 3000 \text{ EITHER HEAT PUMP, CHILLED WATER OR WELL WATER HEAT EXCH (PPEE)$$

= OPERATING HOURS, (NOT FULL LOAD HRS)

WELL WATER BOOSTER PUMPS - TWO

$$20 \text{ HP} \times 746 \times \frac{.85 \text{ LOAD}}{.90 \text{ EFFIC}} \times \frac{\$ .045}{\text{KWH}} \times 3000 \times 2 = \$ 3305$$

CONDENSER WATER PUMPS - TWO

$$20 \text{ HP} \times 746 \times \frac{.85}{.90} \times \frac{\$ .045}{\text{KWH}} \times 1200 \text{ HRS} \times .94 \times 2 = 4300$$

\*\* MOD. VALUES: LOAD SAME AS CH

CHILLED WATER PUMPS - TWO

(CHILLED WATER PUMPAGE SAME IN BOTH) = 0  
 WELL W & CONVERSION SYSTEM

TOTAL PUMP COST = \$ 12338



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project WATER STUDY Sheet 2 of 3  
Comm. No. 4485.00 Date 1/29/90

GRANDDAE ANNUAL OPER COSTS - COND - WELL W

B) EQUIPMENT

WATER SOURCE HEAT PUMPS

ASSUME EQUIVALENT FULL LOAD HR \* FULL LOAD = <sup>OPER HRS</sup> LOAD PROFILE

NOTE 1)  $EER = \frac{BTUH \text{ COOLING OUTPUT}}{WATT \text{ INPUT}}$  USING WELL WATER (EER PER MANUFACTURER AS INSTALLED)

2) FULL LOAD HOURS: PER ASST. ARE = 800-1200 FL HRS

ASSUME = 1000 FL HRS

$$\frac{BTUH}{WATT} \times \frac{1}{EER} \times \frac{KW}{1000W} \times \frac{\$}{KWH} \times HRS \times QTY = \$/YR$$

$$13,600 \times \frac{1}{11.9} \times \frac{KW}{1000W} \times \frac{\$}{KWH} \times 1000 \times 7 = \$ 360$$

$$13,500 \times \frac{1}{11.4} \times \frac{KW}{1000W} \times \frac{\$}{KWH} \times 1000 \times 1 = \$ 73$$

$$27,000 \times \frac{1}{12.6} \times \frac{KW}{1000W} \times \frac{\$}{KWH} \times 1000 \times 20 = 1928$$

$$31,000 \times \frac{1}{11.7} \times \frac{KW}{1000} \times \frac{\$}{KWH} \times 1000 \times 9 = 1073$$

$$36,000 \times \frac{1}{12.3} \times \frac{1}{1000} \times \frac{\$}{KWH} \times 1000 \times 67 = 8825$$

$$61,500 \times \frac{1}{12.1} \times \frac{1}{1000} \times \frac{\$}{KWH} \times 1000 \times 1 = \$ 228$$

TOTAL = \$ 12487

(73)

GAUIDAE - ANNUAL OPER WELL WATER

CHILLER #1

$$109 \text{ KW} \times \frac{250 \text{ PEAK}}{265 \text{ TOTAL}} \times \frac{\$ .045}{\text{KWH}} \times 900 \text{ HR} = \$ 4164$$

\* PER GAUIDAE

CHILLER #2

$$109 \text{ KW} \times \frac{250}{265} \times \frac{\$ .045}{\text{KWH}} \times 260 \text{ HR} = 1203$$

\$ 5367 / YR

TOTAL EQUIPMENT ANNUAL OPER = \$ 17854

C) WATER TREATMENT PER GAUIDAE = \$ 12,000 / YR

D) MAINT. & LABOR - ASSUME EQUAL, WELL WATER OR TOWER CONVERSION = 0

SUMMARY ANNUAL OPER COST - EXISTING OPERATION

A) PUMPS	12,838
B) EQPT	17,854
C) WATER TR	12,000
D) MAINT & LABOR	0
	<u>42,692</u>



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GPR  
Project CONSUMPTIVE WATER STUDY Sheet 1 of 3  
Comm. No. 448500 Date 1/29/90

GAVILDAE COMMONS

ANNUAL OPERATING COST - CONVERSION  
USING NEW COOLING TOWER

A) PUMPS

TOWER PUMP

912 TONS x 3 GPM/TON CO<sub>2</sub>T = 2736 GPM

BELL & GOSSET PUMP

VSCS 10x12x13 1750 RPM, 2736 GPM, ASSUME 100' HD  
= 88 BHP AND 80% PUMP EFFIC.

PUMP COST - OPER AT 3000 OPERATING HRS (NOT EQUIV. FL)  
TOWER PUMP 88 BHP x  $\frac{746}{1000}$  x  $\frac{\$ .045}{.80 \text{ KW/H}}$  x 3000 = \$11078

CONDENSER PUMP

TOWER PUMP INSTEAD = 0

B) EQUIPMENT OPER

CHILLER #1 IN NEW CONDITIONS .67 KW/TON  
 $177 \text{ KW} \times \frac{250 \text{ PEAK}}{265 \text{ TIL}} \times \frac{\$.045}{\text{KW/H}} \times 900 \text{ FL/HR} = \$6814$

CHILLER #2

$177 \text{ KW} \times \frac{250}{265} \times \$.045 \times 260 = \$1969$

NEW 12% TON CHILLER

- BASED ON McQUAY WHR 100  
 $91 \text{ KW} \times \frac{\$.045}{\text{KW/H}} \times 900 = \frac{3686}{12469}$

(75)

© American Time Products - 4107411-2001 15-2784

ANNUAL OPER. COST - CONVERSION TO TOWER (CONT'D) -  
GAVIIDAE

C) HEAT PUMPS - WATER SOURCE "CLIMATE MASTER"  
EER: PER EIGHT MFR REPRESENTATIVE

$$13,600 \times \frac{1}{10.7} \times \frac{\text{KW}}{1000 \text{ W}} \times \frac{9.045}{\text{KWH}} \times 1000 \text{ HR} \times 7 = 400,800$$

$$18,500 \times \frac{1}{10.3} \times \frac{\text{KW}}{1000} \times .045 \times 1000 \times 1 = 79.3$$

$$27,000 \times \frac{1}{11.5} \times \frac{\text{KW}}{1000} \times .045 \times 1000 \times 20 = 2113$$

$$31,000 \times \frac{1}{10.5} \times \frac{\text{KW}}{1000} \times .045 \times 1000 \times 9 = 1196$$

$$36,000 \times \frac{1}{11.2} \times \frac{1}{1000} \times .045 \times 1000 \times 67 = 9691$$

$$61,500 \times \frac{1}{10.8} \times \frac{1}{1000} \times .045 \times 1000 \times 1 = 256.3$$

\$ 13,736

D) WATER MAKE-UP & SEWER

MAKE-UP WATER COST = EVAP LOSS + BLOWDOWN

SEWER COST = BLOWDOWN

ASSUME: CITY WATER AT AVG MPL + ST.P @ \$1.14/1000 GAL  
SEWER AT \$1.83/1000 GAL

WHERE: TOWER OPER. HRS ≈ AVG FL HR + TOTAL HRS  
FOR WATER MU (EVAP DEPENDANT ON OUTDOOR W





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project WATER STUDY Sheet 3 of 3  
Comm. No. 4485.00 Date 1/29/90

ANNUAL OPER, TOWER CONVERSION, MAKE-UP + BLOWDOWN COSTS  
GAVINDAE

D) CONT'D

EVAP + BLOW-DN

@ 912 TONS 2736 GPM TOWER 78° WET BULB  
7° APPROACH TO 85/95 WATER

EVAP GPM = 27.5

BLOWDN GPM = 9.0

TOTAL = 36.5 GPM

HRS FOR WATER =  $\frac{3000 + 900}{2} = 1950$  HRS

$36.5 \text{ GPM} \times \frac{60 \text{ M}}{\text{H}} \times \frac{1950 \text{ HRS}}{\text{YR}} \times \frac{\$ 1.14}{1000 \text{ GAL}} = \$ 4868$

SEWER

$9 \text{ GPM} \times 60 \times 1950 \times \frac{\$ 1.83}{1000} = \$ 1927$

TOTAL = \$ 6796

E) TOWER FANS OPER - MAKEUP, ONE 60 HP MTR, ASSUME  
FAN HP SELECTION BASED ON 70% MOTOR LOAD, 95% EFFIC  
MOTOR, TWO-SPEED OPERATION, 1/2 TIME AT LOW SPD.

1) HIGH SPD  $60 \times .746 \times \frac{.70}{.95} \times \frac{2.045}{\text{KWH}} \times 1500^* = \$ 1113$

2) LOW  $13 \text{ HP} \times .746 \times \frac{.10}{.95} \times .045 \times 1500^* = \$ 345$

\*ASSUME AVG UP TO 3000 OPER  
FOR YEAR-ROUND HEAT PUMP  
@ 10 HR/DAY X 300 DAYS

TOTAL \$ 1458

F) WATER TREATMENT

SEE SEPARATE SHEET

\$ 2493

GAMINARE

DISTRICT COOLING - ANNUAL OPERATING COST

A) PERL MPLS ENERGY CR @ 400 TONS  
 900 HRS

$$\frac{\$ 112,943}{360,000} = .3137 \frac{\$}{\text{TON HR}}$$

B) TO COMPARE WITH WELL W. OPER COSTS AND CONVERSION OPER COSTS, WHERE MAINT. & LABOR COSTS WERE ASSUMED EQUAL AND THEREFORE NOT INCLUDED:

SUBTRACT OUT OF \$.3137/TONHR THE COST OF MAINTENANCE, ETC:

* BASE	\$ .3137 / TON HR
* LABOR	(.0160)
* MAINT & SUPPLIES	(.0117)
* CAPITAL EQPT	(.0610)
	<hr/>
	\$ .225 / TON HR

FOR COOLING COST COMPARISON:

\* COSTS PER MPLS ENERGY CENTER, 12/89 & 1/90



GAVIIDA

REHV LOAD GPM'S AND TONS  
COOLING ONLY

A) LOAD

2 CHILLERS

$$250 \text{ TONS} \times 2 = 500$$

HEAT PUMPS 284 TONS

HEAT EXCH (WELL W.) 128 TONS

TTL 912 TONS

B) GPM

$$\frac{\text{WELL WATER HEAT EXCH TONS} \times 24}{24} = \text{GPM AT}$$

$$\frac{\text{CONDENSER SIDE TONS} \times 30}{30} = \text{GPM AT}$$

CHILLERS

$$\frac{500 \times 30}{(70-64)} = 938$$

HEAT PUMPS

$$\frac{284 \times 30}{10.95}$$

= 778 (SUMMED ACTUAL GPM'S AS BALANCED)

HEAT EX (WELL W.)

$$\frac{128 \times 24}{3}$$

$$= \frac{1024}{2740} \text{ GPM}$$

$$C) \frac{\text{GPM}}{\text{TON}} = \frac{2740}{912} = \boxed{3.00439} \text{ GPM/TON}$$



GAUVIDAE

TOTAL FIRST COSTS - CONVERSION TO COOLING TOWER

A) CHILLERS FIRST COSTS

1) CENTRIFUGAL CHILLERS - YORK

GEAR CHANGES FOR 35° WATER:  $25000 \times 2 = \$50,000$

CONDENSER VESSELS = 0

= 0

2) RECIPROCATING CHILLERS

ADD NEW 128 TON YORK YORKHILL

= \$32,000

START-UP & BASE

2,000

TOTAL

\$84,000

B) ADD TOWER

\$38,133

PER MARLEY QUOTE

\$38,133

\$38,133 / 912 TONS = \$42/TON

C) PUMPS

R 750 GPM

= B & G PUMP VSSC 10x12x13

\$7,510

1750 RPM, 100" HD, 88 BHP

D) PIPE/INSUL

2750 GPM @ 10 FPS = 10" PIPE

250' @ 10" =  $250 \times 72.35 = 18088$

250' @ 8" =  $250 \times 55.80 = 13950$

TOTAL

\$32,038

E) INSTALLATION

REVAL TO EQUIPMENT

16,000 CHILLER + 38133 + 7510 + 32038 = 93,681

SUBTOTAL

255,362

F) CONTINGENCIES

30% =  $255,362 \times .3 =$

76,609

TOTAL

\$331,971



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By \_\_\_\_\_  
Project WATER USE STUDY Sheet 2 of 2  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

GAULDAE

TOTAL FIRST COSTS: DISTRICT HEAT/COOL CONVERSION

PIPING

(HX, steam pipes to HX, source water pipes from HX)

3.142  $\frac{\text{lbs steam @ 250 psi}}{H}$  = 8" pipe

200' @ 8" \$55.80/LF = \$11,160  
MANN'S CATALOGUE  
1989 p. 87

HEAT EXCHANGER

- 778 GPM

STEAM TO  
WATER

(Mann's 1989 p167) \$26,700

TOTAL FIRST COST - NEW PIPE & HX,  
DISTRICT HEAT & COOL =  $\frac{11160 + 26700}{= \$37860}$

TOTAL ANNUAL - FOR LIFE CYCLE COST ANALYSIS  
DISTRICT COOL & HEAT

181,000 COOL

25,969 HEAT

- 888 HEAT PUMP HEATING MODE COST DIFFERENTIAL

\$106,081 ANNUAL OPER COST TOTAL HEAT & COOL

**YORK**

LEADER IN NEW TECHNOLOGY  
FOR AIR CONDITIONING

Applied Systems  
York International Corporation  
4800 Mustang Circle  
New Brighton, MN 55112  
Telephone Sales (612) 780-4000  
Telephone Service (612) 780-4446  
FAX (612) 780-0643

**TWIN CITIES SALES & SERVICE**  
**FACSIMILE TRANSMITTAL**

TO: OSM DATE: 12/21/89  
 ATTN: GEORGE POTTHENBERGER NO. OF PAGES: \_\_\_\_\_  
 FAX NUMBER: 331-3806 FROM: Jim PORATH  
 SUBJECT: DNR STUDY - CAVIDAE

**MESSAGE:**

GEORGE,

THE FOLLOWING IS THE INFO ON CAVIDAE - HONEYWELL  
STANSON WILL BE COMING SOON.

ORIGINAL CONDITIONS

TOWER CONDITIONS

	ORIGINAL CONDITIONS	TOWER CONDITIONS
MODEL	4TBZC3C1-C100	SAME
GEAR	KQ	KW
EVAP	57/43.6, 4676PM, 2PASS	57/43.6, 4676PM, 2
COND	56/69.8, 5106PM, 2PASS	85/94.49, 7896PM, 2PA
TONS	263	263
KW (KW/TON)	109KW, (.414 KW/TM)	177 KW, (.673 KW/TM)

NOTE: THE INTERNAL SPEED INCREASING GEARS WILL HAVE  
 TO BE CHANGED (FROM KQ TO KW) TO UTILIZE 85°ECM  
 THE CHILLERS WILL NOT WORK WITH THE EXISTING  
 GEAR UNDER THE HIGHER HEAD CONDITIONS OF A  
 COOLING TOWER (85/95).  $\text{\textcircled{2}}$  \$25,000 EACH  
 BUDGET PRICE "KW" GEAR / SERVICE LABOR (TORN-UP)

# Minneapolis Energy Center, Inc.

1060 IDS Center • 80 South 8th Street • Minneapolis, MN 55402  
Telephone (612) 349-6066 • Fax (612) 349-6067

From : mecl3496067

Dec. 29. 1989 03:14 PM FAX

12/29/89

DEAR GEORGE

I HAVE RESEARCHED ACTUAL LOAD ON CITY CENTRAL RETAIL AND ARRIVED AT THE FOLLOWING:

GROSS AREA 280,000 SQ FT

NORMAL ANNUAL CONS. 752,000 TON HOURS

PEAK DEMAND / 1000 SQ FT = 3.0 TONS

▶ GAVIOLAE AREA EXCLUSIVE OF SAKS = 125,000 SQ FT

TESTIMONIAL GAVIOLAE LOAD 3.0 x 125 = 375 TONS

ESTIMATE 400 TONS W/O SAKS @ 900 LBS

720 TONS W SAKS

ANNUAL COST

400 TONS DEMAND	=	\$ 52,968 <sup>00</sup>
360,000 TON HRS/YR	=	26,500 <sup>00</sup>
ESCALATION @ .093	=	33,480 <sup>00</sup>
		<hr/>
		112,948 <sup>00</sup>

ANNUAL COST / SQ FT = .90

(83)

GAVIIPAE COMMONS

12/20/84

P# HEAT PUMPS

CLIMATE PAIR	EWT	LWT	EER	TOTAL WATTS	GPM
814-013	70°F	85°F	11.9	1170	2.4
(1 TON)	85°F	95°F	11.0	1250	3.6
(WT4-9)	90°F	105°F	10.1	1320	2.4

814-013 ENTERING CONDITIONS

% GLYCOL = 0  
 GPM = 2.4  
 CFM = 450  
 ENT WAT TEMP - COOLING = 90 ←  
 ENT DRY TEMP - COOLING = 80  
 ENT WET BULB - COOLING = 67  
 ENT WAT TEMP - HEATING = 70  
 ENT DRY BULB - HEATING = 70

PERFORMANCE FOR MODEL 814-013

COOLING

TOTAL BTUH = 13300  
 TOTAL SBTUH = 9900  
 TOTAL WATTS = 1320  
 EER = 10.1  
 HEAT OF REJ = 17805  
 LVG WAT TEMP = 104.8

HEATING

TOTAL BTUH = 15900  
 TOTAL WATTS = 1350  
 COP = 3.5  
 HEAT OF ABS = 11292  
 LVG WAT TEMP = 60.6

PRESSURE DROP ( FT WATER ) = 11.25

DESIGN POINT DATA VERSION 2.4, COPYRIGHT 1986, CLIMATE MASTER, INC.



GAVIIDAÆ COMMONS

814-013 ENTERING CONDITIONS

% GLYCOL = 0  
GPM = 3.6  
CFM = 450  
ENT WAT TEMP - COOLING = 85 ◀  
ENT DRY TEMP - COOLING = 80  
ENT WET BULB - COOLING = 67  
ENT WAT TEMP - HEATING = 70  
ENT DRY BULB - HEATING = 70

PERFORMANCE FOR MODEL 814-013

COOLING

HEATING

TOTAL BTUH = 13700  
TOTAL SBTUH = 9900  
TOTAL WATTS = 1250  
EER = 11.0  
HEAT OF REJ = 17966  
LVG WAT TEMP = 95.0

TOTAL BTUH = 16400  
TOTAL WATTS = 1380  
COP = 3.5  
HEAT OF ABS = 11690  
LVG WAT TEMP = 63.5

PRESSURE DROP ( FT WATER ) = 23.35

DESIGN POINT DATA VERSION 2.4, COPYRIGHT 1986, CLIMATE MASTER, INC.

814-013 ENTERING CONDITIONS

% GLYCOL = 0  
GPM = 2.4  
CFM = 450  
ENT WAT TEMP - COOLING = 70 ◀  
ENT DRY TEMP - COOLING = 80  
ENT WET BULB - COOLING = 67  
ENT WAT TEMP - HEATING = 70  
ENT DRY BULB - HEATING = 70

PERFORMANCE FOR MODEL 814-013

COOLING

HEATING

TOTAL BTUH = 13900  
TOTAL SBTUH = 9900  
TOTAL WATTS = 1170  
EER = 11.9  
HEAT OF REJ = 17893  
LVG WAT TEMP = 84.9

TOTAL BTUH = 15900  
TOTAL WATTS = 1350  
COP = 3.5  
HEAT OF ABS = 11292  
LVG WAT TEMP = 60.6

PRESSURE DROP ( FT WATER ) = 11.25

85

GAVI'DAE COMPRESSORS

12/20

P. # CLIMATE RANGE	EWT	LWT	EER	TOTAL WATTS	GPM
814-019 (1 1/2 TON) < QTY-17 >	70°F	85°F	11.4	1640	3.25
	85°F	95°F	10.5	1770	4.91
	90°F	105°F	9.7	1870	3.30
814-027 (2 TON) < QTY-20 >	70°F	85°F	12.6	2190	4.70
	85°F	95°F	11.7	2330	6.99
	90°F	105°F	10.7	2470	4.60
814-031 (2 1/2 TON) < QTY-11 >	70°F	85°F	11.7	2720	5.50
	85°F	95°F	10.8	2900	8.19
	90°F	105°F	9.8	3080	5.40
814-036 (3 TON) < QTY-68 >	70°F	85°F	12.3	3000	6.30
	85°F	95°F	11.3	3200	9.38
	90°F	105°F	10.3	3400	6.20
814-042 (3 1/2 TON)	70°F	85°F	12.4	3420	7.20
	85°F	95°F	11.4	3640	10.80
	90°F	105°F	10.5	3860	7.20
814-048 (4 TON)	70°F	85°F	12.0	4190	8.50
	85°F	95°F	11.0	4400	12.70
	90°F	105°F	10.1	4660	8.40
814-060 (5 TON) < QTY-1 >	70°F	85°F	12.1	5200	10.8
	85°F	95°F	11.2	5550	11.2
	90°F	105°F	10.3	5850	10.7

(86)

OFFICE Gorgen Co. MADE BY Dale Schmalz CHECKED BY \_\_\_\_\_ DATE 12-22-89

GPM 2736  
 HW 95 10°R  
 CW 85 7°A  
 WB 78  
 WIND MPH \_\_\_\_\_  
 S. MANUAL \_\_\_\_\_

QUOTATION: FORMAL  LETTER  VERBAL  WORK SHEET COPIES TO: K.C., \_\_\_\_\_  
 PARTY QUOTED George Rothenberger  
 ADDRESS \_\_\_\_\_  
 JOB Gavildae 912 Tons.  
 ADDRESS \_\_\_\_\_  
 ENG'D BY OSM

EQUIPMENT TO SERVE \_\_\_\_\_

NOTE BELOW - SALES COMMENTS - KEY MEN - TITLES - ADDRESSES - ETC.  
 SHOW TOWER ORIENTATION IF LOCATED WITHIN ENCLOSURE

968

NC-941		30,730.
	HC Values	590.
	Basin covers	370
	Lube Lines	310.
	motor out of A-Strm	1300.
	m - Vibration Sw.	130.
	Hand Rail Ladder	850
		<u>34,270</u>
	Freight:	1403.
		<u>35,673.</u>
	Add For 1-60 Hz - 2 Speed Winding High Eff mtr.	2460. <sup>00</sup>
	TOTAL	36730
	17,395	Ship wt.
	39,420	Operating wt

(87)

SUPPLEMENTAL INFORMATION TO:  
GEOHERMAL HEATING AND COOLING SURVEY

November 2, 1989

Permit Number 85-6259  
MCC Development  
Attn: Fred Atkinson  
Gaviidae Common  
651 Nicollet Mall  
Mpls, MN 55402

- Please provide a schematic drawing of the system (include summer and winter mode).
- Well Pump: Variable Speed [ ] yes [X] no  
HP 100/125 GPM 1600/2000 KW Input 74.6/93.25 #2 run for emergency

Efficiency Rating 84.5/86 (if known)  
Heat Pumps: 20 HP  
1600 GPM?

Please indicate the following for each size of unit in the system.

Manufacturer	Climate Master		Model	814 Series	Type	Water/air
1 Ton	Cooling Capacity	<u>13,600 BTU</u>	Heating Capacity	<u>12,700 BTU</u>		
	Design GPM	<u>2.75</u>	Number of Units	<u>7</u>		
	Total GPM	<u>19.25</u>	COP	<u>3.1</u>	EER	<u>10.7</u>
1.5 Ton	Cooling Capacity	<u>18,500</u>	Heating Capacity	<u>17,100</u>		
	Design GPM	<u>4.00</u>	Number of Units	<u>1</u>		
	GPM	<u>4</u>	COP	<u>3.3</u>	EER	<u>10.3</u>
2 Ton	Cooling Capacity	<u>27,000</u>	Heating Capacity	<u>23,200</u>		
	Design GPM	<u>6.2</u>	Number of Units	<u>20</u>		
	GPM	<u>124</u>	COP	<u>3.4</u>	EER	<u>11.5</u>
2.5 Ton	Cooling Capacity	<u>31,000</u>	Heating Capacity	<u>30,800</u>		
	Design GPM	<u>6.9</u>	Number of Units	<u>9</u>		
	GPM	<u>62.1</u>	COP	<u>3.4</u>	EER	<u>10.5</u>
3 Ton	Cooling Capacity	<u>36,000</u>	Heating Capacity	<u>33,400</u>		
	Design GPM	<u>8.3</u>	Number of Units	<u>67</u>		
	GPM	<u>556.1</u>	COP	<u>3.5</u>	EER	<u>11.2</u>
5 Ton	Cooling Capacity	<u>61,500</u>	Heating Capacity	<u>57,100</u>		
	Design GPM	<u>13.8</u>	Number of Units	<u>1</u>		
	GPM	<u>13.1</u>	COP	<u>3.9</u>	EER	<u>10.8</u>

CONDENSATE WATER COOLING MAKE ΔT

$13600 \times 1.25 = 500(2.75) \Delta T = 12.76$

ONE UNIT  $\Delta T = 11.56$

$\Delta T = 10.88$

$31,000 \times 1.25 = 500(6.9) \Delta T = 11.2$

$\Delta T = 10.8$

$\Delta T = 11.14$

778.55 GPM

dy 105

34.6 MBH = 284 COOLING TONS TOTAL

88

4a. PRECOOL OF RETURN WATER (CHILLED WATER FROM BUILDING)  
 HEAT EXCHANGER  
 1) CHILLED WATER SIDE  
 $59.8 / 56.5$  °F EWT/LWT, 930 GPM = 127.8 TONS  $\approx$  SAY 127 TONS  
 2) WELL WATER SIDE  
 $53.0 / 56.0$  ° EWT/LWT, 1020 GPM = 127.5 TONS

4. Chillers: Type #1 York Centrifugal  
 Capacity 265 Tons KW input 109 = .411  $\frac{KW}{TON}$   
 Condenser: Temp In 54 F  
 Temp Out 70 F  
 GPM 510  
 Estimated Peak Load 250 Tons  
 Average Hours Operated per year 900

Type #2 York Centrifugal  
 Capacity 265 Tons KW input 109  
 Condenser: Temp In 54 F  
 Temp Out 70 F  
 GPM 510  
 Estimated Peak Load 250 Tons  
 Average Hours Operated per year 260

5a Water Source Loop PUMP 25 HP 340 GPM

5. Chilled Water Pumps:  
 KW Input 25 Efficiency \_\_\_\_\_  
 HP 25 GPM 465  
 Number of Pumps 2 chilled water pumps and 2 stand-by pumps

6. Control valves on the Well Water loop:  
 2-way  3-way


7. Estimated Operating Costs:  
 Heating \$ \_\_\_\_\_  
 Cooling \$ \_\_\_\_\_  
 Water Treatment \$ 12,000 annually

(89)

Line Drawing ONLY

All Bldg Secondary Systems are Closed loops

Chilled water Systems NOT used IN WINTER



(96)

296-3530

# DOCUMENT TRANSMITTAL

ENCLOSED ARE 4 PAGES (INCLUDING COVER PAGE) TO BE DELIVERED TO:

NAME: Tim Japs

FIRM: Minnesota DNR

CITY: St. Paul # 297-2835

FROM: FRED ATKINSON

FIRM: BCED

CITY: Mpls

PLEASE CALL (612) 372-1500 IF THE COMPLETE DOCUMENT IS NOT RECEIVED.

TO REPLY BY RAPIFAX, DIAL (612) 372-1510.

THANK YOU.

MESSAGE (IF ANY): Please find enclosed the information you requested. Please call me at 372-1226 if you have any additional questions.

Thanks  
[Signature]

(91)

SEPT 18.

GEOTHERMAL HEATING AND COOLING SURVEY

PERMIT NUMBER 85-6295

PERMITTEE MCC Development Co., Inc.

SYSTEM LOCATION Gaviidae Common, 651 Nicollet Mall, Mpls., MN 55402

NAMES AND LOCATIONS OF FACILITIES:

Gaviidae Common, 651 Nicollet Mall, Mpls., MN 55402

TOTAL AREA SERVICED: 237,000 Square feet

WATER SOURCE

Number of wells connected to the system 2

Enclosed is the well information we have on file regarding this installation. Please indicate if this data is accurate and/or submit any additional well data that is available. If no information is enclosed or available, please complete the enclosed Water Well Information form(s).

Are water level measurements taken on the production well(s) or observation well(s)?  Yes  No If yes, please submit a summary of the data. New system - measuring devise being installed.

SYSTEM INFORMATION

Number of years since original system was installed: \_\_\_\_\_

Date system was put on line: April 1989

Is this a once through or closed loop system (describe and attach a simple schematic drawing) ?

Once through

92



Describe any major system modifications and give the completion date:

None, this is a new system

Average water temperature:

Heating 52 intake; (?) discharge (new system)  
Cooling 52 intake: 65 discharge

System size rating:

Heating 13600M (BTU/H) Cooling 525 (Tons/H)

Actual peak load:

Heating (?) (BTU) Cooling 450 (Tons)

Energy efficiency of systems:

Number of chillers/heat pumps in system 2 chillers, <sup>105</sup>80 heat pumps  
Coefficient of Performance (COP) for heat pump 3.1 - 3.5  
Average Energy Efficiency Ratio (EER) for heat pump 10.7 - 11.2  
If no heat pump, chiller efficiency rating (?)  
Number of chillers or heat pumps in system -  
Size rating of chillers/heat pumps 265 each 1.5 - 3 tons

General Water Use Efficiency:

Average Efficiency of Water Use 1.93 (gal/ton) cooling  
1.93 (gal/BTU) heating

How much water is recirculated? None  
How much water is lost in the system, where is it lost and how is the amount of water loss determined?

None

If cooling towers are part of the system, how many are there, how much evaporative loss occurs in this loop, and how is the amount of water loss determined?

N/A

(93)

What is the design capacity of the towers. \_\_\_\_\_  
If cooling towers are not present in the system please describe the feasibility of adding towers including any site and/or system limitations.

---

---

---

---

---

---

---

---

**WATER USAGE**

Indicate the percentage of all primary and secondary uses of the water:

\_\_\_\_\_ Heating                      100 Air conditioning (in summer)  
\_\_\_\_\_ Processing                    100 Other: Heat pumps in winter

Average pumpage: 1,000 gpm; 24 hours/day; 12 months/year

Are flow meters used to determine water usage? []Yes [ ]No

If meters are not used, describe how the amount of water appropriated is determined.

---

---

---

**WATER DISPOSAL**

Indicate any water treatment that is done before or after the water goes through the system.

Liquid sodium sulfite #EG-5308                      Additional water treatment is being  
added at this time for bacteria control. These changes will include post treat

What percentage of the water is discharged and what is the water discharged to?

100% - storm sewer

If water is discharged into a storm sewer indicate the receiving water for the sewer outlet, if known.

Mississippi River

List any discharge authorizations required for the system.

N/A

Indicate any regulated discharge limitations relating to water temperature, quality or quantity.

N/A

#### WATER CONSERVATION

Does the system use variable speed pumps? [ ] Yes [X] No  
Are any load or system controls used to reduce water requirements by reducing the operating load conditions (i.e. load shedding, temperature set points)?

We use modulating valve control to reduce the flow of water to the heat exchanger

List any other measures utilized to reduce water use:

This is a new system and we are just learning how it functions.

What changes can be done to the system to reduce water use?

This will have to be studied.

What alternatives exist for reuse of the discharge water?

Same as above.

Indicate any anticipated future changes in water use and state reasons for projected increases or decreases.

At this time the system is too new to know what our future needs will be.

Please provide us the following information about the person that completed the survey.

Name Pat Gannon

FAX  
372-1570

Title HVAC Tech.

Telephone Number 372-1600 or 1670

Please give the name and phone number of someone that can provide additional information, if different than above.

Contact Person Fred Atkinson, Operations Manager

Telephone Number 372-1226

This survey is to be completed and mailed by September 15, 1989 to:

Department of Natural Resources - Division of Waters  
Attn: Jim Japs  
Geothermal Heating and Cooling Survey  
Box 32, 500 LaFayette Road  
St. Paul, MN 55155-4032

Winnipeg County  
 Minneapolis  
 Township Number: N 3  
 Range Number: E 12  
 Section No.: 1  
 Location: 33. Sixth and Nicollet Mall, Mpls., Minn.  
 Diagram showing a 4x4 grid with dimensions 1 mi. by 1 mi. and a well location marked with a circled 'X' at the intersection of the 3rd row and 3rd column. A north arrow is present.

FORMATION LOG	COLOR	HARDNESS OF FORMATION	FROM	TO
Pitless - Later			0'	12'
Sand and Gravel	Brown		12'	54'
Platteville/Limerock	Gray	Hard	54'	71'
Shale	Gray	Med.	71'	75'
St. Peter Sandrock	Gray	Soft	75'	112'
St. Peter Sandrock	Tan	Med.	112'	241'
Shakopee Limerock	Tan/Pink	Hard	241'	364'
Jordan Sandrock	White	Med.	364'	437'
Jordan Shale & Sandrock	Gray	Med.	437'	461'

Location From Topo  
 29.24.22 ddc

3. PROPERTY OWNER'S NAME: MCC Development, Inc.  
 Minneapolis City Center/Phase II  
 Address: 33 So. Sixth Street  
 Minneapolis, Minnesota 55407

4. WELL DEPTH (Completed) 461' Date of Completion Feb., 1986  
 5.  Cable tool  Reverse  Finned  18" Oug  
 Hydro end  Air  Bored  11"  
 Rotary  Jetted  Power Auger

6. USE:  
 Domestic  Public Supply  Industry  
 Irrigation  Municipal  Commercial  
 Test Well  Air Conditioning

7. CASING:  Black  Threaded  Welded  
 Galv.  Drive Shear? Yes  No  
 30 in. to 42 ft. Weight 118.7 lbs./ft. 29 in. to 112'  
 24 in. to 100 ft. Weight 94.6 lbs./ft. 23 in. to 262'  
 18 in. to 250 ft. Weight 70.6 lbs./ft. 17 in. to 461'  
 8. SCREEN:  Or open hole  
 Make: None from 250 ft. to 461 ft.  
 Type: \_\_\_\_\_ Dia. \_\_\_\_\_  
 Slot/Groove \_\_\_\_\_ Length \_\_\_\_\_  
 Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft. FITTINGS:  
 \_\_\_\_\_ ft. and \_\_\_\_\_ ft.  
 \_\_\_\_\_ ft. and \_\_\_\_\_ ft.

9. STATIC WATER LEVEL: 93 ft.  Above  Below land surface Date Measured: 1/20/86

10. PUMPING LEVEL (below land surface):  
 109' 9" ft. after 3-1/2 hrs. pumping 2250 g.p.m.  
 114' 3" ft. after 21 hrs. pumping 2700 g.p.m.

11. WELL HEAD COMPLETION:  Pitless adapter / Later  Basement offset  At least 12" above grade

12. Well grouted?  Yes  No  Cement  Bestonite  Date: 29-1/2  
 Depth: from 0 to 75 ft. to 75 ft. from 0 to 250 ft. to 250 ft.

13. Nearest source of possible contamination: 25 feet direction Sewer  
 Well disinfected upon completion? Yes  No

14. PUMP - Later  
 Date installed \_\_\_\_\_  
 Not installed  
 Manufacturer's Name \_\_\_\_\_  
 Model Number \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
 Length of drop pipe \_\_\_\_\_ ft. capacity \_\_\_\_\_ g.p.m.  
 Material of drop pipe \_\_\_\_\_  
 Type:  Submersible  L.S. Turbine  Rotating  
 Jet  Centrifugal

15. WATER WELL CONTRACTOR'S CERTIFICATION  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Keys Well Drilling Co. 62012 No.  
 413 N. Lexington Parkway  
 St. Paul, Minnesota 55104  
 Signed: Russell Galvin Date: 2/17/86  
 Authorized Representative  
 President  
 Name of Driller: Russell/Galvin/Horrigan Date: \_\_\_\_\_

16. REMARKS, ILLUSTRATION, SOURCE OF DATA, etc.  
 RECEIVED  
 FEB 20 1986  
 Minn. Dept. of Health  
 GW00  
 MINN. DEPT. OF NATURAL RESOURCES COPY

(97)

**A P P E N D I X**

**HONEYWELL AVIONICS**

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By GER  
Project HONE/WELL Sheet 1 of 1  
Comm. No. 4435.00 Date 1/10/90

SUMMARY

ANNUAL OPERATING COSTS - EXISTING WELL WATER OPERATION.

PUMPING COSTS	\$	31,123
WATER TREATMENT COSTS	\$	22,856
COMPRESSORIZED EQPT, FIG. <u>A1</u>	\$	162,767
LIEBERT UNITS	\$	<u>26,124</u>
TOTAL	\$	<u>242,870</u>

ANNUAL OPERATING COSTS - CONVERSION TO AIR COOLING

PUMPS - MISC

SUPPLY PUMP 40 HP X <sup>1 Nameplate to BHP</sup> .85 X .746 X  $\frac{1}{9}$  X .045 X 3340 = \$ 4236  
 BOOSTER PUMP .33 HP X .85 X .746 X  $\frac{1}{9}$  X .045 X 2736 = \$ 92

PUMPAGE - COOLING TOWERS

$\frac{125}{84} \text{ HP} \times 1.0 \times 1 \times .746 \times \frac{\$ .045}{\text{KW}} \times \frac{3760 \text{ HRS}}{\text{YR}} = \$ 43760 / \text{YR}$

COOLING TOWER FANS (TWO SPEED) 1/2 TIME AT LOW SPEED

$\frac{100}{190} \text{ HP} \times .85 \times 1 \times .746 \times \frac{\$ .045}{\text{KW}} \times 2760 \times .50 = 13,887$   
 $24 \text{ HP} \times .85 \times 1 \times .746 \times \frac{\$ .045}{\text{KW}} \times 2760 \times .50 = 3,333$

CITY WATER + CITY SEWER

SEE FIGURE ATTACHED Pg. B of B = 32,261

WATER TREATMENT = 6,959

COMPRESSORIZED EQPT, FIG. A-2 = 233,412

LIEBERT UNITS (from E2a above) = 49,282

TOTAL ANNUAL COST = \$ 327,157

APPENDIX  
Fig A-1

HONEYWELL AVIONICS  
ANNUAL OPERATING COST OF WELL WATER COOLED COMPRESSORIZED EGPT.  
EFFICIENCIES BASED ON 50 DEG F ENTERING CONDENSER WATER TEMP

ITEM	DESCR	WELL WATER USAGE	COOL TONS	ESTIM. LOAD	ESTIM. EER OR (KW/TON, <1)	HR OPER PER YR	ELEC. \$/KWH	ANNUAL COST
A115	HEAT PUMP	COND	2	0.8	12.6	0	0.045	\$0.00
A111	PKG A/C	COND	5	0.25	10	3744	0.045	\$252.72
A112	PKG A/C	COND	5	0.5	10	4992	0.045	\$673.92
A122	PKG A/C	COND	7.5	0.5	9.7	8736	0.045	\$1,823.75
A105	COND UNIT	COND	75	0.75	0.71	3250	0.045	\$5,840.86
A103	COND UNIT	COND	75	0.75	0.71	8736	0.045	\$15,700.23
A315	FAN COIL U	CW COIL	1	0.5	1	0	0.045	\$0.00
A316	HEAT PUMP	COND	3	0.8	12.3	8736	0.045	\$920.48
VAX ROOM	HEAT PUMP	COND	3	1	12.3	8736	0.045	\$1,150.60
A205	COND UNIT	COND	10	1	0.85	8736	0.045	\$3,341.52
A327	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A307	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A309	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A328	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A321	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A322	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A324	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A318	PKG A/C	COND	7.5	0.25	9.7	4368	0.045	\$455.94
A202	COND UNIT	COND	3	0.5	10	8736	0.045	\$707.62
A204	HEAT PUMP	COND	5	0.8	12.1	8736	0.045	\$1,559.48
A206	FAN COIL	CW COIL	12.5	0.5	1	0	0.045	\$0.00
A317	PKG A/C	COND	15	0.5	9.7	8736	0.045	\$3,647.51
A207	CHILLER-RECP	COND	15	0.66	0.744	8736	0.045	\$2,895.56
A216	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
A218	AHU	CW COIL	15	0.5	1	0	0.045	\$0.00
A219	AHU	CW COIL	15	0.5	1	0	0.045	\$0.00
A211	COND UNIT	COND	100	0.5	0.68	4368	0.045	\$6,683.04
A520	PKG A/C	COND	6	0.25	10	8736	0.045	\$707.62
A521	PKG A/C	COND	6	0.4	10	8736	0.045	\$1,132.19
A201	COND UNIT	COND	3	0.66	10	8736	0.045	\$934.05
A615	CHILLER-RECP	COND	100	0.5	0.791	1680	0.045	\$2,989.98
A621	PKG A/C	COND	15	0.5	9.7	8736	0.045	\$3,647.51
A622	COND UNIT	COND	30	0.5	0.7	8736	0.045	\$4,127.76
A260	COMP RM U	COND	10	1	9.7	8736	0.045	\$4,863.34
A452	FAN COIL	CW COIL	10	0.5	1	0	0.045	\$0.00
A101A	COND UNIT	COND	40	0.75	0.71	2730	0.045	\$2,616.71
A102	COND UNIT	COND	15	0.75	0.71	2730	0.045	\$981.26
A337	MAKE-UP AHU	CW COIL	25	0.5	1	0	0.045	\$0.00
A364	AHU	CW COIL	11.5	0	1	0	0.045	\$0.00
AC02	CHILLER-RECP	COND	75	0	0.786	0	0.045	\$0.00
AC03	CHILLER-RECP	COND	75	0.1	0.786	4368	0.045	\$1,158.72
AC04	CHILLER-CENT	COND	500	0.8	0.382	4368	0.045	\$30,034.37
AC05	CHILLER-CENT	COND	300	1	0.4133	8736	0.045	\$48,742.95
AC06	CHILLER-RECP	COND	130	0.8	0.853	2184	0.045	\$8,718.62
AC08	CHILLER-RECP	COND	100	0.1	0.791	4368	0.045	\$1,554.79
AC09	CHILLER-RECP	COND	100	0.1	0.791	4368	0.045	\$1,554.79
A311	COND UNIT	COND	75	0	0.71	4368	0.045	\$0.00
A305	AHU	CW COIL	30	1	1	0	0.045	\$0.00
A305A	COND UNIT	COND	30	0	0.62	0	0.045	\$0.00
A308	CHILLER-RECP	COND	40	0.6	0.71	4368	0.045	\$3,349.38
A443	AHU	CW COIL	20	1	1	0	0.045	\$0.00
A220	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
A221	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
AC01	CHILLER-RECP	COND	100	0	0.791	0	0.045	\$0.00

TOTAL

\$162,767.25



APPENDIX  
Fig A-2

HONEYWELL AVIONICS  
ANNUAL OPERATING COST COMPRESSORIZED EQPT - COOLING TOWER OPERATION.  
EFFICIENCIES BASED ON 85 / 95 DEG F ENTERING/LEAVING CONDENSER WATER.

ITEM	DESCR	WELL WATER USAGE	COOL TONS	ESTIM. LOAD	ESTIM. EER OR (KW/TON)	HR OPER PER YR	ELEC. \$/KWH	ANNUAL COST
A115	HEAT PUMP	COND	2	0.8	11.7	8736	0.045	\$645.12
A111	PKG A/C	COND	5	0.25	9	3744	0.045	\$280.80
A112	PKG A/C	COND	5	0.5	9	4992	0.045	\$748.80
A122	PKG A/C	COND	7.5	0.5	8.7	8736	0.045	\$2,033.38
A105	COND UNIT	COND	75	0.75	1.07	3250	0.045	\$8,802.42
A103	COND UNIT	COND	75	0.75	1.07	8736	0.045	\$23,660.91
A315	FAN COIL U	CW COIL	1	0.5	1	0	0.045	\$0.00
A316	HEAT PUMP	COND	3	0.8	11.7	8736	0.045	\$967.68
VAX ROOM	HEAT PUMP	COND	3	1	11.7	8736	0.045	\$1,209.60
A205	COND UNIT	COND	10	1	1.09	8736	0.045	\$4,285.01
A327	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A307	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A309	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A328	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A321	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A322	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A324	COMP RM U	CW COIL/COND	20	0.5	1	0	0.045	\$0.00
A318	PKG A/C	COND	7.5	0.25	8.7	4368	0.045	\$508.34
A202	COND UNIT	COND	3	0.5	9	8736	0.045	\$786.24
A204	HEAT PUMP	COND	5	0.8	11.2	8736	0.045	\$1,684.80
A206	FAN COIL	CW COIL	12.5	0.5	1	0	0.045	\$0.00
A317	PKG A/C	COND	15	0.5	8.7	8736	0.045	\$4,066.76
A207	CHILLER-RECP	COND	15	0.66	0.843	8736	0.045	\$3,280.86
A216	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
A218	AHU	CW COIL	15	0.5	1	0	0.045	\$0.00
A219	AHU	CW COIL	15	0.5	1	0	0.045	\$0.00
A211	COND UNIT	COND	100	0.5	1.07	4368	0.045	\$10,515.96
A520	PKG A/C	COND	6	0.25	8.7	8736	0.045	\$813.35
A521	PKG A/C	COND	6	0.4	8.7	8736	0.045	\$1,301.36
A201	COND UNIT	COND	3	0.66	9	8736	0.045	\$1,037.84
A615	CHILLER-RECP	COND	100	0.5	0.891	1680	0.045	\$3,367.98
A621	PKG A/C	COND	15	0.5	6.7	8736	0.045	\$4,066.76
A622	COND UNIT	COND	30	0.5	0.95	8736	0.045	\$5,601.96
A260	COMP RM U	COND	10	1	8.7	8736	0.045	\$5,422.34
A452	FAN COIL	CW COIL	10	0.5	1	0	0.045	\$0.00
A101A	COND UNIT	COND	40	0.75	1.02	2730	0.045	\$3,759.21
A102	COND UNIT	COND	15	0.75	1.07	2730	0.045	\$1,478.81
A337	MAKE-UP AHU	CW COIL	25	0.5	1	0	0.045	\$0.00
A364	AHU	CW COIL	11.5	0	1	0	0.045	\$0.00
AC02	CHILLER-RECP	COND	75	0	0.903	0	0.045	\$0.00
AC03	CHILLER-RECP	COND	75	0.1	0.903	4368	0.045	\$1,331.20
AC04	CHILLER-CENT	COND	500	0.8	0.6152	4368	0.045	\$48,369.48
AC05	CHILLER-CENT	COND	300	1	0.6438	8736	0.045	\$75,927.20
AC06	CHILLER-RECP	COND	130	0.8	0.973	2184	0.045	\$9,945.15
AC08	CHILLER-RECP	COND	100	0.1	0.891	4368	0.045	\$1,751.35
AC09	CHILLER-RECP	COND	100	0.1	0.891	4368	0.045	\$1,751.35
A311	COND UNIT	COND	75	0	1.07	4368	0.045	\$0.00
A305	AHU	CW COIL	30	1	1	0	0.045	\$0.00
A305A	COND UNIT	COND	30	0	0.93	0	0.045	\$0.00
A308	CHILLER-RECP	COND	40	0.6	0.85	4368	0.045	\$4,009.82
A443	AHU	CW COIL	20	1	1	0	0.045	\$0.00
A220	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
A221	AHU	CW COIL	20	0.5	1	0	0.045	\$0.00
AC01	CHILLER-RECP	COND	100	0	0.891	0	0.045	\$0.00

TOTAL \$233,411.85

APPENDIX  
Fig A-3

HONEYWELL AVIONICS  
COOLING TOWER GPM  
CONVERSION TO COOLING TOWERS  
CONDENSING TEMPERATURES 95/95 ENT/LWT DEG F

ITEM	DESCR	WELL WATER USAGE	COOL TONS	ESTIM. LOAD	TOTAL
A115	HEAT PUMP	COND	2	0.8	1.6
A111	PKG A/C	COND	5	0.5	2.5
A112	PKG A/C	COND	5	0.5	2.5
A122	PKG A/C	COND	7.5	0.5	3.75
A105	COND UNIT	COND	75	0.75	56.25
A103	COND UNIT	COND	75	0.75	56.25
A316	HEAT PUMP	COND	3	0.8	2.4
VAX ROOM	HEAT PUMP	COND	3	1	3
A205	COND UNIT	COND	10	1	10
A318	PKG A/C	COND	7.5	0.1	0.75
A202	COND UNIT	COND	3	1	3
A204	HEAT PUMP	COND	5	1	5
A317	PKG A/C	COND	15	1	15
A207	CHILLER-RECP	COND	15	1	15
A211	COND UNIT	COND	100	0.5	50
A520	PKG A/C	COND	6	0.5	3
A521	PKG A/C	COND	6	1	6
A201	COND UNIT	COND	3	1	3
A615	CHILLER-RECP	COND	100	0	0
A621	PKG A/C	COND	15	1	15
A622	COND UNIT	COND	30	0.75	22.5
A260	COMP RM U	COND	10	1	10
A101A	COND UNIT	COND	40	0.75	30
A102	COND UNIT	COND	15	0.75	11.25
AC02	CHILLER-RECP	COND	75	0.25	18.75
AC03	CHILLER-RECP	COND	75	0.25	18.75
AC04	CHILLER-CENT	COND	500	1	500
AC05	CHILLER-CENT	COND	300	1	300
AC06	CHILLER-RECP	COND	130	0.5	65
AC08	CHILLER-RECP	COND	100	0.25	25
AC09	CHILLER-RECP	COND	100	0	0
A311	COND UNIT	COND	75	1	75
A305A	COND UNIT	COND	30	0	0
A308	CHILLER-RECP	COND	40	0.5	20
A306	COND UNIT	COND	0	0	0
AC01	CHILLER-RECP	COND	100	0	0

TOTAL TONS. ADJUSTED 1350.25

NOTE: COND WATER TYPICALLY CONTROLLED WITH TWO-WAY PENN VALVES - TOWER REQMT ABOVE

102

APPENDIX  
A-4

HONEYWELL AVIONICS  
ENVIRONMENTAL WELL WATER USAGE  
MILLION GALLONS PER YEAR

ITEM	DESCR	WELL WATER USAGE	COOL TONS	HEAT REJ FACTOR	ESTIM. LOAD	ESTIM. TD	HR OPER PER YR	TOTAL MBY
A115	HEAT PUMP	COND	2	1.25	0.25	25	8736	0.31
A111	PKG A/C	COND	5	1.25	0.25	25	3744	0.34
A112	PKG A/C	COND	5	1.25	0.25	25	4992	0.45
A122	PKG A/C	COND	7.5	1.25	0.25	25	8736	1.18
A105	COND UNIT	COND	75	1.25	0.3	25	3250	5.27
A103	COND UNIT	COND	75	1.25	0.3	25	3250	5.27
A315	FAN COIL U	CW COIL	1	1	0.25	15	8736	0.21
A316	HEAT PUMP	COND	3	1.25	0.25	25	8736	0.47
VAX ROOM	HEAT PUMP	COND	3	1.25	0.25	25	8736	0.47
A205	COND UNIT	COND	10	1.25	0.3	25	8736	1.89
A327	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A307	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A309	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A328	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A321	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A322	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A324	COMP RM U	CW COIL/COND	20	1.25	0.5	30	8736	5.24
A318	PKG A/C	COND	7.5	1.25	0.1	25	4368	0.24
A202	COND UNIT	COND	3	1.25	0.25	25	8736	0.47
A204	HEAT PUMP	COND	5	1.25	0.25	25	8736	0.79
A206	FAN COIL	CW COIL	12.5	1	0.3	15	3736	3.14
A317	PKG A/C	COND	15	1.25	0.25	25	8736	2.36
A207	CHILLER-RECP	COND	15	1.25	0.1	25	8736	0.94
A216	AHU	CW COIL	20	1	0.3	15	4368	2.52
A218	AHU	CW COIL	15	1	0.3	15	1400	0.60
A219	AHU	CW COIL	15	1	0.3	15	2498	1.08
A211	COND UNIT	COND	100	1.25	0.3	25	4368	9.43
A520	PKG A/C	COND	6	1.25	0.25	25	8736	0.94
A521	PKG A/C	COND	6	1.25	0.25	25	8736	0.94
A201	COND UNIT	COND	3	1.25	0.3	25	8736	0.57
A615	CHILLER-RECP	COND	100	1.25	0.3	25	1680	3.63
A621	PKG A/C	COND	15	1.25	0.25	25	8736	2.36
A622	COND UNIT	COND	30	1.25	0.3	25	8736	5.66
A260	COMP RM U	COND	10	1.25	0.5	25	8736	3.14
A452	FAN COIL	CW COIL	10	1	0.25	15	8736	2.10
A101A	COND UNIT	COND	40	1.25	0.3	25	2730	2.36
A102	COND UNIT	COND	15	1.25	0.3	25	2730	0.88
A337	MAKE-UP AHU	CW COIL	25	1	0.3	15	8736	6.29
A384	AHU	CW COIL	11.5	1	0	15	8736	0.90
AC02	CHILLER-RECP	COND	75	1.25	0	25	0	0.00
AC03	CHILLER-RECP	COND	75	1.25	0.1	20	4368	2.95
AC04	CHILLER-CENT	COND	500	1.25	0.65	25	4368	102.21
AC05	CHILLER-CENT	COND	300	1.25	0.6	25	8736	113.22
AC06	CHILLER-RECP	COND	130	1.25	0.3	25	2184	6.13
AC08	CHILLER-RECP	COND	100	1.25	0.1	25	4368	3.14
AC09	CHILLER-RECP	COND	100	1.25	0.1	25	4368	3.14
A311	COND UNIT	COND	75	1.25	0	25	4368	0.00
A305	AHU	CW COIL	30	1	0.3	15	4368	3.77
A305A	COND UNIT	COND	30	1.25	0	1	0	0.00
A308	CHILLER-RECP	COND	40	1.25	0.25	25	4368	3.14
A306	COND UNIT	COND	0	1.25	0	1	0	0.00
A443	AHU	CW COIL	20	1	0.3	15	4368	2.52
A220	AHU	CW COIL	20	1	0.3	15	1560	0.90
A221	AHU	CW COIL	20	1	0.3	15	3744	2.16
AC01	CHILLER-RECP	COND	100	1.25	0	25	0	0.00

TOTAL 346.28

103

APPENDIX  
A-5

HONEYWELL AVIONICS  
ENVIRONMENTAL WELL WATER USAGE  
TOTAL PEAK CAPACITY  
AND DESIGN BFM

ITEM	DESCR	WELL WATER USAGE	COOL TONS	ESTIM. LOAD	TONS	HR OPER PER YR	ANNUAL TON-HR	ESTIM. TD	GPM
A115	HEAT PUMP	COND	2	0.8	1.6	8736	13977.50	25	1.92
A111	PKG A/C	COND	5	0.5	2.5	3744	9360.00	25	3
A112	PKG A/C	COND	5	0.5	2.5	4992	12480.00	25	3
A122	PKG A/C	COND	7.5	0.5	3.75	8736	32760.00	25	4.5
A105	COND UNIT	COND	75	0.5	37.5	3250	121875.00	25	45
A103	COND UNIT	COND	75	0.5	37.5	8736	327600.00	25	45
A315	FAN COIL U	CW COIL	1	0.5	0.5	8736	4368.00	15	0.8
A316	HEAT PUMP	COND	3	0.8	2.4	8736	20968.40	25	2.88
VAX ROOM	HEAT PUMP	COND	3	1	3	8736	26208.00	25	3.6
A205	COND UNIT	COND	10	1	10	8736	87360.00	25	12
A327	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A307	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A309	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A328	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A321	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A322	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A324	COMP RM U	CW COIL/COND	20	1	20	8736	174720.00	30	16
A318	PKG A/C	COND	7.5	0.5	3.75	4368	16380.00	25	4.5
A202	COND UNIT	COND	3	0.5	1.5	8736	13104.00	25	1.8
A204	HEAT PUMP	COND	5	0.5	2.5	8736	21840.00	25	3
A206	FAN COIL	CW COIL	12.5	0.5	6.25	8736	54600.00	15	10
A317	PKG A/C	COND	15	0.5	7.5	8736	65520.00	25	9
A207	CHILLER-RECP	COND	15	0.66	9.9	8736	86436.40	25	11.38
A216	AHU	CW COIL	20	0.5	10	4368	43680.00	15	16
A218	AHU	CW COIL	15	0.5	7.5	1400	10500.00	15	12
A219	AHU	CW COIL	15	0.5	7.5	2484	18720.00	15	12
A211	COND UNIT	COND	100	0.5	50	4368	218400.00	25	60
A520	PKG A/C	COND	6	0.5	3	8736	26208.00	25	3.6
A521	PKG A/C	COND	6	0.5	3	8736	26208.00	25	3.6
A201	COND UNIT	COND	3	0.66	1.99	8736	17297.28	25	2.376
A615	CHILLER-RECP	COND	100	0.5	50	1680	84000.00	25	60
A621	PKG A/C	COND	15	0.5	7.5	8736	65520.00	25	9
A622	COND UNIT	COND	30	0.5	15	8736	131040.00	25	18
A250	COMP RM U	COND	10	1	10	8736	87360.00	25	12
A452	FAN COIL	CW COIL	10	0.5	5	8736	43680.00	15	8
A101A	COND UNIT	COND	40	0.75	30	2730	81900.00	25	36
A102	COND UNIT	COND	15	0.75	11.25	2730	30712.50	25	13.5
A337	MAKE-UP AHU	CW COIL	25	0.5	12.5	8736	109200.00	15	20
A364	AHU	CW COIL	11.5	0	0	8736	0.00	15	0
AC02	CHILLER-RECP	COND	75	0	0	0	0.00	25	0
AC03	CHILLER-RECP	COND	75	0.1	7.5	4368	32750.00	20	11.25
AC04	CHILLER-CENT	COND	500	1	500	4368	2184000.00	25	600
AC05	CHILLER-CENT	COND	300	1	300	8736	2620800.00	25	360
AC06	CHILLER-RECP	COND	130	0.3	104	2184	227136.00	25	124.8
AC08	CHILLER-RECP	COND	100	0.1	10	4368	43680.00	25	12
AC09	CHILLER-RECP	COND	100	0.1	10	4368	43680.00	25	12
A311	COND UNIT	COND	75	0	0	4368	0.00	25	0
A305	AHU	CW COIL	30	0.5	15	4368	65520.00	15	24
A305A	COND UNIT	COND	30	0	0	0	0.00	1	0
A308	CHILLER-RECP	COND	40	0.6	24	4368	104832.00	25	28.8
A306	COND UNIT	COND	0	0	0	0	0.00	1	0
A443	AHU	CW COIL	20	1	20	4368	87360.00	15	32
A220	AHU	CW COIL	20	0.5	10	1560	15600.00	15	16
A221	AHU	CW COIL	20	0.5	10	3744	37440.00	15	16
AD01	CHILLER-RECP	COND	100	0	0	0	0.00	25	0
							0.00	1	0

TOTAL TONS 1507.38 TOTAL TON-HR 8595159.18 TOTAL 1776.8  
TON-HR/10(6) 8.595

104

Well Water Cooled Comfort/Environmental Equipment

	M	N	O	P	Q	R	S	T	U
78					Est. Total Yearly Well Water Usage (Gal/Yr.)			363,154,420	
79									
80					Total Well Water usage 88-89 (Gal/Yr.)			423,768,000	
81									
82					% Well Water for Comfort/Environmental			86	
83									
84									
85					Total AC04, AC05 & D.F.S Computer rooms			255,462,480	
86									
87					% Of total A/C usage			70	
88									
89					Total of 52 Week loads (Gal/Yr.)			287,518,795	
90									
91					% Of total A/C usage			89	

	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z
	gpm/ton	hrs/ton	lbs. of W	lbs. of Y	Load Factor	Min/hr	Gal/Yr							
1														
2														
3														
4														
5														
6														
7	A172	5	0.7	24	7	0.25	60	262,080						
8														
9	A172	75	0.7	24	7	0.25	60	6,000,000						
10		75	0.7	24	7	0.25	60	6,000,000						
11		75	0.7	24	7	0.3	60	6,000,000						
12														
13		5	2.4	24	7	0.25	60	1,572,480						
14		2	0.7	24	7	0.5	60	366,912						
15		2.5	0.7	24	7	0.5	60	468,640						
16		7.5	0.7	24	7	0.25	60	687,840						
17														
18		20	1.75	24	7	0.5	60	9,172,800						
19		20	1.75	24	7	0.5	60	9,172,800						
20		20	1.75	24	7	0.5	60	9,172,800						
21		20	1.75	24	7	0.5	60	9,172,800						
22		20	1.75	24	7	0.5	60	9,172,800						
23														
24		20	1.75	24	7	0.5	60	9,172,800						
25		20	1.75	24	7	0.5	60	9,172,800						
26		8	0.7	24	7	0.1	60	293,520						
27														
28		5	0.7	24	7	0.3	60	330,240						
29		5	0.7	24	7	0.3	60	330,240						
30		12.5	2.4	24	7	0.3	60	4,717,440						
31		15	0.7	24	7	0.25	60	1,575,920						
32														
33		15	0.7	24	7	0.25	60	375,920						
34		75	2.4	24	7	0.3	60	14,152,320						
35		75	2.4	24	7	0.3	60	4,632,200						
36		75	2.4	24	7	0.3	60	8,687,040						
37		100	0.7	24	7	0.3	60	5,505,600						
38														
39		5	0.7	24	7	0.3	60	550,368						
40		5	0.7	24	7	0.3	60	550,368						
41		5	0.7	24	7	0.3	60	330,240						
42														
43		100	0.7	24	7	0.3	60	1,270,080						
44		100	0.7	24	7	0.3	60	1,651,104						
45		25	0.7	24	7	0.3	60	750,640						
46														
47	A267	1	0.7	24	7	0.5	60	875,840						
48		10	2.4	24	7	0.5	60	3,772,960						
49														
50		40	0.7	12	5	0.3	60	78,240						
51		15	0.7	12	5	0.5	60	29,840						
52														
53		25	2.4	24	7	0.3	60	1,684,800						
54		10	2.4	24	7	0.3	60	54,240						
55														
56		75	0.7				60	0						
57		75	0.7				60	0						
58		50	0.7	24	7	0.25	60	1,151,040						
59		25	0.7	24	7	0.5	60	481,840						
60														
61		30	0.7				60	0						
62		100	0.7				60	0						
63		100	0.7				60	0						
64		75	0.7				60	0						
65														
66		25	2.4	24	7	0.3	60	4,717,440						
67		30	0.7				60	0						
68		40	0.7	24	7	0.3	60	2,260,420						
69		0	0.7				60	0						
70														
71	A443	20	2.5	24	7	0.3	60	1,223,040						
72														
73	A72	75	2.4	16	5	20	0.3	60	5,654,400					
74	A221	75	2.4	24	5	20	0.3	60	11,305,600					
75														
76	A69	100	0.7											
77														

106

10ml Well water  
M6  
31.40  
21.852  
26.487  
21.300  
21.016  
20.550  
26.304  
23.882  
23.772  
21.872  
23.800  
43.126  
423768 M6

HONEYWELL HYDROLOGS - WELL WATER OPERATING COSTS

A) PUMPING COSTS - ANNUAL

NOTE: BASED ON HONEYWELL DATA, ENVIRONMENTAL COOLING ACCOUNTS FOR 85% OF TOTAL PUMPAGE. THE WELL PUMP HORSEPOWER AND TOTAL MGY IS FACTORED BY THIS PERCENTAGE.

WELL PUMP # 1

$$110 \text{ HP} \times .85 \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times \frac{8760}{2} = \$ 12984 \text{ YR}$$

WELL PUMP # 2

$$117 \text{ HP} \times .85 \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times \frac{8760}{2} = \$ 13811 \text{ YR}$$

SUPPLY PUMP

$$40 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times \frac{3343}{2} = 4236 \text{ YR}$$

BOOSTER PUMP

$$.33 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$ .045}{\text{KWH}} \times 8736 = \$ 92$$

TOTAL PUMPAGE COST = \$ 31,123

B) WATER TREATMENT

$$* 346.3 \text{ MGY} \times \frac{\$ 66}{\text{MGY}} = \$ 22,856 \text{ YR}$$

\* BASED ON SPREADSHEET CALCULATION

\*\* BASED ON GENERAL MILLS COST / MG EXPERIENCE



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By \_\_\_\_\_  
Project HONEYWELL Sheet 2 of 8  
Comm. No. \_\_\_\_\_ Date 12/20/89

C) UNIT EFFICIENCIES OF WATER COOLED EQUIPMENT  
IN ORDER TO ESTABLISH ANNUAL OPERATING COST  
THE KW INPUT OF EQUIPMENT IS DESIRED. -  
EER = BTUH/W

TYPE	TONS	MFR	REFERENCE	SOURCE	EER @ 50/75	EER @ 85/95
PKG	5	CARRIER	SW60	FEB, 1989 ARI	10.0	9.0
A/C	7.5		SW90	"	9.7	8.7
UNITS	10		SW120	"	↓	9.7
	15		( )	-		8.7
			* ASSUMED			

TYPE	TONS	MFR	REFERENCE	SOURCE	EER @ 50/75	EER @ 85/95
HEAT PUMP	1.5	CLIMATE	MAGTRIC	"	11.4	10.5
	2	SERIES	814	TA, PERRY & ASSOC	12.6	11.7
	3			-REP	12.3	11.3
	5				12.1	11.2

TYPE	TONS	MFR	REFERENCE	SOURCE	EER @ 50/75	EER @ 85/95
COMPUTER ROOM	20	* LIBERT	FE2406	DATA CENTER SYSTEMS (LIBERT REP)	10.9	8.6
UNITS						

\* NOTE: UNITS OPERATE ON WELL-WATER OR GLYCOL FREE-COOLING, 75% OF TIME, DX OPERATION AT 25% OF ANNUAL OPERATION IS WITH EER AS SHOWN.



C) UNIT EFFICIENCIES CONT'D

CONDENSING UNITS

Existing condensing units are assumed to be 10 to 15 years old. Typical water-cooled condensing units are self-driven. The make and model used for reference are Carrier model SH compressor/O9RH condensers. Compressors operate at 1750 RPM on R-22 refrigerant. kW per ton efficiency is based on the following equation:

$$\text{BHP} \times \frac{.746 \text{ kW}}{\text{HP}} \times \frac{1}{.90 \text{ EFFIC.}} \times \frac{1}{\text{TON}} = \text{kW/TON}$$

CARRIER UNIT	40° SST, 60°/85° CWT			45° SST, 85°/95° CWT			EAP. FACTOR (TONS/TONS)
	TONS	BHP	kW/TON	TONS	BHP	kW/TON	
SF20	8.7	8.9	.85	8.3	10.9	1.09	.95
SF30	14.0	12.0	.71	12.6	16.2	1.07	.90
SF40	18.6	15.9	.71	16.7	21.6	1.07	.90
60/SF60	28.0	23.6	.70	25.1	32.2	1.06	.90
60/O9RH027	29.2	21.7	.62	26.3	29.6	.93	.90
40/O9RH027	44.2	37.6	.71	39.9	49.0	1.02	.90
66/O9RH084	83.2	70.9	.71	73.9	95.5	1.07	.89
86/O9RH027	112.5	92.0	.68	98.6	126.8	1.07	.88

NOTE: SST - saturated suction temperature  
CWT - Condenser Water Temperature  
TONS - Capacity in tons (@ 12000 BTU/H per TON)  
BHP - Brake Horsepower  
kW/TON - Electrical input versus cooling capacity output



C, UNIT EFFICIENCIES CONT'D  
CHILLERS - RECIPROCATING

The existing chillers are assumed to be 10-15 years old. Reciprocating chillers utilize fully hermetic or semi-hermetic compressors, and are water cooled.

Ratings are based on Carrier model 30 HK. Operating conditions are ~~exp~~ extrapolated at 50°F condenser entering water temperature and are based on 44°F leaving chilled water temperature.

50/78° CWT, 44° LCWT			85/95 CWT, 44° LCWT			CAP. FACTOR (TONS/TONS)
TONS	KW	KW/TON	TONS	KW	KW/TON	
16.0	12.5	.744	15.9	13.4	.843	.95
77.2	56.8	.786	68.1	51.5	.903	.94
101.6	80.4	.791	96.7	86.2	.891	.95
136.8	116.8	.853	129.1	125.6	.973	.94

Note: CWT - condenser water temperature  
LCWT - leaving chilled water temperature

CHILLERS - CENTRIFUGAL

The existing centrifugal chillers are open-drive, York model YT. Design conditions of 55°F entering condenser water temperature are based on specifications for the units as installed in 1987. Performance experience indicates condenser <sup>entering</sup> temperatures of 50°F.

The design data has been provided by York International, computer simulation specifically for the units as installed at Honeywell Avionics.

55/71 CWT, 44° LCWT			85/95 CWT, 44° LCWT			CAP. FACTOR
TONS	KW	KW/TON	TONS	KW	KW/TON	
300	124	.4133	292	188	.6438	.973
500	191	.382	447	275	.6152	.894



D) OPERATING COSTS OF EXISTING WELL-WATER COOLED EQUIPMENT.

SEE FIGURE A-1

The following formula was used for calculating operating costs based on EER's for well-water cooled equipment as shown in item (B) above:

$$\text{TONS} \times \text{LOAD} \times \frac{1}{\text{EER}} \times \frac{12,000 \text{ BTUH}}{\text{TON}} \times \frac{\text{KW}}{1000\text{W}} \times \frac{\$.045}{\text{KWH}} \times \frac{\text{HRS}}{\text{YR}} = \frac{\$}{\text{YR}}$$

Where EER = BTUH/WATT

E) OPERATING COSTS OF LIEBERT COMPUTER ROOM UNITS

1) There are seven Liebert units, 20 tons each, which have both a cold water coil and a direct expansion refrigeration coil. 75% of operation is estimated to be under cold water "free cooling" operation. Total operation hours are 8760 HOURS/YR. The "free cooling" mode requires a 7.5 HP fan motor.

FREE COOLING:

$$\frac{7.5 \text{ HP} \times .85}{.9} \times .746 \times \frac{\$.045}{\text{KWH}} \times 8760 \times .75 = \frac{\$ 1562}{\text{YR}}$$

DX MODE @ 10.9 EER:

$$20 \text{ TONS} \times \frac{1}{10.9 \text{ EER}} \times \frac{12,000 \text{ TON}}{\text{BTUH}} \times \frac{\text{KW}}{1000\text{W}} \times \frac{\$.045}{\text{KWH}} \times 8760 \times .25 = \frac{\$ 2170}{\text{YR}}$$

III



COMPUTER ROOM UNITS, CONT'D

TOTAL OPERATING COSTS, 7 UNITS @ 50° WELL WATER:

$$7 \times \frac{\$1562}{\text{YR}} + 7 \times \frac{\$2170}{\text{YR}} = \frac{\$26124}{\text{YR}}$$

2) CONVERSION FROM WELL WATER TO GLYCOL "FREE COOLING"  
DRY COOLERS AT 40% GLYCOL - OPERATING COSTS

The seven Liebert units will require a conversion to dry coolers, roof mounted and air cooled, operating in a free cooling mode on 40% glycol for assumed 75% operation and with direct expansion for 25% of total 8760 hours operation.

In addition, operating costs of condenser fans and glycol pumps must be added in:

a) LIEBERT CO has provided annual operating costs, total at \$1.06/kWH per unit, based on operating experience for Minneapolis, MN area

$$\frac{\$9387}{\text{YR}} \times \frac{0.045}{0.060} \times 7 \text{ UNITS} = \frac{\$49282}{\text{YR}} @ 0.045/\text{kWh}$$

b) (CALCULATED) TOTAL SEVEN UNITS

i) FREE COOLING:  $\$1562/\text{YR} \times 7 = 10934$

ii) DX MODE AT 8.6 EER:

$$20 \text{ TONS} \times \frac{1}{8.6 \text{ EER}} \times \frac{12000 \text{ BT}}{\text{HR}} \times \frac{\text{kWh}}{3412 \text{ BT}} \times \frac{\$0.045}{\text{kWh}} \times 8760 \times 0.25 \times 7 = \frac{\$19252}{\text{YR}}$$

iii) CONDENSOR

$$2.25 \text{ HP} \times \frac{0.75}{0.9} \times 0.746 \times 0.045 \times 8760 \times 7 = \$4374$$

iiii) Glycol Pump  $3 \text{ HP} \times \frac{0.75}{0.9} \times 0.746 \times 0.045 \times 8760 \times 7 = \$5332$

TOTAL OPER COST WITH NEW DRY COOLERS:  $\$40392/\text{YR}$

c) CONCLUSION: USE \$49,282 ANNUAL OPER, CONVERSION TO DRY COOLERS



HONEYWELL: GPM OF COOLING TOWER

SEE FIGURE A-3

$$\text{TONS} = \frac{\text{GPM } \Delta T}{30} \quad ; \quad \text{GPM} = \text{CONDENSOR GPM}$$

$$\Delta T = 10 \text{ DEG F}$$

$$30 = 24 \times 1.25 \text{ HEAT RET. FACTOR}$$

$$\text{GPM} = \text{TONS} \times 30 \times \frac{1}{10} = \text{TONS} \times 3 \quad ; \quad \text{TONS} = 1350 \text{ (FIG A-3)}$$

$$\text{GPM} = 1350 \times 3 = 4050 \text{ GPM}$$

TOWER PUMP SELECTION

BELL & GOSSET SERIES VSCS 12x14x12 @ 1750 RPM

ASSUME: 100' HEAD

125 BHP, 84% EFFIC.

PUMPING COST

TOWER PUMP

$$125 \times \frac{1}{34} \times 740 \times 1.15 \times 1.16 \times 43760$$

SUPPLY PUMP

$$40 \text{ HP} \times 1.746 \times .85 \times \frac{1}{9} \times 1.045 \times 3340 = 4236$$

BOOSTER PUMP

$$33 \text{ HP} \times 1.746 \times .85 \times \frac{1}{9} \times 1.045 \times 18736 = 92$$

$$43283$$

(113)



HONEYWELL

TOWER - ANNUAL OPER. COST

TOWER MAKE-UP = EVAP + BLOWDOWN

SEWER COSTS = BLOWDOWN ONLY

ASSUMED \$114 / 1000 GAL CITY W  
1.83 / 1000 SEWER

EVAP + BLOWDOWN

EVAP GPM SYSTEM : BETZ CO. CALCULATOR

EVAP + BLOWDOWN = 40.5

20.5

61.0 GPM

OPER HRS = 8760

PL HRS = ~2000

SUM = 5380 USE 5000 HRS

61 GAL x 60 M x 5000 x \$1.14 / 1000 = \$20,865

BLOWDOWN (SEWER)

20.5 GAL x 60 x 5000 x \$1.83 / 1000 = 11,396

TOTAL MW & SEWER = \$32,261

(114)

TOWER - FIRST COSTS

A) CONDENSER-SIDE CHANGES

CHILLERS	66,000	} 282,000	- GEAR & VESSEL CHG'S ON YORK JT ONLY
TOWER	70,000		
PIPE/INSUL	202,018		
PUMP	9,990		

INSIAL 282,000

SUBTOTAL 630,016

CONTINGENCY X 1.30 = 819,020

\$ 1,449,036

B) CHILLED WATER-SIDE CHANGES

ADDITIONAL FIRST COST FOR CONVERSION OF WELL WATER TO CHILLED WATER -

A) CHILLERS - REPLACE RECIPROCATING CHILLERS. EXISTING UNITS AT END OF SERVICE LIFE

B) PIPING & INSUL

ESTIM COST \$ 2,500,000

C) TOTAL FIRST COSTS =  $\Sigma$  A + B

(115)



CONVERSION FIRST COSTS

A) A/C EQPT FIRST COSTS - CHANGES

1) CENTRIFUGAL CHANGES - YORK YT  
GEARS 25,000 x 2 = \$50,000

CONDENSER VESSELS = 16,000  
8,000 x 2

2) RECIPROCATING CHANGES \$ 66,000  
ADD MACHINES TO SUPPLEMENT

B) ADD TOWERS

\$ 69,996 -

C) ADD PIPING & INSULATION - CONDENSER SIDE ONLY

50' - 1 1/2"	x 102.15	\$ 5108
400' - 2"	x 87.95	35180
1800' @ 10"	72.35	130,230
450' @ 6"	42.30	19,035

450' 100' INS = 300 GPM 4" \$ 27.70 12,465

\$ 202,018

D) PUMPS

125 3H = 150 HP

\$ 9990

(116)





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

# PIPE & INSUL

Client MDNR By \_\_\_\_\_  
Project HONEYWELL Sheet 3 of 3  
Comm. No. 4485.00 Date \_\_\_\_\_

SCHED 40	PIPE	MEANS 1989	- WELDED	TOTAL
2 1/2"	\$ 15.05/FT	+	INSUL \$ 4.97 = FIBERGLASS W/ JACKET	\$ 20.02/LF
4"	\$ 21		1917R \$ 6.70	\$ 27.70
6"	\$ 34		\$ 8.30	\$ 42.30
8"	\$ 45		10.80	\$ 55.80
10"	60		12.35	72.35
12"	74		13.95	87.95
14"	87		15.15	102.15

HONEYWELL

# Honeywell

FEB 01 1990

Date	By	Name	Initials
9/15	GER		

January 30, 1990

Orr Schelen Mayeron & Associates  
 Attn: George Rothenberger  
 2021 East Hennepin Ave  
 Minneapolis, MN 55413

Re: Well Water/Cooling Coil Conversion Costs

Dear Mr. Rothenberger:

Our estimated cost for conversion of the Cooling Coils in the Stinson/Ridgway Facility, presently being served directly by well water, is \$2,000,000 - \$3,000,000. This is based somewhat on the \$1,400,000 you estimated for conversion of the chillers to a cooling tower and rough guessing - likely additional chiller capacity will be required (existing Recip. units are for stand-by/peaking and generally not in excellent condition), plus there may be many unknowns.

Sincerely,



Paul S. Binek  
 Manager Facility Services  
 Honeywell, Inc  
 1433 Stinson Blvd MN17-1510  
 Minneapolis, MN 55413  
 (612) 378-4838

**YORK**

LEADER IN NEW TECHNOLOGY  
FOR AIR CONDITIONING

Applied Systems  
York International Corporation  
4800 Mustang Circle  
New Brighton, MN 55112  
Telephone Sales (612) 780-4000  
Telephone Service (612) 780-4446  
FAX (612) 780-0643

**TWIN CITIES SALES & SERVICE**  
**FACTSIMILE TRANSMITTAL**

TO: OSM DATE: 12/21/89  
ATTN: GEORGE ROTHENBERGER NO. OF PAGES: \_\_\_\_\_  
FAX NUMBER: 331-3806 FROM: Jim POZATH  
SUBJECT: DNR STUDY - HONEYWELL STINSON

MESSAGE: George,

ORIGINAL CONDITIONS

TOWER CONDITIONS

MODEL	4TD3D3C1-C1D0	SAME
GEAR	KS	KW
EVAP.	56/44, 600 GPM	55.6/44, 600 GPM
COND	55/71, GPM, 3PASS	85/94.18, 900 GPM, 2 PA
TONS	300	292
KW	124	188

MODEL	4TH3J3E1-CND0	SAME
GEAR	HN	HV
EVAP	56/44, 1000 GPM	55.60/44, 1000 GPM
COND	55/72.8, GPM, 3PASS	85/93.4, 1500 GPM, 2 P
TONS	500	447
KW	191	275

- THE 300 TON UNIT WILL NEED A GEAR CHANGE AND THE CONDOR CONVERTED FROM 3PASS TO 2 PASS

- THE 500 TON UNIT WILL BE THE SAME CHANGES AS ABOVE

\* GEAR CHANGE BUDGET PRICE = \$25,000 EACH  
PASS ARRANGEMENT BUDGET PRICE = \$18,000 EACH

(119)

J-

OFFICE \_\_\_\_\_ MADE BY DalcoSchmalz CHECKED BY \_\_\_\_\_ DATE 12-22-89

GPM 4584  
 HW 95  
 CW 85 10 °R  
 WB 78 7 °A  
 WIND MPH \_\_\_\_\_  
 S. MANUAL \_\_\_\_\_

QUOTATION: FORMAL  LETTER  VERBAL  WORK SHEET  
 COPIES TO: K.C. \_\_\_\_\_  
 PARTY QUOTED George Rothberger  
 ADDRESS \_\_\_\_\_  
 JOB Honewell Avionics 1528 tons  
 ADDRESS \_\_\_\_\_  
 ENG'D BY O.S.M.

EQUIPMENT TO SERVE \_\_\_\_\_

NOTE BELOW - SALES COMMENTS - KEY MEN - TITLES - ADDRESSES - ETC.  
 SHOW TOWER ORIENTATION IF LOCATED WITHIN ENCLOSURE

1-1968

2293 Gpm. 2-Cells

NC 932 -	28700	57,400
HC Valve	590	1180
Basin Covers	370	740
Lubelincs	310	620
Motor Out of Air stream	1300	2600
M-1 Vibration Sw.	130	260
Hand Rail & Ladder		920
		<u>63,730</u>
Freight	1403	<u>2806</u>
		<u>66,536.</u>

Add For 2- 50 HP 2 Speed 1 Winding High Efficiency Motors, \$3460.<sup>00</sup>

TOTAL 69996

32,510 lbs Ship wt.  
 72,680 lbs Operating

**Summary**

The energy cost of 1 FE 240G (60Hz) units for one year is \$9,387 <sup>20 TONS</sup>

Breakdown of these energy costs is as follows:

*Free Cooling*

Coop Fan Motor(s) .....	2,936 *
Compressor(s) .....	3,115 *
Humidifier(s) .....	1,281
Reheat(s) .....	0
Drycooler(s) .....	881
Glycol Pump(s) .....	1,174
<b>Total .....</b>	<b>\$9,387 @ <math>\frac{.06}{kWh}</math></b>

**Design Criteria for this analysis:**

Location: Minneapolis, Minnesota	
Room Drybulb .....	72 F
Room Relative Humidity .....	50 %
Design Ambient .....	95 F
Total Load @ Design Ambient	170000 BTUH
Sensible Load @ Design Ambient	170000 BTUH

**Unit Data:**

Model .....	FE 240G (60Hz)
Air Flow / Unit .....	10200 CFM
Main Fan Motor .....	7.50 HP $\triangle$ FREE COOLING
Number of Units .....	1
Quantity of Compressors .....	2
Compressor KW .....	(Note 1)
Humidifier Capacity .....	22.1 lb/hr
Humidifier KW .....	9.6
Reheat KW .....	30.0
Glycol Pump Motor .....	3.00 HP
Drycooler Fan Motor .....	2.25 HP

**Notes:**

- 1) Compressor KW as well as unit capacity varies with ambient conditions.

These ratios reflect the opinion of Liebert Corporation engineers based on available published catalog information.

(121)

Summary

The energy cost of 1 FH 267W (60Hz) units for one year is \$12,722

Breakdown of these energy costs is as follows:

*Water cooled  
 DX only*

Vap Fan Motor(s) .....	<del>1,487</del> <i>2,136<sup>00</sup></i>
Compressor(s) .....	6,528
Humidifier(s) .....	4,237
Heat(s) .....	0
-----	
Total .....	\$12,722 <i>0.06 KWH</i>

Design criteria for this analysis:

Location: Minneapolis, Minnesota	
Room Drybulb .....	72 F
Room Relative Humidity .....	50 %
Design Ambient .....	95 F
Total Load @ Design Ambient ..	170000 BTUH
Sensible Load @ Design Ambient	170000 BTUH

Unit Data:

Model .....	FH 267W (60Hz)
Air Flow / Unit .....	10200 CFM
Main Fan Motor .....	5.00 HP
Number of Units .....	1
Quantity of Compressors .....	2
Compressor KW .....	(Note 1)
Humidifier Capacity .....	22.1 lb/hr
Humidifier KW .....	9.6
Heat KW .....	30.0

Notes:

- 1) Compressor KW as well as unit capacity varies with ambient conditions.

These ratios reflect the opinion of Liebert Corporation engineers based on available published catalog information.

*122*

NOTE:

I noticed other Liebert units on the Equipment Schedule.

THE LieBERT Fan coil will need to be piped to a chilled (if not already) or replaced with a DX unit.

I did not know if this was important to note but I did anyway!

**GEOHERMAL HEATING AND COOLING SURVEY**

DEC 3 1975

PERMIT NUMBER 75-6231

ORR-SCHELEN-MAYHEW  
& ASSOCIATES, INC.  
MINNEAPOLIS

PERMITTEE Honeywell Military Avionics Division

SYSTEM LOCATION 1433 Stinson Blvd Minneapolis, MN 55413

**NAMES AND LOCATIONS OF FACILITIES:**

Same As Above

TOTAL AREA SERVICED: 525,000 Square feet consisting of 8 separately constructed and joined buildings over a period of 20 years. All HVAC/ water supply systems being installed/modified/joined together during the 40 years of existence of the facility as continuous manufacturing change. **WATER SOURCE**  
Number of wells connected to the system 2 have dictated.

Enclosed is the well information we have on file regarding this installation. Please indicate if this data is accurate and/or submit any additional well data that is available. If no information is enclosed or available, please complete the enclosed Water Well Information form(s).

Are water level measurements taken on the production well(s) or observation well(s)?  Yes  No If yes, please submit a summary of the data.

**SYSTEM INFORMATION**

Number of years since original system was installed: 40 years.  
systems were

Date ~~system was~~ put on line: 1950's/ '60's/ '70's/ '80's

Is this a once through or closed loop system (describe and attach a simple schematic drawing) ?

The well and its associated water piping system is a complex system serving: 1) environmental/comfort cooling system heat rejection, 2) Process equipment heat rejection. 3) Non potable plumbing system water (Water closet, urinals, Bldg Maintenance, etc.) 4) Lawn Irrigation system water. 5. Fire sprinkler system backup. 6) Closed loop heating and cooling system water makeup. The well water distribution system incorporates both "once thru" and multiple or "series" use of the water. It also serves as make-up for closed loop heating & cooling systems.

(124)



**Describe any major system modifications and give the completion date:**

The well water distribution system is a dynamic system to which modifications are made due to process, economic and legislative requirements on a continuing basis.

**Average water temperature:** Overall system; 50 degrees intake to equipment - 55 degrees discharge to storm sewer  
Heating \_\_\_\_\_ intake; \_\_\_\_\_ discharge  
Cooling \_\_\_\_\_ intake; \_\_\_\_\_ discharge

**System size rating:** Facility is made up of numerous systems (55) of all type and usage with actual operating conditions/specifications unavailable.  
Heating \_\_\_\_\_ (BTU/H) Cooling \_\_\_\_\_ (Tons/H)

**Actual peak load:**

Heating \_\_\_\_\_ (BTU) Cooling \_\_\_\_\_ (Tons)

**Energy efficiency of systems:**

Number of chillers/heat pumps in system \_\_\_\_\_ 44  
Coefficient of Performance (COP) for heat pump \_\_\_\_\_  
Average Energy Efficiency Ratio (EER) for heat pump \_\_\_\_\_  
If no heat pump, chiller efficiency rating \_\_\_\_\_  
Number of chillers or heat pumps in system \_\_\_\_\_  
Size rating of chillers/heat pumps \_\_\_\_\_

**General Water Use Efficiency:**

Average Efficiency of Water Use \_\_\_\_\_ (gal/ton) cooling  
\_\_\_\_\_ (gal/BTU) heating  
How much water is recirculated? \_\_\_\_\_  
How much water is lost in the system, where is it lost and how is the amount of water loss determined?  
\_\_\_\_\_  
\_\_\_\_\_

If cooling towers are part of the system, how many are there, how much evaporative loss occurs in this loop, and how is the amount of water loss determined?

Two cooling towers are utilized in one of the systems.  
Loss unknown

(125)

What is the design capacity of the towers? 165 ton  
If cooling towers are not present in the system please describe the feasibility of adding towers including any site and/or system limitations.

1) Adding towers will require extensive building structural work in most areas. 2) Conversion to towers will likely reduce manysystems capacity below required. Only the latest two chiller systems installations have been designed for future conversion to cooling towers.

7.12  
m -

### WATER USAGE

Indicate the percentage of all primary and secondary uses of the water: N/A

Heating       Air conditioning  
 Processing       Other: Plumbing/Bldg Maintenance/

Average pumpage: 700 gpm; 24 hours/day; 12 months/year  
Lawn Irrigation

Are flow meters used to determine water usage? []Yes [ ]No

If meters are not used, describe how the amount of water appropriated is determined.

N/A

### WATER DISPOSAL

Indicate any water treatment that is done before or after the water goes through the system.

Chlorination at wells

What percentage of the water is discharged and what is the water discharged to?

100% discharged to storm sewer, sanitary sewer, to lawn for irrigation, to ambient air (evaporation and ~~two~~ cooling towers)  
3

(126)

If water is discharged into a storm sewer indicate the receiving water for the sewer outlet, if known.

To City of Minneapolis Storm & Sanitary Sewer system. Receiving water unknown.

List any discharge authorizations required for the system.

NPDES permit non contact cooling water (MN0042641)

DNR Water Permit (268mm gal/yr)

Indicate any regulated discharge limitations relating to water temperature, quality or quantity.

1MM gal/day, 85 degrees F. 2mg/liter total residual chlorine, 6.0 to 9.0 ph

WATER CONSERVATION

Does the system use variable speed pumps? [ ] Yes [X] No Are any load or system controls used to reduce water requirements by reducing the operating load conditions (i.e. load shedding, temperature set points)?

A Honeywell Delta 1000 Energy Control System is used to control load conditions.

List any other measures utilized to reduce water use:

- Multiple series use and cooling tower (1 system)
- Reduced individual "chiller systems" by "Looping" units together to increase efficiency and convert reciprocating units to centrifugal units

What changes can be done to the system to reduce water use?

- 1) Install cooling towers on other systems. Install additional chiller cold water loops w/additional chiller capacity.

What alternatives exist for reuse of the discharge water?

Limited reuse alternatives available.

127

Indicate any anticipated future changes in water use and state reasons for projected increases or decreases.

Limited increase due to increase production plans - increased A/C needs expected to be supplied via chiller/cooling tower systems.

Please provide us the following information about the person that completed the survey.

Name Paul Binek

Title Manager Facility Services

Telephone Number 378-4838

Please give the name and phone number of someone that can provide additional information, if different than above.

Contact Person Clark Nelson

Telephone Number 378-4127

**This survey is to be completed and mailed by September 15, 1989 to:**

Department of Natural Resources - Division of Waters  
Attn: Jim Japs  
Geothermal Heating and Cooling Survey  
Box 32, 500 LaFayette Road  
St. Paul, MN 55155-4032



**A P P E N D I X**

**METHODIST HOSPITAL**



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 2  
Comm. No. 4485 Date 2/90

METHODIST HOSPITAL  
— SUMMARY —

ANNUAL OPERATING COSTS

A) EXISTING

PUMPING	53,501
CHILLERS	126,658
WATER TREATMENT	24,145
TOTAL	204,304

B) CONVERSION

PUMPING	16,156
CHILLERS TOWER	120,919 *
WATER TREATMENT	4,948
WATER MAKEUP & SEWER	5,285
	12,809
	160,072

\* CHILLERS CONVERTED FROM .93 & .91 KW/TON TO .72 and .74 KW/TON FOR 650 & 325 TON MACHINES, RESPECTIVELY. RESULTANT ANNUAL OPER COST IS DECREASED.



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 2 of 2  
Comm. No. 4435 Date 2/90

METHODIST  
TON-HOUR CALCULATIONS

A) EXISTING DESIGN

CHILLER #	TONS	LOAD*	HRS OPERATION*	TON HOURS
1	650	.95	3500	2161250
2	325	.90	3000	877500
3				
4				
5				
6				
COILS	488	.50	3000	732000

TOTAL TON HOURS 3,770,750

B) CONVERSION

CHILLER #	TONS	LOAD	HRS OPER	TON HOURS
1				SAME
2				
3				
4				
5				
6				
COILS				

TOTAL TON HR SAME

(131)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GJR  
Project METHODIST HOSPITAL Sheet 1 of 1  
Comm. No. 4485 Date \_\_\_\_\_

A) METHODIST PEAK DAY LOAD

CHILLER # 1 610 TONS

PEAK TONS

= 610

CHILLER # 2 293 TONS

= 293

WELL WATER

S-1  
S-2 } 607 GPM  
S-3 }

S-7  
S-8 } 800 GPM  
S-12 }

$\times \frac{8.33}{24} = 488$  TONS  $\times 1.5$  BLDG DIVERSITY = 244  
(BLDG NUMBER SHUTS DOWN,  
NO JULY 5 "PULL DOWN" REQ'D)

TOTAL 1147

B) PEAK GPM @ DESIGN PEAK DAY LOAD

TONS =  $\frac{\text{GPM} \Delta T}{24}$  (WELL WATER) OR TONS =  $\frac{\text{GPM} \Delta T}{24 \times 1.25}$  (COMPR. HEAT REJECT)

$$\frac{610 \times 30}{10} = 1830$$

$$\frac{293 \times 30}{10} = 879$$

$$\frac{244 \times 24}{8.33} = 703$$

TOTAL 3412 GPM

C) GPM/TON - DESIGN "PEAK DAY"

$$\frac{3412}{1147} = 2.9747 \text{ GPM/T}$$

(32)

© 2004 OSM, Inc. All rights reserved. OSM-100





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 2  
Comm. No. \_\_\_\_\_ Date 12/11/89

METHODIST HOSPITAL - WELL WATER OPERATING COSTS

A) ANNUAL PUMPING COSTS

WELL PUMP

$$125 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$.045}{\text{KWH}} \times 3500 \text{ HRS} = \frac{\$13,870}{\text{YR}}$$

BOOSTER PUMPS - WELL WATER SUPPLY - TWO (2)

$$75 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$.045}{\text{KWH}} \times 3500 \text{ HRS} \times 2 = \frac{\$16,645}{\text{YR}}$$

CHECK: BOOSTER PUMPS; HEAD IS KNOWN

$$\left( \frac{820 \text{ GPM} \times 240 \text{ HD}}{5300 \times .8 \times .9} \right) \times \frac{\$.045}{\text{KWH}} \times 3500 \text{ HRS} \times 2 = \frac{\$16,245}{\text{YR}}$$

USE:

$$\boxed{\frac{\$16,645}{\text{YR}}}$$

CONDENSER WATER PUMP - CHILLER #1

$$40 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$.045}{\text{KWH}} \times 3500 \text{ HR} = \frac{\$4,439}{\text{YR}}$$

CONDENSER WATER PUMP - CHILLER #2

$$20 \text{ HP} \times .746 \times .85 \times \frac{1}{.90} \times \frac{\$.045}{\text{KWH}} \times 3000 \text{ HR} = \frac{\$1,902}{\text{YR}}$$

PUMPS TOTAL 53,501

B) ANNUAL EQUIPMENT OPERATING COSTS

CHILLER #1

$$605.9 \text{ kW} \times .75 \text{ LOAD} \times 3500 \text{ HR} \times \frac{\$.045}{\text{KWH}} = \frac{\$90,658}{\text{YR}}$$

(133)

CONTINUED



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By \_\_\_\_\_  
Project METHODIST HOSP Sheet 2 of 2  
Comm. No. \_\_\_\_\_ Date 12/11/39

CHILLER #2

$$296.3 \text{ KW} \times .90 \text{ LOAD} \times 3000 \text{ HRS} \times \frac{\$ .045}{\text{KWH}} = \frac{\$ 36,000}{\text{YR}}$$

CHILLERS TOTAL 126,658

c) WATER TREATMENT

PER METHODIST HOSPITAL:

\$ 24,145  
YR

(134)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MPNR By \_\_\_\_\_  
Project METHUEN ST. HOV Sheet 1 of 5  
Comm. No. \_\_\_\_\_ Date 1/3/90

CONVERSION - TOWER OPER COST - ANNUAL

DATA FROM CARRIER 1/3/90

CHILLER #1

$$\frac{\$ .045}{\text{KWH}} \times 650 \text{ T} \times \frac{722 \text{ KW}}{\text{TON}} \times .95 \text{ LOAD} \times 3500 \text{ HR} = 70219$$

CHILLER #2

$$\frac{\$ .045}{\text{KWH}} \times 325 \text{ T} \times \frac{7385}{\text{TON}} \times .90 \times 3000 = 29162$$

CHILLER #3

WAS WELL WATER - ADD CHILLER  
244 TONS

$$244 \times \frac{654 \text{ KW}}{\text{TON}} \times .045 \times 3000 = 21,538$$

TOTAL CHILLERS \$120,919

(135)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By \_\_\_\_\_  
Project METHODIST HOSP Sheet 2 of 5  
Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

ANNUAL OPER - TOWER  
GPM = 1147 x 3 = 3441 GPM

PUMP SELECTION

BELL & GOSSET  
SERIES VSCS 10X12X13  
100 HD 1750 RPM

110 BHP, 80% PUMP EFFIC

PUMP COST - ANNUAL

$$110 \text{ BHP} \times 746 \times \frac{1}{.80} \times \frac{.045}{\text{KWH}} \times 3500 = \$ 16,156$$

COND PUMPS = 0 - TOWER P ABOVE = 0  
\$ 16,156

(136)



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413  
612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client

MANKATO  
METHODIST

By

Project

Sheet

3 of 5

Comm. No.

Date

TOWER FANS — ANNUAL OPER

3441 GPM

HIGH SPD 80 HP  $\times .8 \times .746 \times \frac{1}{.95} \times .045 \times 1750 = 3958$  KWH

LOW SPD 20 HP  $\times .8 \times .746 \times \frac{1}{.95} \times .045 \times 1750 = 990$  KWH

TOTAL \$ 4948

(137)

METHODIST

Client \_\_\_\_\_ By \_\_\_\_\_  
 Project \_\_\_\_\_ Sheet 4 of 5  
 Comm. No. \_\_\_\_\_ Date \_\_\_\_\_

ANNUAL OPER COST -  
 TOWER MAKEUP = EVAP + BLOWDOWN  
 SEWER COSTS = BLOW-DOWN ONLY

② ASSUMED \$1.14 / 1000 GAL

WHERE TOWER OPER HRS = AVERAGE OF:  

$$\frac{\text{FULL LOAD HRS} + \text{TOTAL OPER HOURS}}{2}$$

EVAP + BLOW-DN

Methodist @ 1147 tons x 3 = 3441 GPM system

USE 3864 GPM data

EVAP = 38.6 GPM

Blowdn =  $\frac{19.4}{58.0}$  GPM

NOTE: THIS IS A HOSPITAL  
 AND TOWER OPER HOURS  
~~WERE~~ WERE CALCULATED  
 TO BE AVG OF TOTAL  
 OPER HRS and  
 EQUIP FULL LOAD

HRS TOTAL OPER = 3000 } 2100 HRS  
 FL H = 1200 }

$$58 \times \frac{60 \text{M}}{\text{H}} \times 2100 \times \frac{1.14}{1000} = \$8331 \text{ water}$$

BLOW DN

$$19.4 \times 60 \times 2100 \times \frac{1.83}{1000} = 4473 \text{ sewer}$$
  
 TTL \$12804

138

TOTAL  $\frac{40}{1000} +$   
 blowdown  
 sewer



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client DNR By \_\_\_\_\_  
Project METHODIST Sheet 5 of 5  
Comm. No. 4485 Date \_\_\_\_\_

WATER TREATMENT

\$ 5265

SEE WATER TREATMENT CALC SHEET

139



Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MDNR By GER  
Project WATER USE STUDY Sheet 1 of 2  
Comm. No. 4485.00 Date \_\_\_\_\_

METHODIST HOSPITAL

CONVERSION FIRST COSTS

CHILLERS - COND VESSELS & IMPELLERS	\$ 52,000
TOWER	68,116
PUMP - TWR WATER	9,010
PIPE - COND SIDE	27,000
INSTALLATION	104,126
30% CONTINGENCY	78,076
TOTAL	\$ 338,328

(140)





Orr  
Schelen  
Mayeron &  
Associates, Inc.

2021 East Hennepin Avenue  
Minneapolis, MN 55413

612-331-8660  
FAX 331-3806

Engineers  
Surveyors  
Planners

Client MORR By GER  
Project METHODIST Sheet 2 of 2  
Comm. No. 4485.00 Date \_\_\_\_\_

CONVERSION FIRST COSTS

A) A/C EQPT FIRST COSTS - CHANGES

1) CENTRIFUGAL CHANGES - CARRIER  
~~650 TON~~ IMPPELLER - DUAL IMPPELLERS \$ 17,000  
 325 TON MACHINE - IMPPELLER OR 0  
 CONDENSER VESSELS: BOTH UNITS  
 FIELD CHANGE - NEW TUBE BUNDLES = 35,000

2) RECIPROCATING CHANGES  
 ADD MACHINES TO SUPPLEMENT \$ 52,000

B) ADD TOWERS

\$ 68,116

C) ADD PIPING & INSULATION

2750 GPM = 10" PIPE

250' x 72.35 = 18088

150' 15580 = 8370

23458

10 BHP  
 D) PUMPS 125 HP

9010

141

OFFICE Gorham Co. MADE BY Dale Schmalz CHECKED BY \_\_\_\_\_ DATE 12-22-89

GPM 2790  
HW 95  
CW 85 10 °R  
WB 77.8 7.2 °A  
WIND MPH \_\_\_\_\_  
S. MANUAL \_\_\_\_\_

QUOTATION: FORMAL  LETTER  VERBAL  WORK SHEET  
COPIES TO: K.C., \_\_\_\_\_  
PARTY QUOTED George Rathenberger  
ADDRESS \_\_\_\_\_  
JOB Methodist Hospital 930 Tons  
ADDRESS \_\_\_\_\_  
ENG'D BY OSM

EQUIPMENT TO SERVE \_\_\_\_\_

NOTE BELOW SALES COMMENTS - KEY MEN - TITLES - ADDRESSES - ETC.  
SHOW TOWER ORIENTATION IF LOCATED WITHIN ENCLOSURE

1968

Used  
95-85-77.8 WB.

NC 941-	30,730
HC Valves	590
Basin Covers	370
Lube Lines	310
motor outlet Airstream	1300
M-1 Vibration Sw.	130
Hand Rail & Ladder	840
	<u>34,270</u>
Freight	<u>1403</u>
	<u>35673.</u>

SEE  
CROSSING  
MAY 2, 1989  
TOWER

Add For 1-60 HP. 2 Speed 1 Winding High Efficiency motor.  
2460.00

TOTAL 39133

17,395 ship wt  
39,420 operating wt.

142

SUPPLEMENTAL INFORMATION TO:  
GEOTHERMAL HEATING AND COOLING SURVEY

NOV 27

November 2, 1989

Permit Number 85-6010 Methodist Hospital  
6500 Excelsior Blvd.  
St. Louis Park, MN 55426

1. Well Pump: Variable Speed [] yes [ ] no  
HP 125 GPM 1650 (MAX) KW Input 124.50  
Efficiency Rating \_\_\_\_\_ (if known)  
Average Operation Hours per year 3500

2. Chillers:  
Chiller #1 *CARRIER*  
Capacity 650 Tons *97%* KW Input 605.9  
Peak Load 630 Tons Average Hours/Year 3500

Condenser Water

Temperature Entering 62  
Temperature Leaving 72  
GPM 1950

*= FULL LOAD  
650 TONS  
@ 1.25 HP/T*

Chiller #2 *CARRIER*  
Capacity 325 Tons *LOAD 92.3%* KW Input 296.3  
Peak Load 300 Tons Average Hours/Year 3000

Condenser Water

Temperature Entering 62  
Temperature Leaving 72  
GPM 900

*= 12% LOAD  
300 TONS*

*932 w/t*

*USE  
95% LDR*

*= 9117 KW TONS*

*USE!  
ASSUMED  
90% LDR*

Chiller #3

Capacity 650 Tons

KW Input 425

Peak Load 630 Tons

Average Hours/Year 3000

Condenser Water

Temperature Entering 72

Temperature Leaving 82

GPM 1875

3. Cooling Tower:

Pump HP 60

GPM 1875

KW Input 60.6

Hours per Year Operated 3000

Fan Motor HP 50

KW Input 47.3

Which Chiller Number (above) is this used with? 3

4. On the drawing you submitted, please indicate for the pumps shown, KW input or efficiency.

5. Please verify that AHU S-1, 2, 3, 7, & 8, are the only units with well water cooling coils. Please indicate whether these are precooling coils or primary cooling. List the entering and leaving water temperatures or the change in temperature for the well water coils:

	<u>In</u>	<u>Out</u>	<u>Change</u>
S - 1	<u>51</u>	<u>58</u>	<u>7</u>
S - 2	<u>51</u>	<u>60</u>	<u>9</u> 8.33 AT
S - 3	<u>51</u>	<u>60</u>	<u>9</u> /
S - 7	<u>51</u>	<u>57</u>	<u>7</u>
S - 8	<u>51</u>	<u>60</u>	<u>9</u> 8.33
S - 12	<u>51</u>	<u>60</u>	<u>9</u> /

6. Water treatment costs: \$ 24,145.00

Ques. 5: 6 units as listed use well water only for primary cooling. We have no precooling.

(144)




FIGURE 2

FLOW DIAGRAM  
 EXISTING CHILLED WATER SYSTEM  
 -EQUIPMENT ROOM AREA

145

# Methodist Hospital

SEPT 06 89

07:11


5 September 1989

Mr. James Japs  
Water Appropriation Program Coordinator  
Department of Natural Resources  
500 Lafayette Road  
St. Paul, MN 55155

Dear Mr. Japs:

Please find enclosed the completed Geothermal Heating and Cooling Survey you requested. If I can be of any other service, please let me know.

Sincerely,



Victor J. Polich, Jr.  
Director  
Engineering and Maintenance

VJP/jmk

1 Encl.

cc: Bernie Eikmeier

**GEOHERMAL HEATING AND COOLING SURVEY**

PERMIT NUMBER 85-6010

PERMITTEE Methodist Hospital

SYSTEM LOCATION 6500 Excelsior Blvd., St. Louis Park, MN 55426

**NAMES AND LOCATIONS OF FACILITIES:**

Methodist Hospital

6500 Excelsior Blvd.

St. Louis Park, MN 55426

TOTAL AREA SERVICED: 560,000 Square feet

**WATER SOURCE**

Number of wells connected to the system 1

Enclosed is the well information we have on file regarding this installation. Please indicate if this data is accurate and/or submit any additional well data that is available. If no information is enclosed or available, please complete the enclosed Water Well Information form(s).

Are water level measurements taken on the production well(s) or observation well(s)? [ ] Yes [x] No If yes, please submit a summary of the data.

**SYSTEM INFORMATION**

Number of years since original system was installed: 31

Date system was put on line: Summer 1959

Is this a once through or closed loop system (describe and attach a simple schematic drawing) ?

Once through cooling system. Water pumped from the deep well is circulated through cooling coils in air handling units. Water from the air handlers is circulated to the condensers of two chillers. From the chillers, water is discharged to the Minnehaha Creek and used for irrigation of lawns on campus.

(147)

Describe any major system modifications and give the completion date:

No major modifications. Pump size increased in 1973 to present 125hp.

Since then, air handling units relying on well water have decreased in number.

Average water temperature:

Heating \_\_\_\_\_ intake; \_\_\_\_\_ discharge  
Cooling 51°F intake: 70° discharge

System size rating:

Heating N/A (BTU/H) Cooling 2269 (Tons/H)

Actual peak load:

Heating \_\_\_\_\_ (BTU) Cooling est. 2100 (Tons)

Energy efficiency of systems:

Number of chillers/heat pumps in system 3  
Coefficient of Performance (COP) for heat pump \_\_\_\_\_  
Average Energy Efficiency Ratio (EER) for heat pump \_\_\_\_\_  
If no heat pump, chiller efficiency rating 83%  
Number of chillers or heat pumps in system 3  
Size rating of chillers/heat pumps 650 tons - 650 tons - 325 tons

General Water Use Efficiency:

Average Efficiency of Water Use 49% (gal/ton) cooling  
\_\_\_\_\_ (gal/BTU) heating  
How much water is recirculated? chilled loop - all once through - none  
How much water is lost in the system, where is it lost and how is the amount of water loss determined?

N/A

If cooling towers are part of the system, how many are there, how much evaporative loss occurs in this loop, and how is the amount of water loss determined?

1 cooling tower, four cycle operation evaporative rate 25% determined by make up minus blowdown.





What is the design capacity of the towers? 750 tons  
If cooling towers are not present in the system please describe the feasibility of adding towers including any site and/or system limitations.

---

---

---

---

---

---

---

---

**WATER USAGE**

Indicate the percentage of all primary and secondary uses of the water:

       Heating                        X   Air conditioning  
       Processing                           Other: \_\_\_\_\_

Average pumpage: \_\_\_\_\_ gpm; \_\_\_\_\_ hours/day; \_\_\_\_\_ months/year

Are flow meters used to determine water usage? [X]Yes [ ]No

If meters are not used, describe how the amount of water appropriated is determined.

---

---

---

**WATER DISPOSAL**

Indicate any water treatment that is done before or after the water goes through the system.

Pretreatment chlorine  $\checkmark$  .03 mg/L, Chemtex product, C-130 corrosion inhibitor

---

What percentage of the water is discharged and what is the water discharged to?

100% - 20 percent to lawn sprinklers, 80 percent to Minnehaha Creek

149

If water is discharged into a storm sewer indicate the receiving water for the sewer outlet, if known.

NO STORM SEWER - Direct discharge to Minnehaha Creek

List any discharge authorizations required for the system.

NPDS Permit #MN0002470

Indicate any regulated discharge limitations relating to water temperature, quality or quantity.

Flow - no restriction

Temp - max, 86°F

Total residual chlorine - .03 mg/L, ave., .05 mg/L max.

#### WATER CONSERVATION

Does the system use variable speed pumps?  Yes  No  
Are any load or system controls used to reduce water requirements by reducing the operating load conditions (i.e. load shedding, temperature set points)?

Yes. All air handling units are temperature controlled to throttle down water use upon temperature satisfaction.

List any other measures utilized to reduce water use:

Water discharged from air handling units is cycled through chiller condensers prior to dumping.

What changes can be done to the system to reduce water use?

Convert entire hospital to closed loop chilled water system.

What alternatives exist for reuse of the discharge water?

No present alternatives to reuse. This well is part of the containment lens that is being used to prevent spread of pollutants from the Rielly tar plant in St. Louis Park. A 99 year pumping plan requires the operation of this well for containment purposes.

Indicate any anticipated future changes in water use and state reasons for projected increases or decreases.

Anticipate converting to closed loop. However, we want to use well water for condensing water in the chillers.

Please provide us the following information about the person that completed the survey.

*MAN*  
*copy*  
Name B. D. Eikmeier  
Title Plant Operations Supervisor  
Telephone Number 932-5106

Please give the name and phone number of someone that can provide additional information, if different than above.

Contact Person Victor J. Polich, Jr., Director of Eng. & Maint.  
Telephone Number (612) 932-5103

**This survey is to be completed and mailed by September 15, 1989 to:**

Department of Natural Resources - Division of Waters  
Attn: Jim Japs  
Geothermal Heating and Cooling Survey  
Box 32, 500 LaFayette Road  
St. Paul, MN 55155-4032

(151)


MINNESOTA CONSERVATION DEPARTMENT  
DIVISION OF WATERS

STATEMENT ON APPROPRIATION OF WATER

85-6010  
66-5517

Before January 1, 1966, mail report to Director, Division of Waters,  
Centennial Office Bldg., St. Paul, Minnesota 55101.

Location of appropriation 6500 Excelsior Blvd.



Section 20  
Twp. 117  
Range 21

City or town \_\_\_\_\_  
County Rd #3

Owner (Asbury Methodist Hospital)

Address \_\_\_\_\_

Person in Charge: \_\_\_\_\_, Adm. M. E. Nordstrom, Chairman of the Board  
C. G. Petherford, President.

Ground Water (List each well separately)	
Depth of well, Ft.	<u>485</u>
Diameter of casing, In.	<u>20"</u>
Date of completion	<u>1960</u>
Driller	_____
Address	_____
Rated capacity of pump	<u>1200 gpm</u>
Usual pumping rate	_____
Water level, pumping	_____
Water level, not pumping	_____

Surface Water	
Source of water	_____
Number of pumps	_____
Rated capacity of pumps	_____
Date appropriation was first begun	_____

The above installation is now equipped with \_\_\_\_\_

The water appropriated is used for \_\_\_\_\_

All water withdrawn is either returned to the land-ground area or put into Winnepesaukee Creek. ~~xxx~~ No water is put into sewer drains. We were one of the first to return water to the ground area.

Allowable appropri. (permits only)	_____
Terminated	_____
Temporary (for use only)	_____
Well log	_____

This statement is filed with the Department of Conservation in compliance with the requirements of Law 1965, Chapter 797, Section 1. The statements hereon are true and correct representation of the facts to the best of my knowledge.


Signed Howard G. Holt

Title \_\_\_\_\_

Date \_\_\_\_\_

85-6010

(152)



METHODIST HOSPITAL  
 ST. LOUIS PARK, MINNESOTA  
 PLOT & DRAINAGE PLAN

OPEN DITCH                      - - - - -  
 UNDERGROUND DRAINAGE PIPE      —————

DRAWN BY: C.B. BEYERLEIGH      12/1/71  
 REV. BY: H.A. HALSTROM      3/10/78

153

